



CITY OF PROVIDENCE

Esek Hopkins Homestead Restoration Project

Addenda # 2

December 3, 2019

(1 Pages)

Acknowledge Addenda on Bid Form

Question 1: The specs call for the windows to be rated at 120 mph winds, which is impossibility.

Answer: Test report will not be required to meet 120 mph wind for window restoration but contractor shall provide full-size samples of window illustrating glazing system, quality of construction and final finishes for approval. See technical Section 08553_1.05 Submittals.

Please acknowledge this addenda on the bid form.

Parks Department Contact Information

Ed Sanchez 401-680-7206 Primary Contact
Parks Department Fax: 401-941-5920 (Attn: Ed Sanchez)
E-Mail: esanchez@providenceri.gov

DEPARTMENT OF PARKS + RECREATION

Roger Williams Boathouse | 1000 Elmwood Avenue Providence, Rhode Island 02905
401 785 9450 ph | 401 941 5920 fax
www.providenceri.com