

**Attachment B - Installation Schedule**

**Central High School**

**6/30/2021**

*The Contractor will supply and install lighting fixtures and lighting controls as listed in the following schedule. Quantities and descriptions are listed for solicitation purposes. Upon contract award the contractor will verify the scope of work in accordance with Attachment C - Supplemental Conditions Section 3.6*

Item Number	Location Description	Floor	Existing Conditions		Proposed Measure		Type	Ceiling Hgt	Mounting Hgt	Ceiling Type	Note	Incentive Program	Unit Incentive \$	Total Incentive \$
			QTY	Description	QTY	Description								
1	Foyer	1	12	2x2T 2L F14T5	12	18W 2x2 Troffer	B	8-10	8-10	Drop /Grid		Upstream	\$90.00	\$1,080.00
2	Hall @ Room 163 to Room 146 Main Office	1	15	8"RC 1L 42W Lens	15	30W 8" Downlight Kit	I	8-10	8-10	Hard		Upstream	\$15.00	\$225.00
10	Hall @ Room 163 to Room 146 Main Office    Room 146 Main Office	1	3	8"RC 1L 42W Lens	3	30W 8" Downlight Kit	I	8-10	8-10	Hard	Dimmer Switch (2)	Upstream	\$15.00	\$45.00
12	Hall @ Room 163 to Room 146 Main Office    Room 146 Main Office    Room 143 Principal C	1	1	8"RC 1L 42W Lens	1	30W 8" Downlight Kit	I	8-10	8-10	Hard	Dimmer Switch	Upstream	\$15.00	\$15.00
16	Hall @ Room 163 to Room 146 Main Office    Room 146 Main Office    Room 143 Principal C	1	1	8"RC 1L 42W Lens	1	30W 8" Downlight Kit	I	8-10	8-10	Hard		Upstream	\$15.00	\$15.00
24	Hall @ Room 163 to Room 146 Main Office    Gym	1	12	8"RC 1L 42W Lens	12	30W 8" Downlight Kit	I	8-10	8-10	Hard	Wall Station	Upstream	\$15.00	\$180.00
31	Hall @ Room 163 to Room 146 Main Office    Gym    Girls Foyer    Girls Locker Room	1	6	8"RC 1L 42W Lens	6	30W 8" Downlight Kit	I	8-10	8-10	Hard		Upstream	\$15.00	\$90.00
33	Hall @ Room 163 to Room 146 Main Office    Gym    Girls Foyer    Girls Restroom	1	1	8"RC 1L 42W Lens	1	30W 8" Downlight Kit	I	8-10	8-10	Hard		Upstream	\$15.00	\$15.00
44	Hall @ Room 163 to Room 146 Main Office    Gym    Boys Foyer    Boys Locker Room	1	6	8"RC 1L 42W Lens	6	30W 8" Downlight Kit	I	8-10	8-10	Hard		Upstream	\$15.00	\$90.00
46	Hall @ Room 163 to Room 146 Main Office    Gym    Boys Foyer    Boys Restroom	1	1	8"RC 1L 42W Lens	1	30W 8" Downlight Kit	I	8-10	8-10	Hard		Upstream	\$15.00	\$15.00
48	Hall @ Room 175 to Room 194	1	1	8"RC 1L 42W Lens	1	30W 8" Downlight Kit	I	8-10	8-10	Hard		Upstream	\$15.00	\$15.00
82	Hall @ Room 143 to Room 105	1	1	8"RC 1L 42W Lens	1	30W 8" Downlight Kit	I	8-10	8-10	Hard		Upstream	\$15.00	\$15.00
128	Hall @ Stairway 3 to Stairway 4	2	2	8"RC 1L 42W Lens	2	30W 8" Downlight Kit	I	8-10	8-10	Hard		Upstream	\$15.00	\$30.00
131	Hall @ Stairway 3 to Stairway 4    Room 231 Library	2	9	2x2T 2L F14T5	9	18W 2x2 Troffer	B	8-10	8-10	Drop /Grid	Dimmer Switch (4)	Upstream	\$90.00	\$810.00
133	Hall @ Room 235 to Room 253	2	1	8"RC 1L 42W Lens	1	30W 8" Downlight Kit	I	8-10	8-10	Hard		Upstream	\$15.00	\$15.00
156	Hall @ Room 231A to Room 202	2	1	8"RC 1L 42W Lens	1	30W 8" Downlight Kit	I	8-10	8-10	Hard		Upstream	\$15.00	\$15.00
243	Hall @ Stairway 3 to Stairway 4	B	4	8"RC 1L 42W Lens	4	30W 8" Downlight Kit	I	8-10	8-10	Hard		Upstream	\$15.00	\$60.00
259	Hall @ Stairway 3 to Stairway 4    Cafeteria    Room 026 Kitchen	B	3	60W INC JJ	3	LED A19	O	8-10	8-10	Drop /Grid		Upstream	\$3.00	\$9.00
261	Hall @ Stairway 3 to Stairway 4    Cafeteria    Room 026 Kitchen    Cooler	B	1	60W INC JJ	1	LED A19	O	8-10	8-10	Drop /Grid		Upstream	\$3.00	\$3.00
269	Hall Room 044 to Room 068	B	1	8"RC 1L 42W Lens	1	30W 8" Downlight Kit	I	8-10	8-10	Hard		Upstream	\$15.00	\$15.00
298	Hall @ Room 018 to Room 001	B	1	8"RC 1L 42W Lens	1	30W 8" Downlight Kit	I	8-10	8-10	Hard		Upstream	\$15.00	\$15.00