

# **REQUEST FOR PROPOSALS**

## Item Description: BLACKSTONE BOULEVARD PATH IMPROVEMENTS

Date to be opened: October 25, 2021

## Issuing Department: PARKS DEPARTMENT

## **QUESTIONS**

- Please direct questions relative to the bidding process, how to fill out forms, and how to submit a bid (Pages 1-8) to Purchasing Agent Patti Jordan.
  - o Phone: (401) 680-5264
  - o Email: pjordan@providenceri.gov
    - Please use the subject line "RFP Question"
- Please direct questions relative to the Minority and Women's Business Enterprise Program and the corresponding forms (Pages 9-13) to the MBE/WBE Outreach Director for the City of Providence, Grace Diaz
  - o Phone: (401) 680-5766
  - Email: <u>gdiaz@providenceri.gov</u>
    - Please use subject line "MBE WBE Forms"
- Please direct questions relative to the specifications outlined (beginning on page 14) to the issuing department's subject matter expert:
  - Sam Greenwood
  - o **401-680-7299**
  - o sgreenwood@providenceri.Gov

## **<u>Pre-bid Conference (NON-MANDATORY)</u>**

## October 12, 2021 at 10 AM

Meeting on-site at the intersection of Blackstone Blvd/Mount Ave Providence, RI



## **INSTRUCTIONS FOR SUBMISSION**

Bids may be submitted up to **2:15 P.M.** on the above meeting date at the **Department of the City Clerk. Room 311, City Hall. 25 Dorrance Street, Providence.** At 2:15 P.M. all bids will be publicly opened and read at the Board of Contract Meeting in the City Council Chambers, on the 3<sup>rd</sup> floor of City Hall.

- Bidders must submit 2 copies of their bid in sealed envelopes or packages labeled with the captioned Item Description and the City Department to which the RFP and bid are related. (On page 1)
- Communications to the Board of Contract and Supply that are not competitive sealed bids (i.e. product information/samples) should have "**NOT A BID**" written on the envelope or wrapper.
- Only use form versions and templates included in this RFP. If you have an old version of a form <u>do not</u> recycle it for use in this bid.
- The bid envelope and information relative to the bid must be addressed to:

Board of Contract and Supply Department of the City Clerk – City Hall, Room 311 25 Dorrance Street Providence, RI 02903

**\*\***<u>PLEASE NOTE</u>: This bid may include details regarding information that you will need to provide (such as proof of licenses) to the issuing department before the formalization of an award.

This information is <u>NOT</u> requested to be provided in your initial bid by design.

<u>All bids submitted to the City Clerk become public record</u>. Failure to follow instructions could result in information considered private being posted to the city's Open Meetings Portal and made available as a public record. The City has made a conscious effort to avoid the posting of sensitive information on the City's Open Meetings Portal, by requesting that such sensitive information be submitted to the issuing department only at their request.



## **BID PACKAGE CHECKLIST**

Digital forms are available in the City of Providence Purchasing Department Office or online at <a href="http://www.providenceri.gov/purchasing/how-to-submit-a-bid/">http://www.providenceri.gov/purchasing/how-to-submit-a-bid/</a>

The bid package **MUST** include the following, in this order:

- Bid Form 1: Bidder's Blank as the cover page/ 1<sup>st</sup> page (see page 6 of this document)
- Bid Form 2: Certification of Bidder as 2<sup>nd</sup> page (see page 7 of this document)
- Bid Form 3: Certificate Regarding Public Records (see page 8 of this document)
- Forms from the Minority and Women Business Enterprise Program: Based on Bidder Category. See forms and instructions enclosed (pages 9-13) or on: <u>https://www.providenceri.gov/purchasing/minority-women-owned-business-mbewbe-procurement-program/</u>

# \*Please note: MBE/WBE forms must be completed for EVERY bid submitted and must be inclusive of <u>ALL</u> required signatures. Forms without all required signatures will be considered <u>incomplete</u>.

- Bidder's Proposal/Packet: Formal response to the specifications outlined in this RFP, including pricing information and details related to the good(s) or service(s) being provided. Please be mindful of formatting responses as requested to ensure clarity.
- Financial Assurance, *if requested* (as indicated on page 5 of this document under "Bid Terms")

All of the above listed documents are **REQUIRED**. (With the exception of financial assurances, which are only required if specified on page 5.)

\*\*\*Failure to meet specified deadlines, follow specific submission instructions, or enclose all required documents with all applicable signatures will result in disqualification, or in an inability to appropriately evaluate bids.



## **NOTICE TO VENDORS**

- 1. The Board of Contract and Supply will make the award to the lowest qualified and responsible bidder.
- 2. In determining the lowest responsible bidder, cash discounts based on preferable payment terms will not be considered.
- 3. Where prices are the same, the Board of Contract and Supply reserves the right to award to one bidder, or to split the award.
- 4. No proposal will be accepted if the bid is made in collusion with any other bidder.
- 5. Bids may be submitted on an "equal in quality" basis. The City reserves the right to decide equality. Bidders must indicate brand or the make being offered and submit detailed specifications if other than brand requested.
- 6. A bidder who is an out-of-state corporation shall qualify or register to transact business in this State, in accordance with the Rhode Island Business Corporation Act, RIGL Sec. 7-1.2-1401, et seq.
- 7. The Board of Contract and Supply reserves the right to reject any and all bids.
- 8. Competing bids may be viewed in person at the Department of the City Clerk, City Hall, Providence, immediately upon the conclusion of the formal Board of Contract and Supply meeting during which the bids were unsealed/opened. Bids may also be accessed electronically on the internet via the City's <u>Open</u> <u>Meetings Portal</u>.
- 9. As the City of Providence is exempt from the payment of Federal Excise Taxes and Rhode Island Sales Tax, prices quoted are not to include these taxes.
- 10. In case of error in the extension of prices quoted, the unit price will govern.
- 11. The contractor will **NOT** be permitted to: a) assign or underlet the contract, or b) assign either legally or equitably any monies or any claim thereto without the previous written consent of the City Purchasing Director.
- 12. Delivery dates must be shown in the bid. If no delivery date is specified, it will be assumed that an immediate delivery from stock will be made.
- 13. A certificate of insurance will normally be required of a successful vendor.
- 14. For many contracts involving construction, alteration and/or repair work, State law provisions concerning payment of prevailing wage rates apply (<u>RIGL Sec. 37-13-1 et seq.</u>)
- 15. No goods should be delivered or work started without a Purchase Order.
- 16. Submit 2 copies of the bid to the City Clerk, unless the specification section of this document indicates otherwise.
- 17. Bidder must certify that it does not unlawfully discriminate on the basis of race, color, national origin, gender, gender identity or expression, sexual orientation and/or religion in its business and hiring practices and that all of its employees are lawfully employed under all applicable federal, state and local laws, rules and regulations. (See Bid Form 2.)



## **BID TERMS**

- Financial assurances may be required in order to be a successful bidder for Commodity or Construction and Service contracts. <u>If either of the first two checkboxes below is checked, the specified assurance</u> <u>must accompany a bid, or the bid will not be considered by the Board of Contract and Supply</u>. The third checkbox indicates the lowest responsible bidder will be contacted and required to post a bond to be awarded the contract.
  - a) A certified check for **\$\_\_\_\_** must be deposited with the City Clerk as a guarantee that the Contract will be signed and delivered by the bidder.
  - b) A bid bond in the amount of <u>5</u> per centum (%) of the proposed total price, must be deposited with the City Clerk as a guarantee that the contract will be signed and delivered by the bidder; and the amount of such bid bond shall be retained for the use of the City as liquidated damages in case of default.
  - c)  $\square$  A performance and payment bond with a satisfactory surety company will be posted by the bidder in a sum equal to one hundred per centum (100%) of the awarded contract.
  - d) 🗌 No financial assurance is necessary for this item.
- 2. Awards will be made within **sixty (60) days of bid opening**. All bid prices will be considered firm, unless qualified otherwise. Requests for price increases will not be honored.
- 3. Failure to deliver within the time quoted or failure to meet specifications may result in default in accordance with the general specifications. It is agreed that deliveries and/or completion are subject to strikes, lockouts, accidents and Acts of God.

## The following entry applies only for COMMODITY BID TERMS:

4. Payment for partial delivery will not be allowed except when provided for in blanket or term contracts. **The following entries apply only for CONSTRUCTION AND SERVICE BID TERMS:** 

- 5. Only one shipping charge will be applied in the event of partial deliveries for blanket or term contracts.
- 6. Prior to commencing performance under the contract, the successful bidder shall attest to compliance with the provisions of the Rhode Island Worker's Compensation Act, RIGL 28-29-1, et seq. If exempt from compliance, the successful bidder shall submit a sworn Affidavit by a corporate officer to that effect, which shall accompany the signed contract.
- 7. Prior to commencing performance under the contract, the successful bidder shall, submit a certificate of insurance, in a form and in an amount satisfactory to the City.



## **BID FORM 1: Bidders Blank**

- 1. Bids must meet the attached specifications. Any exceptions or modifications must be noted and fully explained.
- 2. Bidder's responses must be in ink or typewritten, and all blanks on the bid form should be completed.
- 3. The price or prices proposed should be stated both in **WRITING** and in **FIGURES**, and any proposal not so stated may be rejected. **Contracts exceeding twelve months must specify annual costs for each year.**
- 4. Bids SHOULD BE TOTALED so that the final cost is clearly stated (unless submitting a unit price bid), however each item should be priced individually. Do not group items. Awards may be made on the basis of *total* bid or by *individual items*.
- 5. All bids MUST BE SIGNED IN INK.

Name of Bidder (Firm or Individual):	
Contact Name:	
Business Address:	
Business Phone #:	
Contact Email Address:	
Agrees to bid on (Write the "Item Description" here):	
If the bidder's company is based in a state other than Rhode Island, list name and contact information for a local ag	gent for service of
process that is located within Rhode Island	
Delivery Date (if applicable):	
Name of Surety Company (if applicable):	
Total Amount in Writing*:	
Total Amount in Figures*:	
* If you are submitting a unit price bid, please insert "Unit Price Bid"	
Use additional pages if necessary for additional bidding details.	

Signature of Representation

Title



## **BID FORM 2: Certification of Bidder**

(Non-Discrimination/Hiring)

Upon behalf of	(Firm or Individual Bidding),
I,	(Name of Person Making Certification),
being its	(Title or "Self"), hereby certify that:

- 1. Bidder does not unlawfully discriminate on the basis of race, color, national origin, gender, sexual orientation and/or religion in its business and hiring practices.
- 2. All of Bidder's employees have been hired in compliance with all applicable federal, state and local laws, rules and regulations.

I affirm by signing below that I am duly authorized on behalf of Bidder, on

this\_\_\_\_\_day of \_\_\_\_\_20\_\_\_.

Signature of Representation

Printed Name



## **BID FORM 3: Certificate Regarding Public Records**

Upon behalf of	(Firm or Individual Bidding),
I,	(Name of Person Making Certification),
being its	(Title or "Self"), hereby certify an

understanding that:

- 1. All bids submitted in response to Requests for Proposals (RFP's) and Requests for Qualification (RFQ's), documents contained within, and the details outlined on those documents become public record upon receipt by the City Clerk's office and opening at the corresponding Board of Contract and Supply (BOCS) meeting.
- 2. The Purchasing Department and the issuing department for this RFP/RFQ have made a conscious effort to request that sensitive/personal information be submitted directly to the issuing department and only at request if verification of specific details is critical the evaluation of a vendor's bid.
- 3. The requested supplemental information may be crucial to evaluating bids. Failure to provide such details may result in disqualification, or an inability to appropriately evaluate bids.
- 4. If sensitive information that has not been requested is enclosed or if a bidder opts to enclose the defined supplemental information prior to the issuing department's request in the bidding packet submitted to the City Clerk, the City of Providence has no obligation to redact those details and bears no liability associated with the information becoming public record.
- 5. The City of Providence observes a public and transparent bidding process. Information required in the bidding packet may not be submitted directly to the issuing department at the discretion of the bidder in order to protect other information, such as pricing terms, from becoming public. Bidders who make such an attempt will be disqualified.

I affirm by signing below that I am duly authorized on behalf of Bidder, on

this\_\_\_\_\_day of\_\_\_\_\_20\_\_\_.

Signature of Representation

Printed Name



## **WBE/MBE Form Instructions**

The City of Providence actively seeks Minority and Women business enterprises to participate in bids to meet the City's procurement needs. Pursuant to the City of Providence Code of Ordinances, Chapter 21, Article II, Sec. 21-52 (Minority and Women's Business Enterprise) and Rhode Island General Laws (as amended), Chapter 31-14, et seq. (Minority Business Enterprise), Minority Business Enterprise (MBE) and Women's Business Enterprise (WBE) participation goals apply to contracts.

The goal for Minority Business Enterprise (MBE) participation is **10%** of the total bid value. The goal for Women's Business Enterprise (WBE) participation is **10%** of the total bid value. The goal for combined MBE/WBE participation is **20%** of the total bid value.

Only businesses certified with the State of Rhode Island as minority and/or women business enterprises are counted towards the City's goals. Eligible minority or women-owned businesses are encouraged to seek certification from the State of Rhode Island Minority Business Enterprise Compliance Office at: http://odeo.ri.gov/offices/mbeco/

**Note**: MBE certification with the State of Rhode Island on the basis of Portuguese heritage is not currently recognized by the City of Providence's MBE program.

### **Bid Requirements:**

*All Bidders:* All bidders must complete and submit the *MBE/WBE Participation Affidavit* indicating whether or not they are a statecertified MBE/WBE and acknowledging the City's participation goals. Submission of this form is required with **every bid**. Your bid will not be accepted without an affidavit.

*Bidders who will be subcontracting:* Bidders who will be subcontracting must submit the *Subcontractor Disclosure Form* as part of their bid submission. All subcontractors, regardless of MBE/WBE status, must be listed on this form. Business NAICS codes can be found at <u>https://www.naics.com/search/</u>. Awarded bidders are required to submit *Subcontractor Utilization and Payment Reports* with each invoice.

## Waiver Requests:

If the percentage of the total amount of the bid being awarded to MBE or WBE vendors is less than 20% (Box F on the Subcontractor Disclosure Form) and the prime contractor is not a Rhode Island State-certified MBE or WBE, the Bidder must complete the *MBE/WBE Waiver Request Form* for review. Waivers will be considered on a case by case basis.

No waiver will be granted unless the waiver request includes documentation that demonstrates that the Bidder has made good faith efforts to achieve the City's stated participation goals. Waivers must be reviewed and signed by the City of Providence's MBE/WBE Outreach Director, Grace Diaz, or her designee. Department Directors cannot recommend a bidder for award if this form is applicable and absent. If the bid does not meet the participation goals of the City of Providence and a waiver is not filed with the signature of the MBE/WBE Outreach Director or her designee, the bid will not be accepted.

#### Verifying MBE/WBE Certification

It is the responsibility of the bidder to confirm that every MBE/WBE named in a proposal and included in a contract is certified by the Rhode Island Minority Business Enterprise Compliance office. The current MBE/WBE directory is available at the State of RI MBE Office, One Capitol Hill, 2nd Floor, Providence, RI, or online at <a href="http://odeo.ri.gov/offices/mbeco/mbe-wbe.php">http://odeo.ri.gov/offices/mbeco/mbe-wbe.php</a>. You can also call (401) 574-8670 to verify certification, expiration dates, and services that the MBE/WBE is certified to provide. Note: MBE certification with the State of Rhode Island on the basis of Portuguese heritage is not currently recognized by the City of Providence's MBE program.



#### **Form Instructions:**

Access all bid forms from <u>http://www.providenceri.gov/oeo/</u> or <u>http://www.providenceri.gov/purchasing/minority-women-owned-business-mbewbe-procurement-program/</u>. **Download** the forms as blank PDFs. Once saved on your computer, fill them out using the Adobe program. The fillable PDFs must be completed in Adobe in order to be saved property. Google Chrome and similar platforms do not allow for the forms to be saved as filled PDFs. Therefore, please download the blank forms to your computer, then fill them out and save.

## Assistance with Form Requirements

Examples of completed forms can be found on the City of Providence website at <u>http://www.providenceri.gov/oeo/</u> or <u>http://www.providenceri.gov/purchasing/minority-women-owned-business-mbewbe-procurement-program/</u>.

## **Contract Requirements:**

Prime contractors engaging subcontractors must submit the *Subcontractor Utilization and Payment Report* to the City Department's Fiscal Agent with every invoice and with request for final payment. This form is not submitted as a part of the initial bid package.

For contracts with duration of less than 3 months, this form must be submitted along with the contractor's request for final payment. The form must include all subcontractors utilized on the contract, both MBE/WBE and non-MBE/WBE, the total amount paid to each subcontractor for the given period and to date. During the term of the contract, any unjustified failure to comply with the MBE/WBE participation requirements is a material breach of contract.

## **Questions?**

For more information or for assistance with MBE/WBE Forms, contact the City of Providence MBE/WBE Outreach Director, Grace Diaz, at <u>mbe-wbe@providenceri.com</u> or (401) 680-5766.



BOARD OF CONTRACT AND SUPPLY

CITY OF PROVIDENCE, RHODE ISLAND

## **MBE/WBE PARTICIPATION AFFIDAVIT**

Item Discussion (as seen on RFP):

Prime Bidder: \_\_\_\_\_\_ Prime Bidder (Company) Phone Number: \_\_\_\_\_\_

Which one of the following describes your business' status in terms of Minority and/or Woman-Owned Business Enterprise certification with the State of Rhode Island? \_\_\_\_\_MBE \_\_\_\_\_WBE \_\_\_\_\_Neither MBE nor WBE

## By initialing the following sections and signing the bottom of this document in my capacity as the contractor or an authorized representative of contractor, I make this Affidavit:

It is the policy of the City of Providence that minority business enterprises (MBEs) and women business enterprises (WBEs) should have the maximum opportunity to participate in procurements and projects as prime contractors and vendors. Pursuant to Sec. 21-52 of the Providence Code of Ordinances and Chapter 31-14 *et seq*. of the Rhode Island General Laws (as amended), MBE and WBE participation goals apply to contracts.

The goal for Minority Business Enterprise (MBE) participation is 10% of the total bid value. The goal for Women's Business Enterprise (WBE) participation is 10% of the total bid value. The goal for combined MBE/WBE participation is 20% of the total bid value.

I acknowledge the City of Providence's goals of supporting MBE/WBE certified businesses. Initial \_

If awarded the contract, I understand that my company must submit to the Minority and Women's Business Coordinator at the City of Providence (MBE/WBE Office), copies of all executed agreements with the subcontractor(s) being utilized to achieve the participation goals and other requirements of the RI General Laws. **I understand that these documents must be submitted prior to the issuance** of a notice to proceed. Initial

<u>I understand that, if awarded the contract, my firm must submit to the MBE/WBE Office canceled checks and reports</u> required by the MBE/WBE Office on a quarterly basis verifying payments to the subcontractors(s) utilized on the contract. Initial

If I am awarded this contract and find that I am unable to utilize the subcontractor(s) identified in my Statement of Intent, I understand that I must substitute another certified MBE and WBE firm(s) to meet the participation goals. <u>I understand that I may not make a</u> substitution until I have obtained the written approval of the MBE/WBE Office. Initial

If awarded this contract, I understand that authorized representatives of the City of Providence may examine the books, records and files of my firm from time to time, to the extent that such material is relevant to a determination of whether my firm is complying with the City's MBE/WBE participation requirements.

Initial \_\_\_\_

I do solemnly declare and affirm under the penalty of perjury that the contents of the foregoing Affidavit are true and correct to the best of my knowledge, information and belief.

Signature of Bidder

Printed Name

Company Name

Date



## BOARD OF CONTRACT AND SUPPLY

CITY OF PROVIDENCE, RHODE ISLAND

## SUBCONTRACTOR DISCLOSURE FORM

\_\_\_\_\_

Fill out this form only if you WILL SUBCONTRACT with other parties. If you will not subcontract any portion of the proposed bid, do not fill out this form.

Prime Bidder: \_\_\_\_\_ Primary NAICS\_\_\_\_\_

Code:\_\_

Item Description (as seen on RFP):\_\_\_\_\_

**Please list all Subcontractors below.** Include the total dollar value that you propose to share with each subcontractor and the dollar amount to be subcontracted. Please check off MBE and WBE where applicable. The directory of all state-certified MBE/WBE firms is located at <u>www.mbe.ri.gov</u>. Business NAICS codes can be found at

https://www.naics.com/search/

Proposed Subcontractor	MBE	WBE	Primary NAICS Code	Date of Mobilization	<b>\$ Value of Subcontract</b>
					\$
					\$
					\$
					\$
					\$
					\$
A. MBE SUBCONTRACTED AMO	UNT:				\$
B. WBE SUBCONTRACTED AMOUNT:			\$		
C. NON MBE WBE SUBCONTRAC	C. NON MBE WBE SUBCONTRACTED AMOUNT:			\$	
D. DOLLAR AMOUNT OF WORK DONE BY THE PRIME CONTRACTOR:			\$		
E. TOTAL AMOUNT OF BID (SUM	1 OF A, B,	C, & D):			\$
F. PERCENTAGE OF BID SUBCO (Divide the sum of A and B by E and	NTRACTE I multiply 1	CD TO ME result by 1	BEs AND WBI 00).	Es.	%

Please read and initial the following statement acknowledging you understand. If the percentage of the total amount of the bid being awarded to MBE or WBE vendors is less than 20% (Box F) and the prime contractor is NOT a Rhode Island State-certified MBE or WBE, you must fill out the MBE/WBE WAIVER REQUEST FORM for consideration by City of Providence MBE/WBE Outreach Director. Initial \_\_\_\_\_



## MBE/WBE Waiver Request Form

## Fill out this form only if you are subcontracting and did not meet the 20% MBE/WBE participation goal. State-certified MBE or WBE Prime Bidders are NOT REQUIRED to fill out this form.

Submit this form to the City of Providence MBE/WBE Outreach Director, Grace Diaz, at mbe-wbe@providenceri.gov, for review **prior to bid submission.** This waiver applies only to the current bid which you are submitting to the City of Providence and does not apply to other bids your company may submit in the future.

Prime Bidder:	
Company Trade:	
Item Discussion (as seen on RFP):	

To receive a waiver, you must list the certified MBE and/or WBE companies you contacted, the name of the primary individual with whom you interacted, and the reason the MBE/WBE company could not participate on this project.

MBE/WBE Company Name	Individual's Name	Company Trade	Why did you choose not to work with this company?

I acknowledge the City of Providence's goal of a combined MBE/WBE participation is 20% of the total bid value. I am requesting a waiver of \_\_\_\_\_\_\_% MBE/WBE (20% minus the value of **Box F** on the Subcontractor Disclosure Form). If an opportunity is identified to subcontract any task associated with the fulfillment of this contract, a good faith effort will be made to select MBE/WBE certified businesses as partners.

Signature of Prime Contractor

Printed Name

Date Signed

Signature of City of Providence MBE/WBE Outreach Director Printed Name of City of Providence MBE/WBE Outreach Director Date Signed



## BOARD OF CONTRACT AND SUPPLY

CITY OF PROVIDENCE, RHODE ISLAND

## **SUPPLEMENTAL INFORMATION**

If the issuing department for this RFP determines that your firm's bid is best suited to accommodate their need, you will be asked to provide proof of the following prior to formalizing an award.

An inability to provide the outlined items at the request of the department may lead to the disqualification of your bid.

This information is <u>NOT</u> requested to be provided in your initial bid that you will submit to the City Clerk's office by the "date to be opened" noted on page 1. This list only serves as a list of items that your firm should be ready to provide on request.

<u>All bids submitted to the City Clerk become public record</u>. Failure to follow instructions could result in information considered private being posted to the city's Open Meetings Portal and made available as a public record.

## You must be able to provide:

- Business Tax ID will be requested after an award is approved by the Board of Contract and Supply.
- Proof of Insurance



## **BID FORM 3: Supplemental Bid Form**

To whom it may concern:

1. The undersigned, having familiarized (himself) (themselves) (itself) with the **BLACKSTONE BOULEVARD PATH IMPROVEMENTS** bid affecting the cost of work, and with the Contract Documents (which includes the Invitation for Bids, Instructions to Bidders, Form of Bid Bond, Form of Agreements, form of Non-Collusive Affidavit, Addenda (if any), Drawings, Technical Specification, Form of Surety Bond(s); as prepared by the Providence Parks Department, and on file in the office of the City Clerk 3<sup>rd</sup> Floor, City Hall, Providence, RI 02903, hereby proposes to furnish all supervision, technical personnel, labor, materials, machinery, tools, equipment and services including utility and transportation services, and to perform such other required work for the **BLACKSTONE BOULEVARD PATH IMPROVEMENTS** and such other required and incidental work, complete, all in accordance with the above listed documents and for the unit prices for work in-place for the following items and quantities.

2. In submitting this Bid, the bidder understands that the right is reserved by The Providence Parks Department to reject any and all Bids, If written notice of acceptance of this Bid is mailed, telegraphed or delivered to the undersigned within (90) days after the opening thereof, or at any time thereafter before this Bid is withdrawn, the undersigned agrees to execute and deliver an Agreement in the prescribed form and furnish the required bond within (10) days after the Agreement is presented to him/her for signature.

Herewith in accordance with the instructions to Bidders.

**3.** Attached hereto is an affidavit in proof that the undersigned has not colluded with any person in respect to this. Bid or any bids for the Contractor for which this Bid is submitted. Also attached is a Statement of Bidder's Qualifications.

4. Application unit prices are contained in the Agreement (established as the result of either a Unit Price Bid or a Supplemental Schedule of Unit Prices), the City of Providence may order the Contractor to proceed with desired changes in the work, the value of such changes to be determined by the measured quantities involved and the application unit prices specified in the Contract.

**5.** The City of Providence reserves the right to determine the lowest responsible Bidder based on past experience with the City and/or recommendations by City and/or state agencies with an interest in this procurement. The City reserves the right to award the project to the appropriate bidder in the best interest of the City of Providence.

## **CERTIFICATION OF NON-SEGREGATED FACILITIES**

The Bidder certifies that he/she does not maintain or provide for his/her employees any segregated facilities at any of his establishments, and that he/she does not permit his/her employees to perform their services at any location, under his/her control, where segregation facilities are maintained. The Bidder agrees that a breach of this certification will be a violation of the Equal Opportunity Clause in any contract resulting from acceptance of this Bid. As used in this certification, term "segregation facilities" means any waiting rooms, work rooms, rest rooms and wash rooms, restaurants and other eating areas, time clocks, locker rooms and other storage or dressing areas, parking lots, drinking fountains, recreation or entertainment areas, transportation and housing facilities provided for employee which are segregated by explicit directive or are in fact segregated on basis of race, color, religion, or national origin, because of habit, local custom, or otherwise. The Bidder agrees that (except where he/she has obtained identical certification from proposed subcontractors for specific time periods) he/she will obtain identical certification from proposed subcontractor prior to the award of subcontracts exceeding \$10,000.00 which are not exempt from provisions of the Equal Opportunity Clause, and that he /she will retain such certifications in his/her files.

NOTE: The penalty for making false statements in offers is prescribed in 18 U.S.C. & 1001.

DATE \_\_\_\_\_, 20\_\_\_\_



Name of Bidder and Official Address:	Name of Authorized Representative (Contact):
	By(Signature)
E-Mail:	Title Phone:
Bidder shall indicate, in space provided, the earliest possible Project Start-up Date:	

ADDENDA: The undersigned acknowledges receipt of the following Addenda, if any, and has included the provisions thereof in this Bid (If Any):

<u>Addendum No.</u>	Date	Addendum No.	Date
	, 20		, 20
	, 20		
Sub-Contractors (	If Any):		

Name:	Scope of Work:	_MBE / WBE
<u>Name:</u>	Scope of Work:	_MBE / WBE
<u>Name:</u>	Scope of Work:	_MBE / WBE



## SUPPLEMENTAL BID FORM

## BLACKSTONE BOULEVARD PATH IMPROVEMENTS

#### BASE BID:

Blackstone Boulevard Path Improvements Project is located in the median of Blackstone Blvd from Mount Ave to Rochambeau Ave (south to north) in Providence RI. Blackstone Blvd is an active walking trail that extends from Butler Avenue towards Hope Street for a total of 1.6 miles. The Providence Parks Department is seeking to repair a segment of the path to correct uneven walkway surfacing and to prevent further erosion in sloped areas. The success of this project would potentially invigorate restoration on future segments of the trail.

The Providence Parks Department is seeking qualified contractors to provide construction services for regrading and re-surfacing eroded path. Proposed work will include but is not limited to: grading, bituminous sidewalks, stone dust path installation, bio swale, rip rap and seeding.

All Contractors shall possess substantial credentials in good standing and be able to perform tasks as describe in this Bid. Contractor shall be familiar with all Local and State Regulations to ensure public health and safety.

In addition to stating the Total Base Bid, The bidder shall state Unit Prices for related work listed under each bid item which represents the work items included in the Total Base Bid., The Unit Prices are quoted for computing adjustments to the Base Bid prior to Contract award, as well as during the course of construction, based upon extra work ordered by the City or for work countermanded, reduced or omitted by the City in order to stay within the Project budget.

Base Bid Items and Unit prices are to be Completed prices to be added or deducted on the basis of quantities of work involved, for each item in place in the unit indicated.

BASE BID: The Base Bid scope of work for this project shall include, but not be limited to the following: complete furnishing and installing stone dust path, minor grading, chip-seal asphalt paving, sub base reconstruction, tree protection, installation of concrete pads and benches from stockpile, loam and hydroseeding

ADD/ALTERNATES: #1 - Remove existing trash receptacle, furnish & install new 55 gal trash receptacle on 30" sq concrete pad. #2 – Furnish & install stabilized stone dust with organic lock additive.

#### All Work Included in this Project Shall be Completed for the lump sum of:

Dollars

(\$\_\_\_\_\_), TOTAL BASE BID

#### **ADD ALTERNATES:**

## 1. Add Alt # 1 – F&I 1 (ONE) 55 GAL TRASH RECEPTACLE ON CONCRETE PAD - Per Lump Sum

price in writing

LS

BIDDER:



2. Add Alt #2 - F&I 3" STABILIZED STONEDUST WITH ORGANIC LOCK APPLICATION COMPLETE - Per Lump Sum

	LS	\$
price in writing		
NIT PRICES:		
1. F&I TEMPORARY TREE AND	PLANT PROTECTION	N - Per linear Foot
	LF	\$
tice in writing		
2. F&I TEMPORARY TREE TRU	NK PROTECTION - Pe	er linear Foot
	LF	\$
rice in writing		
3. F&I SILT SOCK EROSION CO	NTROL – Per Linear Fo	oot
	LF	\$
rice in writing		
4. F&I CATCH BASIN SEDIMEN	T TRAP – Per Each	
	LF	\$
rice in writing		
5. F&I PROCESSED GRAVEL BA	SE 4" DEPTH - Per Cu	ibic Yard
	СҮ	\$
rice in writing		
6. F&I 2" PROCESSED STONEDU	UST PATH COMPLETH	E - Per Square Yard
	SY	\$

BIDDER: \_\_\_\_\_



## 7. F&I 3" STABILIZED STONEDUST WITH ORGANIC LOCK APPLICATION COMPLETE - Per Sq Yard

	SY	\$	
price in writing			
8. F&I 3/8" CRUSHED STONE CH	IIP SEAL BITUMINOU	JS SIDEWALK COMPLETE - Per Squ	ıare F
· · · · · ·	SF	\$	
price in writing			
9. F&I 4" 3 (THREE) CONCRETE	PADS FOR BENCHES	COMPLETE – Per Square Foot	
	SF	\$	
price in writing			
10. INSTALL 3 (THREE) WOOD &	IRON BENCHES FRO	M STOCKPILE – Lump Sum	
	LS	\$	
orice in writing			
11. F&I ¾" SCREENED LOAM INS	TALLED COMPLETH	2 - Per Cubic Yard \$	
11. F&I <sup>3</sup> 4" SCREENED LOAM INS	TALLED COMPLETH	2 - Per Cubic Yard \$	
11. F&I <sup>3</sup> 4" SCREENED LOAM INS price in writing 12. FINE GRADE <sup>1</sup> 4" HYDRO SEEI	TALLED COMPLETH	2 - Per Cubic Yard \$ juare Foot	
11. F&I <sup>3</sup> 4" SCREENED LOAM INS price in writing 12. FINE GRADE <sup>1</sup> 4" HYDRO SEEI	TALLED COMPLETH CY D COMPLETE - Per So SF	E - Per Cubic Yard \$ juare Foot \$	
<ul> <li>11. F&amp;I ¼" SCREENED LOAM INS</li> <li>price in writing</li> <li>12. FINE GRADE ¼" HYDRO SEEI</li> <li>price in writing</li> <li>13. F&amp;I 4 (FOUR) +/-3 FT x +/-4 FT</li> </ul>	STALLED COMPLETH CY D COMPLETE - Per So SF BOULDER COMPLET	E - Per Cubic Yard  \$ quare Foot  \$ TE - Per Each	
<ul> <li>11. F&amp;I <sup>3</sup>/<sub>4</sub>" SCREENED LOAM INS</li> <li>brice in writing</li> <li>12. FINE GRADE <sup>1</sup>/<sub>4</sub>" HYDRO SEEI</li> <li>brice in writing</li> <li>13. F&amp;I 4 (FOUR) +/-3 FT x +/-4 FT</li> </ul>	TALLED COMPLETH CY D COMPLETE - Per So SF BOULDER COMPLET EA	E - Per Cubic Yard  \$ quare Foot  \$ CE - Per Each \$	
<ul> <li>11. F&amp;I <sup>3</sup>/<sub>4</sub>" SCREENED LOAM INS</li> <li>price in writing</li> <li>12. FINE GRADE <sup>1</sup>/<sub>4</sub>" HYDRO SEEI</li> <li>price in writing</li> <li>13. F&amp;I 4 (FOUR) +/-3 FT x +/-4 FT</li> <li>price in writing</li> </ul>	TALLED COMPLETH CY D COMPLETE - Per So SF BOULDER COMPLET EA	E - Per Cubic Yard  guare Foot    \$	
11. F&I ¾" SCREENED LOAM INS         price in writing         12. FINE GRADE ¼" HYDRO SEEI         price in writing         13. F&I 4 (FOUR) +/-3 FT x +/-4 FT         price in writing         14. F&I EROSION CONTROL JUTE	TALLED COMPLETH CY D COMPLETE - Per So SF BOULDER COMPLET EA E MESH FOR SLOPE	E - Per Cubic Yard  \$  guare Foot  \$ (TE - Per Each  \$ \$ ≤ 3:1 - Per Linear Foot	
11. F&I ¾" SCREENED LOAM INS         price in writing         12. FINE GRADE ¼" HYDRO SEEI         price in writing         13. F&I 4 (FOUR) +/-3 FT x +/-4 FT         price in writing         14. F&I EROSION CONTROL JUTE	TALLED COMPLETH CY D COMPLETE - Per So SF BOULDER COMPLET EA E MESH FOR SLOPE LF	E - Per Cubic Yard guare Foot  TE - Per Each ≤ 3:1 - Per Linear Foot	



Please note that the list above is not intended to include all items required to complete the base bid scope of work but can and shall be used to adjust the contract prior to or after award – in the best interest of the City of Providence.

#### **BID DOCUMENTS:**

The complete set of Bid Documents consists of the Bid Form, Technical Specifications, Minority Participation Forms, and the following Drawings:

#### **DRAWINGS:**

## **BLACKSTONE BOULEVARD PATH IMPROVEMENTS PROJECT**

- Cover Sheet
   L-1
- Existing Plans (includes Details) L-2 L-4
- Site Construction Plans (includes Grading & Details) L-5 L-7

#### **TECHNICAL SPECIFICATION:**

Attachment A -	BLACKSTONE	E BOULEVARD PATH IMPROVEMENTS PROJECT TECH SPEC
	• 010000	General Requirements
	• 015639	Temporary Tree and Plant Protection
	• 024119	Selective Demolition
	• 312000	Earth Moving
	• 312213	Rough Grading
	• 312500	Erosion and Sedimentation Controls
	• 321216	Asphalt Paving
	• 321313	Concrete Paving
	• 321320	Stone Dust Walk
	• 321540	Organic Lock Stabilized Pathway
	• 329113	Soil Preparation
	• 329119	Landscape Grading
	• 329200	Turf and Grasses

#### **ADDITIONAL INFORMATION REQUIRED WITH BID:**

- Qualifications to Perform Work See Form Below for Information Required
- Minority Participation Forms 10% MBE / 10 % WBE Goal on this Project
- Addenda (If Any) Must Be Acknowledged on Bid Form
- Product Information for Items Submitted as 'Or Equal' to Specified Materials



## PROVISIONS OF THIS PROJECT:

- Upon the Issuance of the Award from the Board of Contract the City shall issue a Contract to be executed by the City and the vendor incorporating the bid specifications. All Provisions of the Specifications are binding.
- Any Permits Required by the City of Providence and/or State of Rhode Island Shall be Obtained by the Vendor Permit Fees by the City of Providence Shall be Waived the State ADA Fee Must be Paid
- The Davis Bacon Act Applies (HUD Projects) Prevailing Wages Must Be Paid for On Site Hours On-Site Interviews will be Conducted During the Project – Employees Shall be Advised of the Prevailing Wage Rates Prior to Mobilization on Site
- Certified payrolls Must be Submitted With Pay Requests Including Monthly Utilizations Form
- Performance and Payment Bonds (If Required) Must be Submitted within 10 Days of Award or Bid Bond Will be Forfeited
- An Insurance Certificate Shall be Submitted to the City Within 10 Days of Award
- A Copy of the Vendors Contractor's License Must be Submitted within 10 Days of Award
- All On-Site Personnel Shall be Licensed (If Required) and Shall have Proof of All Licenses Required by the State of Rhode Island to Perform the Work Required
- Pay Requests Must be Submitted on Approved AIA Billing Documents (City will Provide if Needed)
- All Subcontractors Shall be Listed on the Bid Form All Insurance & Payroll Requirements Apply
  - General Contractor Shall be the Insurance Certificate Holder and the City Shall be Named as 'Additionally Insured' with Respect to Liability Insurance
- A Submittal Log Must be Submitted within 10 Days of Award

#### **CLOSE OUT DOCUMENTS:**

- Prior to Final Payment the Vendor Shall Provide the Following:
  - Copies of Permits Signed off and Approved (If Any)
  - o Operating Manuals and Warranties Shall Be Transferred and/or Delivered
  - o Full and Completed As-Built Drawings Shall be Submitted for Approval
  - Training Shall be Provided to City Personnel (If Required)
  - Certification by Manufactures Representative (If Required)

#### **QUALIFICATIONS:**

Qualifications will be evaluated on the basis of similar project experience for:

- a. Completion of at least 3 similar projects within the past five years.
- b. Size and dollar value of similar completed projects.
- c. Contractor's performance with similar projects. (references will be checked)
- d.. Relevant experience of individuals assigned to the project.

Questions regarding this bid package shall be submitted via e-mail to **Patti Jordan** at <u>pjordan@providenceri.gov</u> and **Brian Byrnes**, **Parks Design Team Manager** at mgardner@providenceri.gov, no later than five (5) working days before the bid opening date.

Sam Greenwood is the project contact and can be reached at 401-680-7299.



## **TECHNICAL SPECIFICATIONS**

"General Decision Number: RI20210001 09/10/2021

Superseded General Decision Number: RI20200001

State: Rhode Island

Construction Types: Building, Heavy (Heavy and Marine) and Highway

Counties: Rhode Island Statewide.

BUILDING CONSTRUCTION PROJECTS (does not include residential construction consisting of single family homes and apartments up to and including 4 stories) HEAVY, HIGHWAY AND MARINE CONSTRUCTION PROJECTS

Note: Under Executive Order (EO) 13658, an hourly minimum wage of \$10.95 for calendar year 2021 applies to all contracts subject to the Davis-Bacon Act for which the contract is awarded (and any solicitation was issued) on or after January 1, 2015. If this contract is covered by the EO, the contractor must pay all workers in any classification listed on this wage determination at least \$10.95 per hour (or the applicable wage rate listed on this wage determination, if it is higher) for all hours spent performing on the contract in calendar year 2021. If this contract is covered by the EO and a classification considered necessary for performance of work on the contract does not appear on this wage determination, the contractor must pay workers in that classification at least the wage rate determined through the conformance process set forth in 29 CFR 5.5(a)(1)(ii) (or the EO minimum wage rate, if it is higher than the conformed wage rate). The EO minimum wage rate will be adjusted annually. Please note that this EO applies to the above-mentioned types of contracts entered into by the federal government that are subject to the Davis-Bacon Act itself, but it does not apply to contracts subject only to the Davis-Bacon Related Acts, including those set forth at 29 CFR 5.1(a)(2)-(60). Additional information on contractor requirements and worker protections under the EO is available at www.dol.gov/whd/govcontracts.

Modification Number	Publication Date
0	01/01/2021
1	01/22/2021
2	03/05/2021
3	04/09/2021
4	04/23/2021
5	06/18/2021

6 7	07/30/2021 09/10/2021	
ASBE0006-006 12/01/2019		
	Rates	Fringes
HAZARDOUS MATERIAL HANDL (Includes preparation, wetting, stripping, remo scrapping, vacuuming, ba & disposing of all insul materials, whether they contain asbestos or not, mechanical systems)	ER val gging ation from	22.40
ASBE0006-008 09/01/2019		
	Rates	Fringes
Asbestos Worker/Insulato Includes applicatio all insulating mate protective covering coatings & finishes types of mechanical	r n of rials, s, to all systems.\$ 43.60	29.90
BOIL0029-001 01/01/2017		
	Rates	Fringes
BOILERMAKER	\$ 42.42	24.92
BRRI0003-001 06/01/2020		
	Rates	Fringes
Bricklayer, Stonemason, Pointer, Caulker & Clean	er\$ 42.55	28.02
BRRI0003-002 03/01/2020	,	
	Rates	Fringes
Marble Setter, Terrazzo Worker & Tile Setter	\$ 40.78	28.92
BRRI0003-003 03/01/2020		
	Rates	Fringes

Marble, Tile & Terrazzo

Rates
-------

Fringes

CARPENTER (Includes Soft	
Floor Layer)\$ 39.72	28.66
Diver Tender\$ 40.72	28.66
DIVER\$ 51.47	28.66
Piledriver\$ 39.72	28.66
WELDER\$ 40.72	28.66

### FOOTNOTES:

When not diving or tending the diver, the diver and diver tender shall receive the piledriver rate. Diver tenders shall receive \$1.00 per hour above the pile driver rate when tending the diver.

Work on free-standing stacks, concrete silos & public utility electrical power houses, which are over 35 ft. in height when constructed: \$.50 per hour additional.

Work on exterior concrete shear wall gang forms, 45 ft. or more above ground elevation or on setback: \$.50 per hour additional.

The designated piledriver, known as the ""monkey"": \$1.00 per hour additional.

-----

CARP1121-002 01/06/2020

	Rates	Fringes	
MILLWRIGHT	\$ 39.07	29.15	
ELEC0099-002 06/02/2021			

	Rates	Fringes
ELECTRICIAN	.\$ 43.61	55.71%
Teledata System Installer	.\$ 32.71	12.57%+14.93

### FOOTNOTES:

Work of a hazardous nature, or where the work height is 30

ft. or more from the floor, except when working OSHA-approved lifts: 20% per hour additional.

Work in tunnels below ground level in combined sewer outfall: 20% per hour additional.

\_\_\_\_\_ ELEV0039-001 01/01/2021 Rates Fringes ELEVATOR MECHANIC......\$ 55.03 35.825+A+B FOOTNOTES: A. PAID HOLIDAYS: New Years Day; Memorial Day; Independence Day; Labor Day; Veterans' Day; Thanksgiving Day; the Friday after Thanksgiving Day; and Christmas Day. B. Employer contributes 8% basic hourly rate for 5 years or more of service of 6% basic hourly rate for 6 months to 5 years of service as vacation pay credit. \_\_\_\_\_

ENGI0057-001 12/01/2020

Rates Fringes

Operating Engineer: (power	
plants, sewer treatment	
plants, pumping stations,	
tunnels, caissons, piers,	
docks, bridges, wind	
turbines, subterranean &	
other marine and heavy	
construction work)	
GROUP 1\$ 42.55	27.70+a
GROUP 2\$ 40.55	27.70+a
GROUP 3\$ 36.17	27.70+a
GROUP 4\$ 33.32	27.70+a
GROUP 5\$ 39.60	27.70+a
GROUP 6\$ 30.40	27.70+a
GROUP 7\$ 24.40	27.70+a
GROUP 8\$ 36.25	27.70+a
GROUP 9\$ 40.17	27.70+a
a. BOOM LENGIHS, INCLUDING JIBS:	

150 feet and over + \$ 2.00 180 feet and over + \$ 3.00 210 feet and over + \$ 4.00 240 feet and over + \$ 5.00 270 feet and over + \$ 7.00 300 feet and over + \$ 8.00 350 feet and over + \$ 9.00 400 feet and over + \$10.00 a. PAID HOLIDAYS: New Year's Day, President's Day, Memorial Day, July Fourth, Victory Day, Labor Day, Columbus Day, Veterans Day, Thanksgiving Day, Christmas Day. a: Any employee who works 3 days in the week in which a holiday falls shall be paid for the holiday. a. FOOTNOTES: Hazmat work: \$2.00 per hour additional. Tunnel/Shaft work: \$5.00 per hour additional. POWER EQUIPMENT OPERATORS CLASSIFICATIONS GROUP 1: Cranes, lighters, boom trucks and derricks GROUP 2: Digging machine, Ross Carrier, locomotive, hoist, elevator, bidwell-type machine, shot & water blasting machine, paver, spreader, graders, front end loader (3 yds. and over), vibratory hammer & vacuum truck, roadheaders, forklifts, economobile type equipment, tunnel boring machines, concrete pump and on site concrete plants. GROUP 3: Oilers on cranes. GROUP 4: Oiler on crawler backhoe. GROUP 5: Bulldozer, bobcats, skid steer loader, tractor, scraper, combination loader backhoe, roller, front end loader (less than 3 yds.), street and mobile-powered sweeper (3-yd. capacity), 8-ft. sweeper minimum 65 HP). GROUP 6: Well-point installation crew. GROUP 7: Utility Engineers and Signal Persons GROUP 8: Heater, concrete mixer, stone crusher, welding machine, generator and light plant, gas and electric driven pump and air compressor. GROUP 9: Boat & tug operator.

#### Rates Fringes

Power Equipment Operator (highway construction projects; water and sewerline projects which are incidental to highway construction projects; and bridge projects that do not span water)	
GROUP 1\$ 35.70	27.70+a
GROUP 2\$ 30.40	27.70+a
GROUP 3\$ 24.40	27.70+a
GROUP 4\$ 30.98	27.70+a
GROUP 5\$ 34.68	27.70+a
GROUP 6\$ 34.30	27.70+a
GROUP 7\$ 29.95	27.70+a
GROUP 8\$ 31.33	27.70+a
GROUP 9\$ 33.28	27.70+a

a. FOOTNOTE: a. Any employee who works three days in the week in which a holiday falls shall be paid for the holiday.

a. PAID HOLIDAYS: New Year's Day, President's Day, Memorial Day, July Fourth, Victory Day, Labor Day, Columbus Day, Veterans Day, Thanksgiving Day & Christmas Day.

#### POWER EQUIPMENT OPERATOR CLASSIFICATIONS

GROUP 1: Digging machine, crane, piledriver, lighter, locomotive, derrick, hoist, boom truck, John Henry's, directional drilling machine, cold planer, reclaimer, paver, spreader, grader, front end loader (3 yds. and over), vacuum truck, test boring machine operator, veemere saw, water blaster, hydro-demolition robot, forklift, economobile, Ross Carrier, concrete pump operator and boats

GROUP 2: Well point installation crew

GROUP 3: Utlity engineers and signal persons

GROUP 4: Oiler on cranes

GROUP 5: Combination loader backhoe, front end loader (less than 3 yds.), forklift, bulldozers & scrapers and boats

GROUP 6: Roller, skid steer loaders, street sweeper

GROUP 7: Gas and electric drive heater, concrete mixer, light

plant, welding machine, pump & compressor

GROUP 8: Stone crusher

GROUP 9: Mechanic & welder

ENGI0057-003 12/01/2020

BUILDING CONSTRUCTION

	R	ates I	-ringes
Power Equip	ment Operator		
GROUP	1\$	41.82	27.70+a
GROUP	2\$	39.82	27.70+a
GROUP	3\$	39.60	27.70+a
GROUP	4\$	35.60	27.70+a
GROUP	5\$	32.75	27.70+a
GROUP	6\$	38.90	27.70+a
GROUP	7\$	38.47	27.70+a
GROUP	8\$	35.79	27.70+a

a.BOOM LENTHS, INCLUDING JIBS:

150 ft. and over: + \$ 2.00 180 ft. and over: + \$ 3.00 210 ft. and over: + \$ 4.00 240 ft. and over: + \$ 5.00 270 ft. and over: + \$ 7.00 300 ft. and over: + \$ 8.00 350 ft. and over: + \$ 9.00 400 ft. and over: + \$10.00

a. PAID HOLIDAYS: New Year's Day, President's Day, Memorial Day, July Fourth, Victory Day, Labor Day, Columbus Day, Veterans Day, Thanksgiving Day & Christmas Day. a: Any employee who works 3 days in the week in which a holiday falls shall be paid for the holiday.

a. FOOTNOTE: Hazmat work: \$2.00 per hour additional. Tunnel/Shaft work: \$5.00 per hour additional.

#### POWER EQUIPMENT OPERATORS CLASSIFICATIONS

GROUP 1: Cranes, lighters, boom trucks and derricks.

GROUP 2: Digging machine, Ross carrier, locomotive, hoist, elevator, bidwell-type machine, shot & water blasting

machine, paver, spreader, front end loader (3 yds. and over), vibratory hammer and vacuum truck GROUP 3: Telehandler equipment, forklift, concrete pump & on-site concrete plant GROUP 4: Fireman & oiler on cranes GROUP 5: Oiler on crawler backhoe GROUP 6: Bulldozer, skid steer loaders, bobcats, tractor, grader, scraper, combination loader backhoe, roller, front end loader (less than 3 yds.), street and mobile powered sweeper (3 yds. capacity), 8-ft. sweeper (minimum 65 hp) GROUP 7: Well point installation crew GROUP 8: Heater, concrete mixer, stone crusher, welding machine, generator for light plant, gas and electric driven pump & air compressor \_\_\_\_\_ IRON0037-001 03/16/2021 Rates Fringes IRONWORKER.....\$ 37.87 30.13 \_\_\_\_\_ LAB00271-001 05/30/2021 BUILDING CONSTRUCTION Rates Fringes LABORER GROUP 1.....\$ 33.55 26.15 GROUP 2....\$ 33.80 26.15 GROUP 3.....\$ 34.30 26.15 GROUP 4.....\$ 34.55 26.15 GROUP 5....\$ 35.55 26.15 LABORERS CLASSIFICATIONS GROUP 1: Laborer, Carpenter Tender, Mason Tender, Cement Finisher Tender, Scaffold Erector, Wrecking Laborer, Asbestos Removal [Non-Mechanical Systems]

GROUP 2: Asphalt Raker, Adzemen, Pipe Trench Bracer, Demolition Burner, Chain Saw Operator, Fence & Guard Rail Erector, Setter of Metal Forms for Roadways, Mortar Mixer,

Pipelayer, Riprap & Dry Stonewall Builder, Highway Stone Spreader, Pneumatic Tool Operator, Wagon Drill Operator, Tree Trimmer, Barco-Type Jumping Tamper, Mechanical Grinder Operator GROUP 3: Pre-Cast Floor & Roof Plank Erectors GROUP 4: Air Track Operator, Hydraulic & Similar Self-Powered Drill, Block Paver, Rammer, Curb Setter, Powderman & Blaster GROUP 5: Toxic Waste Remover \_\_\_\_\_ LAB00271-002 05/30/2021 HEAVY AND HIGHWAY CONSTRUCTION Rates Fringes LABORER COMPRESSED AIR Group 1.....\$ 53.45 24.15 Group 2....\$ 50.98 24.15 Group 3.....\$ 40.50 24.15 FREE AIR Group 1.....\$ 44.05 24.15 Group 2.....\$ 43.05 24.15 Group 3.....\$ 40.50 24.15 LABORER Group 1.....\$ 33.55 24.15 Group 2....\$ 33.80 24.15 Group 3.....\$ 34.55 24.15 Group 4....\$ 27.05 24.15 Group 5....\$ 35.55 24.15 OPEN AIR CAISSON, UNDERPINNING WORK AND BORING CREW Bottom Man.....\$ 39.55 24.15 Top Man & Laborer.....\$ 38.60 24.15 TEST BORING Driller.....\$ 40.00 24.15 Laborer.....\$ 38.60 24.15

#### LABORER CLASSIFICATIONS

GROUP 1: Laborer; Carpenter tender; Cement finisher tender; Wrecking laborer; Asbestos removers [non-mechanical systems]; Plant laborer; Driller in quarries

GROUP 2: Adzeperson; Asphalt raker; Barcotype jumping

tamper; Chain saw operators; Concrete and power buggy operator; Concrete saw operator; Demolition burner; Fence and guard rail erector; Highway stone spreader; Laser beam operator; Mechanical grinder operator; Mason tender; Mortar mixer; Pneumatic tool operator; Riprap and dry stonewall builder; Scaffold erector; Setter of metal forms for roadways; Wagon drill operator; Wood chipper operator; Pipelayer; Pipe trench bracer

GROUP 3: Air track drill operator; Hydraulic and similar powered drills; Brick paver; Block paver; Rammer and curb setter; Powderperson and blaster

GROUP 4: Flagger & signaler

GROUP 5: Toxic waste remover

LABORER - COMPRESSED AIR CLASSIFICATIONS

GROUP 1: Mucking machine operator, tunnel laborer, brake person, track person, miner, grout person, lock tender, gauge tender, miner: motor person & all others in compressed air

GROUP 2: Change house attendant, powder watchperson, top person on iron

GROUP 3: Hazardous waste work within the ""HOT"" zone

#### LABORER - FREE AIR CLASSIFICATIONS

GROUP 1: Grout person - pumps, brake person, track person, form mover & stripper (wood & steel), shaft laborer, laborer topside, outside motorperson, miner, conveyor operator, miner welder, heading motorperson, erecting operator, mucking machine operator, nozzle person, rodperson, safety miner, shaft & tunnel, steel & rodperson, mole nipper, concrete worker, form erector (wood, steel and all accessories), cement finisher (this type of work only), top signal person, bottom person (when heading is 50' from shaft), burner, shield operator and TBM operator

GROUP 2: Change house attendant, powder watchperson

GROUP 3: Hazardous waste work within the ""HOT"" zone

PAIN0011-005 06/01/2021

	Rates	Fringes
PAINTER		
Brush and Roller\$ Epoxy, Tanks, Towers, Swing Stage & Structural	\$ 36.42	22.90
Steel\$ Spray, Sand & Water	38.42	22.90
Blasting	\$ 39.42	22.90
Taper Wall Coverer	5 37.17 5 36.92	22.90 22.90
PAIN0011-006 06/01/2021		
	Rates	Fringes
GLAZIER\$	\$ 39.98	22.90
FOOTNOTES:		
SWING STAGE: \$1.00 per hour additi	ional.	
PAID HOLIDAYS: Labor Day & Christn	nas Day.	
PAIN0011-011 06/01/2021		
	Rates	Fringes
Painter (Bridge Work)	\$ 54.00	22.90
PAIN0035-008 06/01/2011		
	Rates	Fringes
Sign Painter	\$ 24.79	13.72
PLAS0040-001 06/03/2019		
BUILDING CONSTRUCTION		
	Rates	Fringes
CEMENT MASON/CONCRETE FINISHER\$	\$ 36.00	27.15
FOOTNOTE: Cement Mason: Work on free swinging scaffolds under 3 planks width and which is 20 or more feet above ground and any offset structure: \$.30 per hour additional.		

## PLAS0040-002 07/01/2019

HEAVY AND HIGHWAY CONSTRUCTION

	Rates	Fringes		
CEMENT MASON/CONCRETE FINISHER	\$ 32.85	22.20		
PLAS0040-003 07/01/2019				
	Rates	Fringes		
PLASTERER	\$ 37.55	27.50		
* PLUM0051-002 08/30/2021				
	Rates	Fringes		
Plumbers and Pipefitters	\$ 46.49	31.40		
ROOF0033-004 06/01/2021				
	Rates	Fringes		
ROOFER	\$ 39.40	29.06		
SFRI0669-001 04/01/2021				
	Rates	Fringes		
SPRINKLER FITTER	\$ 47.55	26.60		
SHEE0017-002 12/01/2020				
	Rates	Fringes		
Sheet Metal Worker	\$ 38.58	36.73		
TEAM0251-001 05/01/2019				
HEAVY AND HIGHWAY CONSTRUCTION				
	Rates	Fringes		
TRUCK DRIVER				
GROUP 1	\$ 27.96	26.8525+A+B+C		
GROUP 2	\$ 27.61	26.8525+A+B+C		
GROUP 3	\$ 27.66	26.8525+A+B+C		
GROUP 4	\$ 27.71	26.8525+A+B+C		
GROUP 5	\$ 27.81	26.8525+A+B+C		

6\$	28.21	26.8525+A+B+C
7\$	28.41	26.8525+A+B+C
8\$	27.91	26.8525+A+B+C
9\$	28.16	26.8525+A+B+C
10\$	27.96	26.8525+A+B+C
	6\$ 7\$ 8\$ 9\$ 10\$	6\$ 28.21 7\$ 28.41 8\$ 27.91 9\$ 28.16 10\$ 27.96

FOOTNOTES:

A. Paid Holidays: New Year's Day, Memorial Day, Independence Day, Labor Day, Thanksgiving Day and Christmas Day, plus Presidents' Day, Columbus Day, Veteran's Day & V-J Day, providing the employee has worked at least one day in the calendar week in which the holiday falls.

B. Employee who has been on the payroll for 1 year or more but less than 5 years and has worked 150 Days during the last year of employment shall receive 1 week's paid vacation; 5 to 10 years - 2 weeks' paid vacation; 10 or more years - 3 week's paid vacation.

C. Employees on the seniority list shall be paid a one hundred dollar (\$100.00) bonus for every four hundred (400) hours worked, up to a maximum of five hundred dollars (\$500.00)

All drivers working on a defined hazard material job site shall be paid a premium of \$2.00 per hour over applicable rate.

TRUCK DRIVER CLASSIFICATIONS

GROUP 1: Pick-up trucks, station wagons, & panel trucks

GROUP 2: Two-axle on low beds

GROUP 3: Two-axle dump truck

GROUP 4: Three-axle dump truck

GROUP 5: Four- and five-axle equipment

GROUP 6: Low-bed or boom trailer.

GROUP 7: Trailers when used on a double hook up (pulling 2 trailers)

GROUP 8: Special earth-moving equipment, under 35 tons

GROUP 9: Special earth-moving equipment, 35 tons or over

#### GROUP 10: Tractor trailer

#### \_\_\_\_\_

WELDERS - Receive rate prescribed for craft performing operation to which welding is incidental.

Note: Executive Order (EO) 13706, Establishing Paid Sick Leave for Federal Contractors applies to all contracts subject to the Davis-Bacon Act for which the contract is awarded (and any solicitation was issued) on or after January 1, 2017. If this contract is covered by the EO, the contractor must provide employees with 1 hour of paid sick leave for every 30 hours they work, up to 56 hours of paid sick leave each year. Employees must be permitted to use paid sick leave for their own illness, injury or other health-related needs, including preventive care; to assist a family member (or person who is like family to the employee) who is ill, injured, or has other health-related needs, including preventive care; or for reasons resulting from, or to assist a family member (or person who is like family to the employee) who is a victim of, domestic violence, sexual assault, or stalking. Additional information on contractor requirements and worker protections under the EO is available at www.dol.gov/whd/govcontracts.

Unlisted classifications needed for work not included within the scope of the classifications listed may be added after award only as provided in the labor standards contract clauses (29CFR 5.5 (a) (1) (ii)).

#### -----

The body of each wage determination lists the classification and wage rates that have been found to be prevailing for the cited type(s) of construction in the area covered by the wage determination. The classifications are listed in alphabetical order of ""identifiers"" that indicate whether the particular rate is a union rate (current union negotiated rate for local), a survey rate (weighted average rate) or a union average rate (weighted union average rate).

### Union Rate Identifiers

A four letter classification abbreviation identifier enclosed in dotted lines beginning with characters other than ""SU"" or ""UAVG"" denotes that the union classification and rate were
prevailing for that classification in the survey. Example: PLUM0198-005 07/01/2014. PLUM is an abbreviation identifier of the union which prevailed in the survey for this classification, which in this example would be Plumbers. 0198 indicates the local union number or district council number where applicable, i.e., Plumbers Local 0198. The next number, 005 in the example, is an internal number used in processing the wage determination. 07/01/2014 is the effective date of the most current negotiated rate, which in this example is July 1, 2014.

Union prevailing wage rates are updated to reflect all rate changes in the collective bargaining agreement (CBA) governing this classification and rate.

## Survey Rate Identifiers

Classifications listed under the ""SU"" identifier indicate that no one rate prevailed for this classification in the survey and the published rate is derived by computing a weighted average rate based on all the rates reported in the survey for that classification. As this weighted average rate includes all rates reported in the survey, it may include both union and non-union rates. Example: SULA2012-007 5/13/2014. SU indicates the rates are survey rates based on a weighted average calculation of rates and are not majority rates. LA indicates the State of Louisiana. 2012 is the year of survey on which these classifications and rates are based. The next number, 007 in the example, is an internal number used in producing the wage determination. 5/13/2014 indicates the survey completion date for the classifications and rates under that identifier.

Survey wage rates are not updated and remain in effect until a new survey is conducted.

Union Average Rate Identifiers

Classification(s) listed under the UAVG identifier indicate that no single majority rate prevailed for those classifications; however, 100% of the data reported for the classifications was union data. EXAMPLE: UAVG-OH-0010 08/29/2014. UAVG indicates that the rate is a weighted union average rate. OH indicates the state. The next number, 0010 in the example, is an internal number used in producing the wage determination. 08/29/2014 indicates the survey completion date for the classifications and rates under that identifier.

A UAVG rate will be updated once a year, usually in January of each year, to reflect a weighted average of the current negotiated/CBA rate of the union locals from which the rate is based.

\_\_\_\_\_

#### WAGE DETERMINATION APPEALS PROCESS

1.) Has there been an initial decision in the matter? This can be:

- \* an existing published wage determination
- \* a survey underlying a wage determination
- \* a Wage and Hour Division letter setting forth a position on a wage determination matter
- \* a conformance (additional classification and rate) ruling

On survey related matters, initial contact, including requests for summaries of surveys, should be with the Wage and Hour Regional Office for the area in which the survey was conducted because those Regional Offices have responsibility for the Davis-Bacon survey program. If the response from this initial contact is not satisfactory, then the process described in 2.) and 3.) should be followed.

With regard to any other matter not yet ripe for the formal process described here, initial contact should be with the Branch of Construction Wage Determinations. Write to:

> Branch of Construction Wage Determinations Wage and Hour Division U.S. Department of Labor 200 Constitution Avenue, N.W. Washington, DC 20210

2.) If the answer to the question in 1.) is yes, then an interested party (those affected by the action) can request review and reconsideration from the Wage and Hour Administrator (See 29 CFR Part 1.8 and 29 CFR Part 7). Write to:

Wage and Hour Administrator U.S. Department of Labor 200 Constitution Avenue, N.W. Washington, DC 20210

The request should be accompanied by a full statement of the interested party's position and by any information (wage payment data, project description, area practice material, etc.) that the requestor considers relevant to the issue.

3.) If the decision of the Administrator is not favorable, an interested party may appeal directly to the Administrative Review Board (formerly the Wage Appeals Board). Write to:

Administrative Review Board U.S. Department of Labor 200 Constitution Avenue, N.W. Washington, DC 20210

4.) All decisions by the Administrative Review Board are final.

\_\_\_\_\_

END OF GENERAL DECISION"

# Blackstone Boulevard Path Improvements 2021

240-350 Blackstone Boulevard Providence, Rhode Island 02906

Pages

# SPECIFICATIONS GROUP

#### General Requirements Subgroup - GENERAL REQUIREMENTS **DIVISION 01** 010000 **GENERAL REQUIREMENTS** TEMPORARY TREE AND PLANT PROTECTION 015639 Facility Construction Subgroup DIVISION 02 - EXISTING CONDITIONS 024119 SELECTIVE DEMOLITION Site and Infrastructure Subgroup **DIVISION 31 - EARTHWORK** 312000 EARTH MOVING 312213 **ROUGH GRADING** 312500 **EROSION AND SEDIMENTATION CONTROLS** DIVISION 32 - EXTERIOR IMPROVEMENTS **ASPHALT PAVING** 321216 321313 CONCRETE PAVING 321320 STONE DUST WALK ORGANIC-LOCK FOR STABILIZED PATHWAY AGGREGATE: 321540 FOOT TRAFFIC 329113 SOIL PREPARATION 329119 LANDSCAPE GRADING 329200 **TURF AND GRASSES**

END OF TABLE OF CONTENTS



# SECTION 010000 - GENERAL REQUIREMENTS

# PART 1 - GENERAL

- 1.1 All work done under this Contract shall also be in conformance with the Drawings and these Supplemental Technical Specifications.
  - A. SCOPE OF WORK
    - 1. The general summary of work to be done under this contract consists of, but shall not be limited, to the following as shown in the Contract Documents:
  - B. WORK COVERED BY CONTRACT DOCUMENTS
  - C. The Contractor shall execute the scope of work indicated on Plans and Specifications to enhance the use and operations of the site as shown within the project limits.
  - D. Work shall be as specifically indicated, shown or described in the Drawings, Technical Specifications, and other Contract Documents.
  - E. PROJECT INFORMATION
    - 1. OWNER
      - a. City of Providence Parks Department Roger Williams Park Dalrymple Boathouse, 1000 Elmwood Avenue, Providence, RI 02905, Telephone: 401.680.7200
      - b. Superintendent of Parks: Wendy Nilsson
    - 2. OWNER'S REPRESENTATIVE
      - a. Sam Greenwood 401-680-7299 sgreenwood@providenceri.gov

# 1.2 PROJECT LOCATION

A. Blackstone Blvd Median between Mount Ave & Rochambeau Ave

# PART 2 - PRODUCTS

# 2.1 CONTRACTOR USE OF PREMISES

- A. The Contractor's use of premises shall be within the limits shown on the Drawings and as defined in the Standard Form of Agreement, for the performance of the Work.
  - 1. The Contractor shall maintain vehicular access and utility service to the abutting properties at all times throughout the course of the construction.
  - 2. The Contractor shall assume full responsibility for security of all materials and equipment on the site, including those of the subcontractors.

Copyright © 2021 by the American Institute of Architects. Warning: This AIA MasterSpec-based document is protected by U.S. Copyright Law and International Treaties. It was created by "Providence Parks Dept" for "Blackstone Boulevard Path Improvements 2021". A valid, current MasterSpec license is required for editing and use of this document for any other project.(16521)



- 3. If directed by the Owner's Representative, the Contractor shall relocate or move any stored items that interfere with operations of the Owner.
- 4. The Contractor may elect to obtain (at no cost to the Owner) additional storage or work areas off-site if needed to perform the work.

# 2.2 OWNER OCCUPANCY REQUIREMENTS

- A. The Owner (City) anticipates that site inclusive of all on-site amenities beyond the Limit of Work will remain open throughout the course of construction.
- B. Contractor shall provide the Owner's Representative with a written plan describing the sequences and durations anticipated for the execution of the Work.

# 2.3 MOBILIZATION, SITE PREPARATION, & DEMOLITION

- A. THE WORK SPECIFIED IN THIS SECTION INCLUDES:
  - 1. Mobilization of all personnel and equipment;
  - 2. Preparing the construction site for construction operations;
  - 3. Materials to be removed and legally disposed of off site.
  - 4. When applicable, verifying and utilizing survey control points as shown on the Drawings
  - 5. Protecting existing site features to remain, such as fences, trees, shrubs and grassed areas outside the limit of work.
  - 6. Protecting underground and overhead utilities and other existing facilities from damage.
  - 7. Where applicable, provisions for site access and of traffic control.
  - 8. At cessation of site improvement operations: Site clean-up
  - 9. De-mobilization of all personnel and equipment.

# 2.4 CONSTRUCTION STAGING/STOCKPILE AREAS

- A. Staging areas within the Park is permitted as shown on the Plans with the prior consent of and coordination with the Owner.
- B. Restoration of the site to pre-existing condition shall be the sole responsibility of the Contractor.

# 2.5 MATERIALS AND EQUIPMENT:

- A. Materials to be Removed and Stockpiled.
  - 1. Materials directed to be removed and stockpiled shall be removed, transported to and stacked in a location directed by the Owner's Representative. All materials shall be neatly stacked as directed.
  - 2. If the Owner's Representative determines that any part of the materials identified to be stockpiled are unsuitable for re use on the site or by the Owner elsewhere, such materials shall be evaluated for legal disposal by Owner's Representative and Contractor.



- B. Signs: Conform to requirements of Temporary Facilities and Controls.
- C. Temporary Site Protection: Temporary chain-link fence, if so desired shall be furnished, installed and maintained at no additional cost to the Owner. At the completion of all work at the site, the Contractor shall remove all temporary fencing and restore the site to its original condition at no additional cost to the Owner.

# 2.6 TEMPORARY CONSTRUCTION FACILITIES AND UTILITIES

- A. Make arrangements with the Owner's Representative for storage of materials and equipment in designated locations at the construction site. If staged on site, materials shall be secured from vandalism and or theft.
- B. Plastic construction fence or snow fencing if installed shall be maintained in good condition. Provide barricades, barrels, fencing and/or other barriers around excavations and trenches as required for safety. Upon completion, temporary fencing shall be removed and the affected area restored to the existing condition.

# 2.7 SITE MAINTENANCE

- A. Control dust from Contractor operations in accordance with specified dust control measures.
- B. Maintain the Site during construction in a manner that will not obstruct use on neighborhood streets. Proceed with the work in an orderly manner, maintaining the construction site free of debris and unnecessary equipment or materials.
- C. Legally dispose of all debris, rubbish, hazardous materials, oil, and grease in accordance with local ordinances.
- D. Maintain safety and security of the construction site and any stockpiled or staged materials or equipment if left on site.

# 2.8 TRAFFIC CONTROL

- A. For all of his/her operations, the Contractor shall provide appropriate traffic control in accordance with, TEMPORARY FACILITIES AND CONTROLS. The purposes of the traffic control are 1) to ensure that operations in the project area are performed in a safe and orderly manner, and 2) to minimize the impact of truck and equipment traffic and noise on adjacent homes near the project area. The Contractor shall be responsible for obtaining any and all required permits and approvals.
- B. Police Details, if required by the City, shall be paid directly to and coordinated with Providence Public Safety by the Owner.



# 2.9 DEMOBILIZATION

- A. Contractor shall be responsible for site security and safety at all times. Upon substantial completion of the work, Contractor shall remove all excess materials, equipment, construction debris, temporary facilities and construction measures (fencing, signs, barriers, etc.) from the project area, and shall leave the site in suitable condition for full occupancy and use by the Owner. The sedimentation and erosion controls installed as part of the Work may not necessarily be removed at this time (see below).
- B. The Owner's Representative shall be the sole judge of whether the site has been suitably cleaned.
- C. Upon suitable stabilization of all disturbed "erodible" areas (e.g. acceptable level of grass growth in loamed and seeded areas, mulch applied and stable in planting areas, etc.), contractor shall remove and legally dispose of all sedimentation and erosion control measures (silt fence, hay bales, catch basin inserts, etc.). See Section 024119 Selective Demolition and 329200 Turf and Grasses for directives and procedures.

# PART 3 - EXECUTION

# 3.1 GENERAL REQUIREMENTS

- A. The construction site entrance shall be as indicated on the plans. The Owner will provide access to any locked gate. Any tracked debris from the site present on adjacent roadways shall be removed and the roads swept daily to remove any excess mud, dirt, or rock originating from the site. Trucks hauling material shall be covered and equipped with gates that prevent material from falling out. If present, catch basins within 100 feet of site entry and exit locations shall be protected with inlet sediment control devices and maintained for the duration of the work.
- B. Identify, clearly mark and protect all survey monuments, temporary bench marks as well as any adjacent contractors' work and facilities (if applicable). Repair or replacement shall be at Contractor's sole expense if damaged by Contractor.
- C. Protect existing culverts, sewers, and all other utilities including gas, telecommunications, electricity, and water. Repair or replace at Contractor's sole expense if damaged by Contractor.
- D. Utilize or install drum or sawhorse barricades or backfill all open excavations, holes, trenches, and depressions occurring at construction sites or occurring as part of this work.

# 3.2 CHANGE ORDER PROCEDURE

# A. DESCRIPTION

1. The Contractor shall comply with this procedure in the process of giving notification of change and preparing and submitting a proposal for adjustment due to a desired, perceived, or actual change in the work. Changes in the work, or period of performance of the work, may be directed in writing by the Owner's Representative or may be



requested by the Contractor. In either case, payment for work accomplished under a modification may not be made until a formal contract modification, incorporating the change into the contract, has been issued and executed. Therefore, it is incumbent upon the Contractor to comply fully with this procedure and to expedite the resolution of changes.

# 3.3 CHANGE SUBMITTALS

- A. When requested, the Contractor shall submit the following to the Owner's Representative in accordance with the Submittals procedures described in these specifications:
  - 1. Proposal cover letter on Contractor's letterhead;
  - 2. Detailed price proposal;
  - 3. Drawings or other explanatory data; and
  - 4. Time extension statement with justification if any time extension is requested.

# 3.4 COMPLIANCE

A. The Contractor shall take such measures as needed to assure familiarity and compliance by its staff with these procedures. If change proposals are incomplete, unclear, or ambiguous or are not supported by adequate documentation, the data will be returned and the Contractor shall resubmit or supplement the proposal as requested by the Owner's Representative. Delay resulting from the Contractor's noncompliance with this procedure shall not in itself constitute the basis for an extension in the time of performance under the contract.

# 3.5 PROCESSING CHANGES INITIATED BY THE OWNER'S REPRESENTATIVE

- A. The Owner's Representative will initiate changes only in writing. The Owner will sign any Request for Proposal (RFP). This will establish an Extra Work Order (EWO) number, by which the change will be identified until such time as it may be incorporated into the contract by formal Change Order (CO).
- B. The Contractor may or may not be authorized to proceed with the changed work pending resolution of changes in the contract price or time of performance. If the work described in the RFP becomes critical to the timely performance of the Contractor's work, a written request for a Notice to Proceed must be forwarded to the Owner immediately. The Owner will issue any Notice to Proceed. This unilateral modification to the contract may be subject to further negotiation regarding price and time for completion.
- C. Payment for changed work, covered by an authorized modification, will not be made until a notice to proceed covering the changed work has been executed.
- D. The Contractor shall prepare and submit its proposal for change to include at a minimum:
  - 1. A cover letter referencing the EWO number and citing the attachments, if any, which constitute the Contractor's total proposal.



- 2. A detailed price proposal showing labor, construction equipment, and material quantities and prices at the lowest practical level of each element of the work.
- 3. Any drawings, sketches, catalog cuts, samples, certifications, or other data required to be submitted by the Owner's Representative that is required to fully document
- 4. A statement of the proposed change in the time of completion of the contract, together with all required justification for such a change.
- 5. A statement to the effect that there is "no change in price and/or time of completion of the work under this contract as a result of this proposed change", if that is the case.
- E. The Owner may accept the Contractor's proposal without negotiation. Alternatively, upon receipt of a proposal which is satisfactory in form, the Owner's Representative may require negotiation with the Contractor to arrive at a fair and equitable change in the contract price and time of completion. Upon agreement, a contract modification will be issued by the Owner for Contractor's execution.

# 3.6 PROCESSING CHANGES INITIATED BY THE CONTRACTOR

- A. Should the Contractor feel that a change to the work under the contract, or to the contract itself, is necessary or desirable, it shall propose such a change to the Owner's Representative. This proposed change shall include a clear and concise description of the proposed change, along with that information cited in above.
- B. Within a reasonable time, the Owner's Representative will review the Contractor's proposal and determine if the proposed change is in the Owner's best interest. If so, Contractor will be advised of this and an EWO number will be assigned to Contractor's proposal.

# 3.7 EXECUTING CHANGED WORK

A. The Contractor is cautioned not to proceed with the work described in a proposed change until it is authorized to do so in writing by the Owner's Representative.

# 3.8 TERMINATIONS AND DELAYS

A. Termination of Contract: If the Contractor or any of his/her subcontractors refuses or fails to prosecute the work with such diligence as will insure its completion within the time specified in these Contract Documents, or as modified, as provided for in these Contract Drawings, or violates any other Provisions of this Contract, the Local Public Agency, Local Public Agency, City, by written notice to the Contractor, may terminate the Contractor's right to proceed with the Work. Upon such termination, the City of Providence may take over the work and prosecute the same to completion, by contract or otherwise, and the Contractor and his/her sureties shall be liable to the City of Providence for any additional cost incurred by the City of Providence in its completion of the work and they shall also be liable to the City of Providence for liquidated damages for any delay in the completion of the work as provided below. work and they shall also be liable to the City of Providence for liquidated damages for any delay work. If the Contractor's right to proceed is so terminated, the Local Public Agency Local Public Agency City may take possession of and utilize in completing the work such materials, tools, equipment, and plants as may be on the site

#### 010000 - 6



of the work and necessary thereof. Project work must commence 30 days after award of Contract or as mutually agreed upon by the Contractor and the Owner. The Contractor is required to submit a Work Schedule including all items included in the scope of work. The Work Schedule shall mirror the Schedule of Values which should be in chronological order. Both items are identified in the standard Pre-Bid and Pre-Construction Meeting Minutes as required. The work shall be continuous and the Contractor shall staff the project appropriately to meet the agreed upon work schedule. De- Mobilization from the project, prior to completion, must be agreed upon in writing by the Owner.

# 3.9 INSPECTION OF WORK

# A. DESCRIPTION

- 1. Work included in this Section consists of periodic observation of construction of the project. The Contractor's work shall be monitored periodically by the Owner's Representative
- 2. The Owner's Representative presence on site or construction observation work is inspectional in nature and will not include supervision or direction of the actual work of the contractor.
- 3. In no event will the Owner's Representative be responsible or liable for the contractor's use or administration of personnel, machinery, staging, or other temporary or precautionary construction, safety precautions or procedures, or for compliance by the contractor with the provisions, terms, or specifications of the contract. Observation services provided by the Owner's Representative are solely for the benefit of the Owner.
- 4. The Contractor shall keep the Owner's Representative informed concerning the work status and projected work schedule through regular communications.
- 5. The Contractor shall not cover any work related to the required field visits until one of the following occurs:
  - a. The Contractor is authorized by the Owner's Representative to proceed after the field visit.
  - b. The field visit is re-scheduled by the Owner's Representative to a later construction event
  - c. The field visit is waived in writing by the Owner's Representative
- 6. The Contractor shall request a Final Inspection seven calendar days in advance of the planned completion date. After review of the Notice of Completion, the Owner's Representative may reject the Notice for cause or schedule the Final Inspection. The Owner's Representative will perform its Final Inspection on all phases of the work and develop a comprehensive punch list, which will be provided to the Contractor.
- 7. The Final Inspection will be scheduled when the punch list items discovered during the Final Inspection have been corrected. If discovered, the Owner's Representative may add new items to the punch list at this inspection.
- 8. The Contractor is advised that the Owner's Representative will not accept the work until the Owner's Representative determines Substantial Completion has been achieved. Therefore, to minimize its risk, the Contractor should schedule its work to be substantially complete in time to allow the Final Inspection and punch list work to occur in advance of the Project Close Out Date. Due to the construction time period and the anticipated weather conditions, substantially complete will be defined as the completion of construction for all item and the temporary stabilization of all disturbed areas,



excluding planting and final seeding. Planting and final seeding is to occur during the time periods specified..

9. Nothing in this Section shall be construed to limit the Owner's Representative right to inspect the work at any time.

# 3.10 CONSTRUCTION SCHEDULES

# A. DESCRIPTION

1. Work included in this Section consists of preparation, submittal, and updating of the project.

# 3.11 CONSTRUCTION SCHEDULE

- A. Submit the following to the Owner's Representative in accordance with the Submittals Section. Submittals are for the record or approval as indicated.
  - 1. The proposed construction schedule shall be submitted for approval within five (5) calendar days after receipt of Notice to Proceed.
  - 2. Submit contract Weekly Summary Reports to the Owner's Representative for the record at weekly site meeting at request by the Owner.
  - 3. Submit construction progress schedule including a two week look ahead as back up to progress invoices.
- B. The construction schedule shall show all work activities for completion of the work to be performed under this contract and will reflect Contractor's general sequential approach to the work. The construction schedule will be in a bar chart format. The minimum level of detail (number of activities) shall include the activities described in the Schedule of Values and the Scope of the Work. The construction schedule shall demonstrate completion of all work within the period of performance of the contract in a reasonable and achievable manner.

# 3.12 PERIODIC SCHEDULE UPDATES

- A. The Contractor shall support monthly payment requests with an approved construction schedule marked to indicate progress. Submit updated schedule as necessary.
- B. When in the opinion of the Owner's Representative changes in the work occur that significantly affect the schedule, the Contractor shall submit a revised construction schedule for approval. The revised construction schedule shall be submitted within 10 calendar days after it is requested by the Owner's Representative The current approved construction schedule shall be used as a baseline for progress reporting.
- C. Acts of God: Claims for additional compensation for 'Acts of God' will be reviewed by the Owner. It is the Contractor's responsibility to secure the work site daily and failure to provide adequate provisions to do so may result in repairs to the site at the Contractor's expense. Documented 'Acts of God' such as the state issuing a 'State of Emergency' may result in the



Owner's authorization to proceed repair funded by the Owner. No work shall proceed without written authorization by the Owner.

# 3.13 SUBMITTAL PROCEDURES

# A. DESCRIPTION

- 1. This Specification Section covers the preparation and submission of all work plans, drawings, samples, manufacturer's literature and brochures, installation instructions, and operation and maintenance manuals as specified herein and in the various sections of these Specifications.
- 2. A Submittal Schedule shall be submitted for approval within five (5) calendar days after receipt of Notice to Proceed.

# 3.14 DRAWINGS

- A. The term "drawings" as used herein includes 'Shop Drawings' as required for fabrication, erection and installation, layout, and setting of proposed improvements; lists or schedules of materials and catalogues and brochures; performance and test data; and all other drawings and descriptive data pertaining to materials and methods of construction as may be required to show that the materials, equipment, or systems and the positions thereof conform to the requirements of the Contract Documents.
- B. Where specified and if so directed by the Owner's Representative provide shop drawings that are accompanied by design computations.
- C. Sheet sizes of drawings shall not exceed 24 in. by 36 in. The title block on all drawings shall bear the name of the Owner, the name of the project, and the project location.
- D. The Contractor's drawings shall be submitted electronically in PDF format to the Owner's Representative for review and approval.
- E. The Contractor shall maintain a complete set of construction drawings at the jobsite, clearly marked to reflect as-built conditions. Upon completion of the work, the Contractor shall submit these Record Drawings to the Owner's Representative.
- F. The Owner's Representative will review drawings and schedules only for conformance with the design of the Project and for compliance with the Contract Documents and Contract Drawings. The Contractor shall make any and all updates and corrections required by the Owner's Representative
- G. Drawings shall be reviewed and returned within ten (10) working days of receipt of drawings at jobsite. Drawings and all supporting data, catalogs, or similar information shall be prepared by the Contractor or his suppliers and subcontractors but shall be submitted as instruments of the Contractor.
- H. The Owner's Representative review of drawings will be of a general nature and shall not relieve the Contractor from responsibility for errors and omissions of any sort, for deviations from



Drawings or Specifications, or for conflict with the work of others that may result from such deviations. The Owner's Representative review of drawings will not relieve the Contractor of responsibility to complete the work in accordance with the requirements of the Contract Documents.

- I. After Notice of Award, the Contractor shall submit a Submittal Schedule to the Owner's Representative. The Contractor's schedule shall be brought up to date from time to time to show the latest changes, omissions, and additions. The Schedule will be based on the Contractor's Construction Schedule and will show when the Contractor will submit the drawings and when he/she expects them to be returned so that construction activities shown on the Construction Schedule are not interrupted. There will be a minimum of three weeks between these two activities. Specific methods and routines for handling drawing reviews shall be established in advance within the general framework of the Contract Documents.
- J. Work for which the Contractor's submittals are required shall not be started until the submittals have been reviewed and accepted in writing by the Owner or Landscape Architect. Owner or Landscape Architect. Owner or Landscape Architect. Owner or Landscape Architect. Owner or september of a previously accepted submittal must be accepted in writing by the Owner's Representative before implementation.

# 3.15 SAMPLES

A. The Contractor shall, at his or her expense, furnish the Owner's Representative with samples of the various materials as specified in these Specification and Drawings. Samples shall be delivered to the office of the Owner's Representative at the Contractor's expense.

# 3.16 PRODUCT DATA

A. The Contractor shall submit to the Owner's Representative all required Material Safety Data Sheets (MSDS) and all Product Data Sheets and any other relevant product information for all items identified in the Technical Specifications and Drawings. All data shall be furnished by the Contractor in accordance with the approved schedule.

# B. SUBMITTAL LOG

- 1. Contractor to provided the following information:
  - a. An I.D. number for each item
  - b. Specification Section, Paragraph Number and Line Item Number (ie. 321313 / 1.3 / A)
  - c. Item Name
  - d. Description of the Item
  - e. Date Submitted
  - f. Status: Approved / Approved As Noted / Rejected
  - g. Sub-Contractor (If any) providing the material
  - h. Comments

#### 010000 - 10



# 3.17 QUALITY CONTROL DESCRIPTION

- A. This Section provides the requirements for Contract quality control (QC) pertaining to the Work, including:
  - 1. QC of products and workmanship;
  - 2. Manufacturer's instructions; and
  - 3. Manufacturer's certificates and field services.

# 3.18 WORKMANSHIP

- A. The Contractor shall comply with industry standards of the region, except when more restrictive tolerances or specified requirements indicate more rigid standards or more precise workmanship.
- B. The Contractor shall provide suitably-qualified personnel to produce work of specified quality.
- C. The Contractor shall secure products in place with positive anchorage devices designed and sized to withstand stresses, vibration, and racking.
- D. The Contractor shall provide materials to match approved samples.

# 3.19 MANUFACTURER'S INSTRUCTIONS

A. The Contractor shall require compliance with instructions in full detail, including each step in sequence. Should instructions conflict with the Contract Documents, the Contractor shall request clarification from the Owner's Representative before proceeding.

# 3.20 MANUFACTURER'S CERTIFICATES

A. When required in individual Specifications sections, the Contractor shall submit manufacturer's certificates, in duplicate, certifying that products meet or exceed specified requirements.

# 3.21 TESTING LABORATORY SERVICES (NIC)

- A. Not Utilized in this Contract
- B. (Modify as Required)

# 3.22 MANUFACTURER'S FIELD SERVICES

A. When required by the manufacturer or Owner's Representative, the Contractor shall have the manufacturer provide a qualified representative to observe field conditions, conditions of surfaces and installation, and quality of workmanship as applicable and to make written report of observations and recommendations to the Owner's Representative.



# 3.23 AUTHORITY OF OWNER'S REPRESENTATIVE

- A. The Owner's Representative will decide all questions that may arise as to the quality and acceptability of materials furnished. All questions that may arise as to the interpretation of the Contract Drawing and Specifications shall be determined by the Owner's Representative.
- B. The Owner and Owner's Representative shall not be responsible for the Contractor's means, methods, techniques, sequences, or procedures of construction or the safety precautions and programs incident thereto, and the Owner's Representative will not be responsible for the Contractor's failure to perform the work in accordance with the Contract Documents.
- C. The Owner's Representative will not be responsible for the acts or omissions of the Contractor or any subcontractors, of the agents or employees of any Contractor or subcontractor, or of any other persons at the site or otherwise performing any of the work.

# 3.24 COORDINATION OF DRAWINGS AND SPECIFICATIONS

- A. The Contractor shall take no advantage of any apparent error or omission in the Contract Drawings or Specifications. In the event the Contractor discovers such a discrepancy, error or omission, he shall immediately notify the Owner's Representative. After review and consultation with the Owner's Representative the Owner's Representative will issue clarifications, provide interpretations and make such corrections as may be deemed necessary for the Contractor to proceed with fulfilling the intent of the Contract Drawings and Specifications.
- B. When general reference is made on the Contract Drawings or within the Specifications to any cited Standard Specifications, it shall refer to the current edition of such Specifications or the latest revision thereof or interim Specifications adopted and in effect on the date of Effective Date of Agreement. In the event of a conflict between the Contract Drawings and the specifications, the Owner's Representative shall be notified to provide a clarification to the Contractor.

# 3.25 COOPERATION WITH UTILITIES

- A. The Contractor will notify all utility companies, all pipeline owners, or other parties affected and endeavor to have all necessary adjustments of the public or private utility fixtures, pipelines, and other appurtenances within or adjacent to the limits of construction made as soon as practical.
- B. Water lines, gas lines, wire lines, service connections, water and gas meter boxes, water and gas valve boxes, light standards, cableways, signals, and all other utility appurtenances within the limits of the proposed construction which are to be crossed, relocated or adjusted are to be moved by the Contractor or its designated agents, except as otherwise noted on the Contract Drawings. In the case of utility lines, the Contractor shall coordinate with the respective utilities for their removal and relocation.
- C. Attention is directed to the possible existence of underground facilities not known to the Owner's Representative or in a location different from that which is shown on the Contract



Drawings. The Contractor shall take steps to ascertain the exact location of all underground facilities prior to doing work that may damage such facilities or interfere with their service.

# 3.26 INDEPENDENT TESTING AND INSPECTION (NIC)

A. Not Applicable under this Contract

# 3.27 REQUIREMENTS

A. The requirements for sampling and testing or inspection are specified in the Specifications and Drawings. The Contractor shall maintain a complete and up-to-date file of all quality control documentation at the jobsite.

# 3.28 MATERIAL AND EQUIPMENT

# A. DESCRIPTION

1. This Specification Section includes the requirements for the transportation, handling, storage, and protection of materials and equipment as specified herein and in the various Sections of these Specifications. This Section also addresses the procedure for Contractor-proposed product substitutions.

# 3.29 MANUFACTURER REQUIREMENTS

A. In general, the Contractor shall receive, handle, and store materials and equipment in accordance with manufacturer's recommendations and in a manner which will protect such items from damage or deterioration.

# B. GENERAL

C. Products include the material, equipment, and systems used on this Project. Comply with the Specifications, Drawings and referenced standards as minimum requirements.

# 3.30 TRANSPORTATION AND HANDLING

- A. The Contractor shall receive, handle, and store materials and equipment supplied by him/her in a manner that will protect such items from damage or deterioration in accordance with procedures provided by product manufacturers and the Owner.
- B. Promptly inspect the shipments to assure that the products comply with requirements, the quantities are correct, and the products are undamaged.



# 3.31 STORAGE AND PROTECTION

- A. Materials and equipment shall be stored off the ground on blocking or pallets and shall be covered for protection from vandalism and weather damage.
- B. Materials and equipment shall be stored, tested, and cleaned prior to use, in accordance with the Specification and all specific manufacturers' requirements. Damaged or nonconforming items shall be removed immediately to a separated storage area for expeditious removal from site.
- C. The Contractor shall provide a secure outside storage area in the vicinity of the site.

# 3.32 SUBSTITUTIONS

- A. Substitutions will be considered only when a product becomes unavailable due to no fault of the Contractor or when deemed appropriate by the Owner's Representative
- B. Document each request with complete data substantiating the compliance of the proposed substitution with the Contract Documents.
- C. The requested substation proposed constitutes a representation that the Contractor:
  - 1. Has investigated the proposed product and determined that it meets or exceeds, in all respects, the specified product.
  - 2. Will provide the same warranty for substitution as for the specified product.
  - 3. Will coordinate installation and make other changes which may be required for the Work to be complete in all respects.
  - 4. Waives claims for additional costs which may subsequently become apparent.
- D. Substitutions will be considered when they are indicated or implied on shop drawings or product data submittals without separate written request, or when acceptance will require substantial revision of the Contract Documents.
- E. The Owner's Representative will determine acceptability of the proposed substitution, and will notify the Contractor of acceptance or rejection in writing within a reasonable time. Only one request for the substitution will be considered for each product. When substitution is not accepted, the Contractor shall provide the specified product.

# 3.33 REJECTED MATERIALS AND DEFECTIVE WORK

- A. Materials furnished by the Contractor and rejected by the Owner's Representative as unsuitable or not in conformity with the specifications shall forthwith be removed from the job-site and work area by the Contractor, and shall not be made use of elsewhere in the work.
- B. Any errors, defects, or omissions in the execution of work or in the materials furnished by the Contractor, even though they may have been passed or overlooked or have appeared after the completion of the work, discovered at any time before the final payment is made hereunder, shall be forthwith rectified and made good by and at the expense of the Contractor and in a manner satisfactory to the Owner or Owner's Representative.



C. The Contractor shall reimburse the Owner for any expense, losses or damages incurred in consequence of any defect error, omission or act of the Contractor or his employees, as determined by the Owner's Representative, occurring previous to the final payment.

# 3.34 PROJECT CLOSEOUT

# A. DESCRIPTION

- 1. This Section specifies administrative and procedural requirements for the project closeout including, but not limited to:
  - a. Project record document (As-Built drawings) submittal. Maintain a clean, undamaged set of blue or black line white-prints of Contract Drawings and Shop Drawings. Mark the set to show the actual installation where the installation varies substantially from the Work as originally shown. Mark whichever drawing is most capable of showing conditions fully and accurately; where Shop Drawings are used, record a cross-reference at the corresponding location on the Contract Drawings. Give particular attention to concealed elements that would be difficult to measure and record at a later date.
  - b. Organize record drawing sheets into manageable sets, bind with durable paper cover sheets, and print suitable titles, dates and other identification on the cover of each set. Upon completion of work, submit record drawings to the Owner's Representative.
- 2. Record Specifications
  - a. Maintain one complete copy of the Project Manual, including addenda. Mark these documents to show substantial variations in actual Work performed in comparison with the Specifications and modifications. Give particular attention to substitutions, selection of options and similar information on elements that are concealed or cannot otherwise be readily discerned later by direct observation. Note related record drawing information and Product Data. Upon completion of the Work, submit record Specifications.
- 3. Test Results
  - a. Not Applicable this project
- 4. REMOVAL OF PROTECTION
  - a. Remove temporary protection and facilities installed for protection of the Work during construction. Fencing and erosion and sediment control measures and best management practices can be removed after permanent measures have been established.

# 3.35 WARRANTIES

- A. DESCRIPTION
  - 1. This Section specifies general administration and procedural requirements for warranties and bonds required by the Contract Documents, including manufacturers' standard warranties on products and special warranties.
    - a. Refer to the General Conditions for terms of the Contractor's special warranty of workmanship and materials;
    - b. General closeout requirements are included in Section "Project Closeout"; and

### 010000 - 15

Copyright © 2021 by the American Institute of Architects. Warning: This AIA MasterSpec-based document is protected by U.S. Copyright Law and International Treaties. It was created by "Providence Parks Dept" for "Blackstone Boulevard Path Improvements 2021". A valid, current MasterSpec license is required for editing and use of this document for any other project.(16521)



- c. Specific requirements for warranties for the Work and products and installations that are specified to be warranted are included in the specifications and Drawings.
- 2. Disclaimers and Limitations
  - a. Manufacturer's disclaimers and limitations on product warranties do not relieve the Contractor of the warranty on the Work that incorporates the products, nor does it relieve suppliers, manufacturers, and subcontractors required to countersign special warranties with the Contractor.

# B. DEFINITIONS

- 1. Standard Warranties
  - a. Standard product warranties are pre-printed written warranties published by individual manufacturers for particular products and are specifically endorsed by the manufacturer to the Owner.
- 2. Special Warranties
  - a. Special warranties are written required by or incorporated in the Contract Documents, either to extend time limits provided by standard warranties or to provide greater rights for the Owner.

# C. WARRANTY REQUIREMENTS

- 1. Related Damages and Losses
  - a. When correcting warranted Work that has failed, remove and replace other Work that has been damaged as a result of such failure or that must be removed and replaced to provide access for corrections of warranted Work.
- 2. Reinstatement of Warranty
  - a. When Work covered by a warranty has failed and been corrected by replacement or rebuilding, reinstate the warranty by written endorsement. The reinstated warranty shall be equal to the original warranty with an equitable adjustment for depreciation.
- 3. Replacement Cost
  - a. Upon determination that Work covered by a warranty has failed, replace or rebuild the Work to an acceptable condition complying with requirements of Contract Documents. The Contractor is responsible for the cost of replacing or rebuilding defective Work regardless of whether the Owner's Representative has benefited from use of the Work through a portion of its anticipated useful service life.
- 4. Owner's Recourse
  - a. Written warranties made to the Owner are in addition to implied warranties, and shall not limit the duties, obligations, rights and remedies otherwise available under the law, nor shall warranty periods be interpreted as limitations on time in which the Owner can enforce such other duties, obligations, rights and remedies.
- 5. Rejection of Warranties
  - a. The Owner's Representative reserves the right to reject warranties and to limit selections to products with warranties not in conflict with requirements of the Contract Documents. The Owner's Representative reserves the right to refuse to accept Work for the Project where a special warranty, certification, or similar commitment is required on such Work or part of the Work, until evidence is presented that entities required to counter sign such commitments are willing to do so.



b. All warranties shall be submitted to the Owner in accordance with conditions of the Contract and the Submittals.

# D. WARRANTY PERIOD

- 1. All warranties required by the Contract documents shall commence on the date of Final Acceptance.
- 2. Warranty period is 1 (one) year from date of final acceptance unless otherwise specified.

# END OF SECTION 010000

Copyright © 2021 by the American Institute of Architects. Warning: This AIA MasterSpec-based document is protected by U.S. Copyright Law and International Treaties. It was created by "Providence Parks Dept" for "Blackstone Boulevard Path Improvements 2021". A valid, current MasterSpec license is required for editing and use of this document for any other project.(16521)



# SECTION 015639 - TEMPORARY TREE AND PLANT PROTECTION

# PART 1 - GENERAL

# 1.1 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General Requirements, apply to this Section.

# 1.2 SUMMARY

- A. Section includes general protection and pruning of existing trees and plants that are affected by execution of the Work, whether temporary or permanent construction.
- B. Related Requirements:
  - 1. Section 311000 "Site Clearing" for removing existing trees and shrubs.

## 1.3 DEFINITIONS

- A. (DBH): Diameter breast height; diameter of a trunk as measured by the average of the smallest and largest diameters at a height 54 inches above the ground line for trees with caliper of 8 inches or greater as measured at a height of 12 inches above the ground.
- B. Plant-Protection Zone: Area surrounding individual trees, shrubs, or other vegetation to be protected during construction and indicated on Drawings.
- C. Tree-Protection Zone: Area surrounding individual trees or groups of trees to be protected during construction and indicated on Drawings .
- D. Vegetation: Trees, shrubs, groundcovers, grass, and other plants.

# 1.4 PRE- CONSTRUCTION MEETINGS

- A. Pre-construction Conference: Conduct conference at Project site .
  - 1. Review methods and procedures related to temporary tree and plant protection including, but not limited to, the following:
    - a. Tree-service firm's personnel, and equipment needed to make progress and avoid delays.
    - b. Arborist's responsibilities.
    - c. Coordination of Work and equipment movement with the locations of protection zones.
    - d. Trenching by hand or with air spade within protection zones.
    - e. Field quality control and maintenance.



f. Coordination by Parks Department City Forester and Forestry crews.

# 1.5 ACTION SUBMITTALS

A. Contractor shall arrange site visit with City Forester prior to mobilization to determine the scope of pruning by the Parks Department Forestry Division or Contractor as indicated on the drawings.

# 1.6 QUALITY ASSURANCE

A. Arborist Qualifications: Licensed arborist in jurisdiction where Project is located .

# 1.7 FIELD CONDITIONS

- A. The following practices are prohibited within protection zones:
  - 1. Storage of construction materials, debris, or excavated material.
  - 2. Moving or parking vehicles or equipment.
  - 3. Foot traffic.
  - 4. Erection of sheds or structures.
  - 5. Impoundment of water.
  - 6. Excavation or other digging unless otherwise indicated.
  - 7. Attachment of signs to or wrapping materials around trees or plants unless otherwise indicated.
- B. Prohibit heat sources, flames, ignition sources, and smoking within or near protection zones and organic mulch.

# PART 2 - PRODUCTS

# 2.1 MATERIALS

- A. Backfill Soil: Stockpiled soil mixed with planting soil of suitable moisture content and granular texture for placing around tree; free of stones, roots, plants, sod, clods, clay lumps, pockets of coarse sand, concrete slurry, concrete layers or chunks, cement, plaster, building debris, and other extraneous materials harmful to plant growth.
  - 1. Mixture: Well-blended mix of two parts stockpiled soil to one part planting soil .
- B. Protection-Zone Fencing: Fencing fixed in position and meetingthe following requirements:
  - 1. Plastic Protection-Zone Fencing: Plastic construction fencing constructed of high-density extruded and stretched polyethylene fabric with 2-inch maximum opening in pattern and weighing a minimum of 0.4 lb/ft.; remaining flexible from minus 60 to plus 200 deg F; inert to most chemicals and acids; minimum tensile yield strength of 2000 psi and ultimate tensile strength of 2680 psi; secured with plastic bands or galvanized-steel or



stainless-steel wire ties; and supported by tubular or T-shape galvanized-steel posts spaced not more than 96 inches apart.

- a. Height: 72 inches .
- b. Color: High-visibility orange, nonfading.

# PART 3 - EXECUTION

# 3.1 PREPARATION

A. Protect tree root systems from damage caused by runoff or spillage of noxious materials while mixing, placing, or storing construction materials. Protect root systems from ponding, eroding, or excessive wetting caused by dewatering operations.

# 3.2 PROTECTION ZONES

- A. Protection-Zone Fencing: Install protection-zone fencing along edges of protection zones before materials or equipment are brought on the site and construction operations begin in a manner that will prevent people from easily entering protected areas except by entrance gates. Construct fencing so as not to obstruct safe passage or visibility at vehicle intersections where fencing is located adjacent to pedestrian walkways or in close proximity to street intersections, drives, or other vehicular circulation.
- B. Protection-Zone Signage: Install protection-zone signage in visibly prominent locations in a manner approved by Owner's Representative. Install one sign on protection-zone fencing. Sign to read "Tree Protection Zone Do not Disturb". Sign to be printed on 24"x 36" white panel with black lettering at a minimum of 3" height lettering.
- C. Maintain protection zones free of trash.
- D. Maintain protection-zone fencing in good condition as acceptable by Owner's Representative and remove when construction operations are complete and equipment has been removed from the site.
  - 1. Do not remove protection-zone fencing, even temporarily, to allow deliveries or equipment access through the protection zone.
  - 2. Temporary access is permitted subject to preapproval in writing by Owner's Representative if a root buffer effective against soil compaction is constructed as directed by Owner's Representative. Maintain root buffer so long as access is permitted.

# 3.3 EXCAVATION

- A. General: Excavate at edge of protection zones and for trenches indicated within protection zones according to requirements in Section 312000 "Earth Moving" unless otherwise indicated.
- B. Trenching within Protection Zones: Where utility trenches are required within protection zones, excavate under or around tree roots by hand or with air spade, or tunnel under the roots as



directed by Owner's Representative. Do not cut main lateral tree roots or taproots larger than 2" without direction from Owner's Representative; cut only smaller roots that interfere with installation of utilities. Cut roots as required for root pruning. If excavating by hand, use narrow-tine spading forks to comb soil and expose roots.

- C. Redirect roots in backfill areas where possible. If encountering large, main lateral roots, expose roots beyond excavation limits as required to bend and redirect them without breaking. If encountered immediately adjacent to location of new construction and redirection is not practical, cut roots approximately 3 inches back from new construction and as required for root pruning.
- D. Do not allow exposed roots to dry out before placing permanent backfill. Provide temporary earth cover and wrap with dampened burlap. Water and maintain in a moist condition. Temporarily support and protect roots from damage until they are permanently relocated and covered with soil or as directed by Owner's Representative.

# 3.4 ROOT PRUNING

- A. Prune tree roots that are affected by temporary and permanent construction. Prune roots as follows:
  - 1. Cut roots manually by digging a trench and cutting exposed roots with sharp pruning instruments; do not break, tear, chop, or slant the cuts. Do not use a backhoe or other equipment that rips, tears, or pulls roots.
  - 2. No roots larger than two (2) inches in diameter may be cut without permission of the City Forester. Cuts must be made with hand-pruner , handsaws, or chainsaws.
  - 3. Temporarily support and protect roots from damage until they are permanently redirected and covered with soil.
  - 4. Cover exposed roots with burlap and water regularly.
  - 5. Backfill as soon as possible according to requirements in Section 312000 "Earth Moving."
- B. Root Pruning within Protection Zone: Clear and excavate by hand or with air spade to the depth of the required excavation to minimize damage to tree root systems. If excavating by hand, use narrow-tine spading forks to comb soil to expose roots. Cleanly cut roots as close to excavation as possible.

# 3.5 REGRADING

- A. Lowering Grade: Where new finish grade is indicated below existing grade around trees, slope grade beyond the protection zone. Maintain existing grades within the protection zone.
- B. Lowering Grade within Protection Zone: Where new finish grade is indicated below existing grade around trees, slope grade away from trees as recommended by Owner's Representative unless otherwise indicated.
  - 1. Root Pruning: Prune tree roots exposed by lowering the grade. Do not cut main lateral roots or taproots; cut only smaller roots. Cut roots as required for root pruning.



C. Minor Fill within Protection Zone: Where existing grade is 2 inches or less below elevation of finish grade, fill with backfill soil. Place backfill soil in a single uncompacted layer and hand grade to required finish elevations.

# 3.6 REPAIR AND REPLACEMENT

- A. General: Repair or replace trees, shrubs, and other vegetation indicated to remain or to be relocated that are damaged by construction operations, in a manner approved by Owner's Representative.
  - 1. Submit details of proposed pruning and repairs.
  - 2. Perform repairs of damaged trunks, branches, and roots within 24 hours according to arborist's written instructions.
  - 3. Replace trees and other plants that cannot be repaired and restored to full-growth status, as determined by Owner's Representative. Replacement trees to be equal to the total diameter of mature tree by multiple equal diameter specimens.
- B. Trees: Remove and replace trees tha damaged during construction operations that Owner's Representative determines are incapable of restoring to normal growth pattern.
  - 1. Small Trees: Provide new trees of same size and species as those being replaced for each tree that measures 4" or smaller in caliper size.
  - 2. Large Trees: Provide multiple trees of 2-1/2" 3" caliper size to equal total diameter of tree being replaced.
    - a. Species: As determined by Owner's Representative.
  - 3. Plant and maintain new trees as specified in Section 329300 "Plants."
- C. Soil Aeration: Where directed by Owner's Representative, aerate surface soil compacted during construction. Aerate to loosen soil 10 feet beyond drip line and no closer than 36" to tree trunk with air spade.

# 3.7 DISPOSAL OF SURPLUS AND WASTE MATERIALS

A. Disposal: Remove excess excavated material, displaced trees, trash, and debris and legally dispose of them off Owner's property.

# END OF SECTION 015639



# SECTION 024119 - SELECTIVE DEMOLITION

# PART 1 - GENERAL

# 1.1 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General Requirements, apply to this Section.

# 1.2 SUMMARY

- A. Section Includes:
  - 1. Demolition and removal of selected site elements.
  - 2. Salvage of existing items to be reused or recycled.
- B. Related Requirements:
  - 1. Section 015639 "Temporary Tree and Plant Protection" for temporary protection of existing trees and plants that are affected by selective demolition.

# 1.3 DEFINITIONS

- A. Remove: Detach items from existing construction and legally dispose of them off-site unless indicated to be salvaged or reinstalled.
- B. Remove and Salvage: Detach items from existing construction, in a manner to prevent damage, and deliver to Owner, ready for reuse or store on a per project basis.
- C. Remove and Reinstall: Detach items from existing construction, in a manner to prevent damage, prepare for reuse, and reinstall where indicated.
- D. Existing to Remain: Leave existing items that are not to be removed and that are not otherwise indicated to be salvaged or reinstalled.
- E. Dismantle: To remove by disassembling or detaching an item from a surface, using gentle methods and equipment to prevent damage to the item and surfaces; disposing of items unless indicated to be salvaged or reinstalled.

# 1.4 MATERIALS OWNERSHIP

A. Unless otherwise indicated, demolition waste becomes property of Contractor.



- B. Historic items, relics, antiques, and similar objects including, but not limited to, cornerstones and their contents, commemorative plaques and tablets, and other items of interest or value to Owner that may be uncovered during demolition remain the property of Owner.
  - 1. Carefully salvage in a manner to prevent damage and promptly return to Owner.

# 1.5 PRE-CONSTRUCTION MEETINGS

- A. Pre-demolition Conference: Conduct conference at Project site .
  - 1. Inspect and discuss condition of construction to be selectively demolished.
  - 2. Review and finalize selective demolition schedule and verify availability of materials, demolition personnel, equipment, and facilities needed to make progress and avoid delays.
  - 3. Review requirements of work performed by other trades that rely on substrates exposed by selective demolition operations.
  - 4. Review areas where existing construction is to remain and requires protection.

# 1.6 INFORMATIONAL SUBMITTALS

- A. Proposed Protection Measures: Submit report, including Drawings, that indicates the measures proposed for protecting individuals and property, for environmental protection, for dust control and, for noise control. Indicate proposed locations and construction of barriers.
- B. Schedule of Selective Demolition Activities: Indicate the following:
  - 1. Detailed sequence of selective demolition and removal work, with starting and ending dates for each activity. Ensure Owner's on-site uses are uninterrupted.
  - 2. Interruption of utility services. Indicate how long utility services will be interrupted.
  - 3. Coordination for shutoff, capping, and continuation of utility services.
  - 4. Coordination of Owner's continuing use of portions of existing site and of Owner's partial use of completed Work.
- C. Predemolition Photographs or Video: Show existing conditions of adjoining construction, including finish surfaces, that might be misconstrued as damage caused by demolition operations. Comply with Section 013233 "Photographic Documentation." Submit before Work begins.
- D. Warranties: Documentation indicating that existing warranties are still in effect after completion of selective demolition.

# 1.7 FIELD CONDITIONS

A. Owner will occupy portions of the site immediately adjacent to selective demolition area. Conduct selective demolition so Owner's use will not be disrupted.



- B. Conditions existing at time of inspection for bidding purpose will be maintained by Owner as far as practical.
  - 1. Before selective demolition, Owner will remove the items specifically indicated on the drawings
- C. Notify Owner's Representative of discrepancies between existing conditions and Drawings before proceeding with selective demolition.
- D. Hazardous Materials: It is not expected that hazardous materials will be encountered in the Work.
  - 1. Hazardous materials will be removed by Owner before start of the Work.
  - 2. If suspected hazardous materials are encountered, do not disturb; immediately notify Architect and Owner. Hazardous materials will be removed by Owner under a separate contract.
- E. Hazardous Materials: Present in buildings and structures to be selectively demolished. A report on the presence of hazardous materials is on file for review and use. Examine report to become aware of locations where hazardous materials are present.
  - 1. Hazardous material remediation is specified elsewhere in the Contract Documents.
  - 2. Do not disturb hazardous materials or items suspected of containing hazardous materials except under procedures specified elsewhere in the Contract Documents.
  - 3. Owner will provide material safety data sheets for suspected hazardous materials that are known to be present in buildings and structures to be selectively demolished because of building operations or processes performed there.
- F. Historic Areas: Demolition and hauling equipment and other materials shall be of sizes that clear surfaces within historic spaces, areas, rooms, and openings, including temporary protection
- G. Storage or sale of removed items or materials on-site is not permitted.
- H. Utility Service: Maintain existing utilities indicated to remain in service and protect them against damage during selective demolition operations.

# 1.8 WARRANTY

- A. Existing Warranties: Remove, replace, patch, and repair materials and surfaces cut or damaged during selective demolition, by methods and with materials and using approved contractors so as not to void existing warranties. Notify warrantor before proceeding.
- B. Notify Owner on completion of selective demolition, and obtain documentation verifying that existing system has been inspected and warranty remains in effect. Submit documentation at Project closeout.



# 1.9 COORDINATION

A. Arrange selective demolition schedule so as not to interfere with Owner's use.

# PART 2 - PRODUCTS

# 2.1 PERFORMANCE REQUIREMENTS

- A. Regulatory Requirements: Comply with governing EPA notification regulations before beginning selective demolition. Comply with hauling and disposal regulations of authorities having jurisdiction.
- B. Standards: Comply with ASSE A10.6 and NFPA 241.

# PART 3 - EXECUTION

# 3.1 EXAMINATION

- A. Verify that utilities have been disconnected and capped before starting selective demolition operations.
  - 1. Contact Dig Safe-Provide Dig Safe number to Owner prior to mobilization.
- B. Review Project Record Documents of existing construction or other existing condition and hazardous material information provided by Owner. Owner does not guarantee that existing conditions are same as those indicated in Project Record Documents.
  - 1. Meet with Owner's Representative to identify local utilities prior to mobilization.
- C. Survey of Existing Conditions: Record existing conditions by use of preconstruction photographs. measured drawings .
  - 1. Comply with requirements specified in Section 013233 "Photographic Documentation."
  - 2. Inventory and record the condition of items to be removed and salvaged. Provide photographs or video of conditions that might be misconstrued as damage caused by salvage operations. Notify Owner of damaged items.
  - 3. Before selective demolition or removal of existing elements that will be reproduced or duplicated in final Work, make permanent record of measurements, materials, and construction details required to make exact reproduction.

# 3.2 UTILITY SERVICES AND MECHANICAL/ELECTRICAL SYSTEMS

A. Existing Services/Systems to Remain: Maintain services/systems indicated to remain and protect them against damage.



- B. Existing Services/Systems to Be Removed, Relocated, or Abandoned: Locate, identify, disconnect, and seal or cap off utility services and mechanical/electrical systems serving areas to be selectively demolished.
  - 1. Owner will arrange to shut off indicated services/systems when requested by Contractor.
  - 2. Arrange to shut off utilities with utility companies.
  - 3. If services/systems are required to be removed, relocated, or abandoned, provide temporary services/systems that bypass area of selective demolition and that maintain continuity of services/systems to other parts of the site.
  - 4. Disconnect, demolish, and remove fire-suppression systems, plumbing, and HVAC systems, equipment, and components indicated on Drawings to be removed.
    - a. Piping to Be Removed: Remove portion of piping indicated to be removed and cap or plug remaining piping with same or compatible piping material.
    - b. Piping to Be Abandoned in Place: Drain piping and cap or plug piping with same or compatible piping material and leave in place.
    - c. Equipment to Be Removed: Disconnect and cap services and remove equipment.
    - d. Equipment to Be Removed and Reinstalled: Disconnect and cap services and remove, clean, and store equipment; when appropriate, reinstall, reconnect, and make equipment operational.
    - e. Equipment to Be Removed and Salvaged: Disconnect and cap services and remove equipment and deliver to Owner.
    - f. Ducts to Be Removed: Remove portion of ducts indicated to be removed and plug remaining ducts with same or compatible ductwork material.
    - g. Ducts to Be Abandoned in Place: Cap or plug ducts with same or compatible ductwork material and leave in place.

# 3.3 PROTECTION

- A. Temporary Protection: Provide temporary barricades and other protection required to prevent injury to people and damage to adjacent buildings and facilities to remain.
  - 1. Provide protection to ensure safe passage of people around selective demolition area and to and from occupied portions of the site.
  - 2. Provide temporary weather protection, during interval between selective demolition of existing construction on exterior surfaces and new construction, to prevent water leakage and damage to structure and interior areas.
  - 3. Protect walls, ceilings, floors, and other existing finish work that are to remain or that are exposed during selective demolition operations.
  - 4. Cover and protect furniture, furnishings, and equipment that have not been removed.
  - 5. Comply with requirements for temporary enclosures, dust control, heating, and cooling specified in Section 015000 "Temporary Facilities and Controls."
- B. Temporary Shoring: Design, provide, and maintain shoring, bracing, and structural supports as required to preserve stability and prevent movement, settlement, or collapse of construction and finishes to remain, and to prevent unexpected or uncontrolled movement or collapse of construction being demolished.
  - 1. Strengthen or add new supports when required during progress of selective demolition.



C. Remove temporary barricades and protections where hazards no longer exist.

# 3.4 SELECTIVE DEMOLITION, GENERAL

- A. General: Demolish and remove existing construction only to the extent required by new construction and as indicated. Use methods required to complete the Work within limitations of governing regulations and as follows:
  - 1. Neatly cut openings and holes plumb, square, and true to dimensions required. Use cutting methods least likely to damage construction to remain or adjoining construction. Use hand tools or small power tools designed for sawing or grinding, not hammering and chopping. Temporarily cover openings to remain.
  - 2. Cut or drill from the exposed or finished side into concealed surfaces to avoid marring existing finished surfaces.
  - 3. Do not use cutting torches until work area is cleared of flammable materials. At concealed spaces, such as duct and pipe interiors, verify condition and contents of hidden space before starting flame-cutting operations. Maintain portable fire-suppression devices during flame-cutting operations.
  - 4. Maintain adequate ventilation when using cutting torches.
  - 5. Remove decayed, vermin-infested, or otherwise dangerous or unsuitable materials and promptly dispose of off-site.
  - 6. Dispose of demolished items and materials promptly and legally off site.
- B. Site Access and Temporary Controls: Conduct selective demolition and debris-removal operations to ensure minimum interference with roads, streets, walks, walkways, and other adjacent occupied and used facilities.
- C. Work in Historic Areas: Selective demolition may be performed only in areas of Project that are not designated as historic. In historic spaces, areas, and rooms, or on historic surfaces, the terms "demolish" or "remove" shall mean historic "removal" or "dismantling."
- D. Removed and Salvaged Items:
  - 1. Clean salvaged items.
  - 2. Store items in a secure area until delivery to Owner.
  - 3. Transport items to location designated by Owner's Representative.
  - 4. Protect items from damage during transport and storage.
- E. Removed and Reinstalled Items:
  - 1. Clean and repair items to functional condition adequate for intended reuse.
  - 2. Protect items from damage during transport and storage.
  - 3. Reinstall items in locations indicated. Comply with installation requirements for new materials and equipment. Provide connections, supports, and miscellaneous materials necessary to make item functional for use indicated.
- F. Existing Items to Remain: Protect construction indicated to remain against damage and soiling during selective demolition. When permitted by Owner's Representative, items may be removed



to a suitable, protected storage location during selective demolition and reinstalled in their original locations after selective demolition operations are complete.

# 3.5 SELECTIVE DEMOLITION PROCEDURES FOR SPECIFIC MATERIALS

- A. Concrete: Demolish in small sections. Using power-driven saw, cut concrete to a depth of at least 3/4 inch at junctures with construction to remain. Dislodge concrete from reinforcement at perimeter of areas being demolished, cut reinforcement, and then remove remainder of concrete.
- B. Concrete: Demolish in sections. Cut concrete full depth at junctures with construction to remain and at regular intervals using power-driven saw, and then remove concrete between saw cuts.
- C. Masonry: Demolish in small sections. Cut masonry at junctures with construction to remain, using power-driven saw, and then remove masonry between saw cuts.
- D. Concrete Slabs-on-Grade: Saw-cut perimeter of area to be demolished, and then break up and remove.
- E. Roofing: Remove no more existing roofing than what can be covered in one day by new roofing and so that building interior remains watertight and weathertight.
  - 1. Remove existing roof membrane, flashings, copings, and roof accessories.
  - 2. Remove existing roofing system down to substrate.

# 3.6 DISPOSAL OF DEMOLISHED MATERIALS

- A. Remove demolition waste materials from Project site and dispose of legally.
  - 1. Do not allow demolished materials to accumulate on-site.
  - 2. Remove and transport debris in a manner that will prevent spillage on adjacent surfaces and areas.
  - 3. Remove debris from elevated portions of building by chute, hoist, or other device that will convey debris to grade level in a controlled descent.
- B. Burning: Do not burn demolished materials.

# 3.7 CLEANING

A. Clean adjacent structures and improvements of dust, dirt, and debris caused by selective demolition operations. Return adjacent areas to condition existing before selective demolition operations began.

END OF SECTION 024119



# SECTION 312000 - EARTH MOVING

# PART 1 - GENERAL

# 1.1 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General Requirements apply to this Section.

# 1.2 SUMMARY

- A. Section Includes:
  - 1. Excavating and filling for rough grading the Site.
  - 2. Preparing subgrades for slabs-on-grade walks pavements turf and grasses .
  - 3. Excavating and backfilling for buildings and structures.
  - 4. Drainage course for concrete slabs-on-grade.
  - 5. Subbase course for concrete pavements.
  - 6. Subbase course and base course for asphalt paving.
- B. Related Requirements:
  - 1. Section 329200 "Turf and Grasses" for finish grading in turf and grass areas, including preparing and placing planting soil for turf areas.

# 1.3 DEFINITIONS

- A. Backfill: Soil material or controlled low-strength material used to fill an excavation.
  - 1. Initial Backfill: Backfill placed beside and over pipe in a trench, including haunches to support sides of pipe.
  - 2. Final Backfill: Backfill placed over initial backfill to fill a trench.
- B. Base Course: Aggregate layer placed between the subbase course and hot-mix asphalt paving.
- C. Bedding Course: Aggregate layer placed over the excavated subgrade in a trench before laying pipe.
- D. Borrow Soil: Satisfactory soil imported from off-site for use as fill or backfill.
- E. Drainage Course: Aggregate layer supporting the slab-on-grade that also minimizes upward capillary flow of pore water.
- F. Excavation: Removal of material encountered above subgrade elevations and to lines and dimensions indicated.



- 1. Authorized Additional Excavation: Excavation below subgrade elevations or beyond indicated lines and dimensions as directed by Architect. Authorized additional excavation and replacement material will be paid for according to Contract provisions for unit prices
- 2. Bulk Excavation: Excavation more than 10 feet in width and more than 30 feet in length.
- 3. Unauthorized Excavation: Excavation below subgrade elevations or beyond indicated lines and dimensions without direction by Architect. Unauthorized excavation, as well as remedial work directed by Architect, shall be without additional compensation.
- G. Fill: Soil materials used to raise existing grades.
- H. Rock: Rock material in beds, ledges, unstratified masses, conglomerate deposits, and boulders of rock material 3/4 cu. yd. or more in volume that exceed a standard penetration resistance of 100 blows/2 inches when tested by a geotechnical testing agency, according to ASTM D1586.
- I. Structures: Buildings, footings, foundations, retaining walls, slabs, tanks, curbs, mechanical and electrical appurtenances, or other man-made stationary features constructed above or below the ground surface.
- J. Subbase Course: Aggregate layer placed between the subgrade and base course for hot-mix asphalt pavement, or aggregate layer placed between the subgrade and a cement concrete pavement or a cement concrete or hot-mix asphalt walk.
- K. Subgrade: Uppermost surface of an excavation or the top surface of a fill or backfill immediately below subbase, drainage fill, drainage course, or topsoil materials.
- L. Utilities: On-site underground pipes, conduits, ducts, and cables as well as underground services within buildings.

# 1.4 PREINSTALLATION MEETINGS

- A. Preinstallation Conference: Conduct preexcavation conference at Project site .
  - 1. Review methods and procedures related to earthmoving, including, but not limited to, the following:
    - a. Personnel and equipment needed to make progress and avoid delays.
    - b. Coordination of Work with utility locator service.
    - c. Coordination of Work and equipment movement with the locations of tree- and plant-protection zones.
    - d. Extent of excavation by hand or with air spade.
    - e. Field quality control.

# 1.5 FIELD CONDITIONS

A. Traffic: Minimize interference with adjoining roads, streets, walks, and other adjacent occupied or used facilities during earth-moving operations.


- 1. Do not close or obstruct streets, walks, or other adjacent occupied or used facilities without permission from Owner and authorities having jurisdiction.
- 2. Provide alternate routes around closed or obstructed traffic ways if required by Owner or authorities having jurisdiction.
- B. Utility Locator Service: Notify utility locator service "Dig Safe System" for area where Project is located before beginning earth-moving operations.
- C. Do not commence earth-moving operations until temporary site fencing and erosion- and sedimentation-control measures specified in 312500 Erosion & Sedimentation Control are in place.
- D. Do not commence earth-moving operations until plant-protection measures specified in Section 015639 "Temporary Tree and Plant Protection" are in place.
- E. The following practices are prohibited within protection zones:
  - 1. Storage of construction materials, debris, or excavated material.
  - 2. Parking vehicles or equipment.
  - 3. Foot traffic.
  - 4. Erection of sheds or structures.
  - 5. Impoundment of water.
  - 6. Excavation or other digging unless otherwise indicated.
  - 7. Attachment of signs to or wrapping materials around trees or plants unless otherwise indicated.
- F. Do not direct vehicle or equipment exhaust towards protection zones.
- G. Prohibit heat sources, flames, ignition sources, and smoking within or near protection zones.

# PART 2 - PRODUCTS

#### 2.1 SOIL MATERIALS

- A. General: Provide borrow soil materials when sufficient satisfactory soil materials are not available from excavations.
  - 1. Unsatisfactory soils also include satisfactory soils not maintained within 2 percent of optimum moisture content at time of compaction.
- B. Base Course: Naturally or artificially graded mixture of natural or crushed gravel, crushed stone, and natural or crushed sand; ASTM D2940/D2940M; with at least 95 percent passing a 1-1/2-inch sieve and not more than 8 percent passing a No. 200 sieve.



## 2.2 GEOTEXTILES

- A. Subsurface Drainage Geotextile: Nonwoven needle-punched geotextile, manufactured for subsurface drainage applications, made from polyolefins or polyesters; with elongation greater than 50 percent; complying with AASHTO M 288 and the following, measured per test methods referenced:
  - 1. Survivability: Class 2; AASHTO M 288.
  - 2. Survivability: As follows:
    - a. Grab Tensile Strength: 157 lbf; ASTM D4632.
    - b. Sewn Seam Strength: 142 lbf; ASTM D4632.
    - c. Tear Strength: 56 lbf; ASTM D4533.
    - d. Puncture Strength: 56 lbf; ASTM D4833.
  - 3. Apparent Opening Size: No. 40 sieve, maximum; ASTM D4751.
  - 4. Permittivity: 0.5 per second, minimum; ASTM D4491.
  - 5. UV Stability: 50 percent after 500 hours' exposure; ASTM D4355.

#### 2.3 ACCESSORIES

- A. Detectable Warning Tape: Acid- and alkali-resistant, polyethylene film warning tape manufactured for marking and identifying underground utilities, a minimum of 6 inches wide and 4 mils thick, continuously inscribed with a description of the utility, with metallic core encased in a protective jacket for corrosion protection, detectable by metal detector when tape is buried up to 30 inches deep; colored as follows:
  - 1. Red: Electric.
  - 2. Yellow: Gas, oil, steam, and dangerous materials.
  - 3. Orange: Telephone and other communications.
  - 4. Blue: Water systems.
  - 5. Green: Sewer systems.

#### PART 3 - EXECUTION

#### 3.1 PREPARATION

- A. Protect structures, utilities, sidewalks, pavements, and other facilities from damage caused by settlement, lateral movement, undermining, washout, and other hazards created by earth-moving operations.
- B. Protect and maintain erosion and sedimentation controls during earth-moving operations.
- C. Protect subgrades and foundation soils from freezing temperatures and frost. Remove temporary protection before placing subsequent materials.

Providence Parks Department Blackstone Boulevard Path Improvements 2021



### 3.2 EXPLOSIVES

A. Explosives: Do not use explosives.

## 3.3 EXCAVATION, GENERAL

- A. Unclassified Excavation: Excavate to subgrade elevations regardless of the character of surface and subsurface conditions encountered. Unclassified excavated materials may include rock, soil materials, and obstructions. No changes in the Contract Sum or the Contract Time will be authorized for rock excavation or removal of obstructions.
  - 1. If excavated materials intended for fill and backfill include unsatisfactory soil materials and rock, replace with satisfactory soil materials.
- B. Classified Excavation: Excavate to subgrade elevations. Material to be excavated will be classified as earth and rock. Do not excavate rock until it has been classified and cross sectioned by Architect. The Contract Sum will be adjusted for rock excavation according to unit prices included in the Contract Documents. Changes in the Contract Time may be authorized for rock excavation.
  - 1. Earth excavation includes excavating pavements and obstructions visible on surface; underground structures, utilities, and other items indicated to be removed; and soil, boulders, and other materials not classified as rock or unauthorized excavation.

#### 3.4 EXCAVATION FOR WALKS AND PAVEMENTS

A. Excavate surfaces under walks and pavements to indicated lines, cross sections, elevations, and subgrades.

#### 3.5 SUBGRADE INSPECTION

- A. Notify Architect when excavations have reached required subgrade.
- B. If Architect determines that unsatisfactory soil is present, continue excavation and replace with compacted backfill or fill material as directed.
- C. Authorized additional excavation and replacement material will be paid for according to Contract provisions for changes in the Work.
- D. Reconstruct subgrades damaged by freezing temperatures, frost, rain, accumulated water, or construction activities, as directed by Architect, without additional compensation.

#### 3.6 UNAUTHORIZED EXCAVATION

A. Fill unauthorized excavation under foundations or wall footings by extending bottom elevation of concrete foundation or footing to excavation bottom, without altering top elevation. Lean



concrete fill, with 28-day compressive strength of 2500 psi, may be used when approved by Architect.

1. Fill unauthorized excavations under other construction, pipe, or conduit as directed by Architect.

### 3.7 STORAGE OF SOIL MATERIALS

- A. Stockpile borrow soil materials and excavated satisfactory soil materials without intermixing. Place, grade, and shape stockpiles to drain surface water. Cover to prevent windblown dust.
  - 1. Stockpile soil materials away from edge of excavations. Do not store within drip line of remaining trees.

## 3.8 BACKFILL

- A. Place and compact backfill in excavations promptly, but not before completing the following:
  - 1. Construction below finish grade including, where applicable, subdrainage, dampproofing, waterproofing, and perimeter insulation.
  - 2. Removing trash and debris.
- B. Place backfill on subgrades free of mud, frost, snow, or ice.

# 3.9 SOIL FILL

- A. Plow, scarify, bench, or break up sloped surfaces steeper than 1 vertical to 4 horizontal so fill material will bond with existing material.
- B. Place and compact fill material in layers to required elevations as follows:
  - 1. Under grass and planted areas, use satisfactory soil material.
  - 2. Under walks and pavements, use satisfactory soil material.
- C. Place soil fill on subgrades free of mud, frost, snow, or ice.

#### 3.10 GRADING

- A. General: Uniformly grade areas to a smooth surface, free of irregular surface changes. Comply with compaction requirements and grade to cross sections, lines, and elevations indicated.
  - 1. Provide a smooth transition between adjacent existing grades and new grades.
  - 2. Cut out soft spots, fill low spots, and trim high spots to comply with required surface tolerances.



### 3.11 SUBBASE AND BASE COURSES UNDER PAVEMENTS AND WALKS

- A. Place base course on subgrades free of mud, frost, snow, or ice.
- B. On prepared subgrade, place base course under pavements and walks as follows:
  - 1. Install separation geotextile on prepared subgrade according to manufacturer's written instructions, overlapping sides and ends.
  - 2. Place base course material under hot-mix asphalt pavement.
  - 3. Shape base course to required crown elevations and cross-slope grades.
  - 4. Place base course 6 inches or less in compacted thickness in a single layer.
  - 5. Place base course that exceeds 6 inches in compacted thickness in layers of equal thickness, with no compacted layer more than 6 inches thick or less than 3 inches thick.

#### 3.12 PROTECTION

- A. Protecting Graded Areas: Protect newly graded areas from traffic, freezing, and erosion. Keep free of trash and debris.
- B. Repair and reestablish grades to specified tolerances where completed or partially completed surfaces become eroded, rutted, settled, or where they lose compaction due to subsequent construction operations or weather conditions.
  - 1. Scarify or remove and replace soil material to depth as directed by Architect; reshape and recompact.
- C. Where settling occurs before Project correction period elapses, remove finished surfacing, backfill with additional soil material, compact, and reconstruct surfacing.
  - 1. Restore appearance, quality, and condition of finished surfacing to match adjacent work, and eliminate evidence of restoration to greatest extent possible.

#### 3.13 DISPOSAL OF SURPLUS AND WASTE MATERIALS

- A. Transport surplus satisfactory soil to designated storage areas on Owner's property. Stockpile or spread soil as directed by Architect.
  - 1. Remove waste materials, including unsatisfactory soil, trash, and debris, and legally dispose of them off Owner's property.

END OF SECTION 312000



# SECTION 312213 - ROUGH GRADING

### PART 1 - GENERAL

#### 1.1 SUMMARY

- A. Section Includes:
  - 1. Excavating topsoil.
  - 2. Excavating subsoil.
  - 3. Cutting, grading, filling, rough contouring, compacting, site for stonedust & chip-seal paths and concrete pads .
- B. Related Sections:
  - 1. Section 310513 Soils for Earthwork: Soils for fill.
  - 2. Section 310516 Aggregates for Earthwork: Aggregates for fill.
  - 3. Section 329119 Landscape Grading: Finish grading with topsoil to contours.

## 1.2 UNIT PRICE - MEASUREMENT AND PAYMENT

- A. Topsoil Fill Type S4 :
  - 1. Basis of Measurement: By Cubic Yard .
  - 2. Basis of Payment: Includes excavating existing soil, supplying soil materials, stockpiling, scarifying substrate surface, placing where required, and compacting.
- B. Subsoil Fill Type S2 :
  - 1. Basis of Measurement: By the cubic yard.
  - 2. Basis of Payment: Includes excavating existing subsoil, supplying subsoil materials, stockpiling, scarifying substrate surface, placing where required, and compacting.

#### 1.3 REFERENCES

- A. American Association of State Highway and Transportation Officials:
  - 1. AASHTO T180 Standard Specification for Moisture-Density Relations of Soils Using a 4.54-kg (10-lb) Rammer and a 457-mm (18-in.) Drop.
- B. ASTM International:
  - 1. ASTM C136 Standard Test Method for Sieve Analysis of Fine and Coarse Aggregates.
  - 2. ASTM D698 Standard Test Method for Laboratory Compaction Characteristics of Soil Using Standard Effort (12,400 ft-lbf/ft3 (600 kN-m/m3).



3. ASTM D1557 - Standard Test Methods for Laboratory Compaction Characteristics of Soil Using Modified Effort (56,000 ft-lbf/ft3 (2,700 kN-m/m3).

# 1.4 SUBMITTALS

A. Materials Source: Submit name of imported materials suppliers.

### 1.5 CLOSEOUT SUBMITTALS

- A. Section 01000 General Requirements: Requirements for submittals.
- B. Project Record Documents: Accurately record actual locations of utilities remaining by horizontal dimensions, elevations or inverts, and slope gradients.

## 1.6 QUALITY ASSURANCE

- A. Perform Work in accordance with RIDOT Standard Specifications for Road and Bridge Construction, latest edition.
- B. Maintain one copy of each document on site

## PART 2 - PRODUCTS

#### 2.1 MATERIALS

- A. Topsoil: Type S4 as specified in Section 310513.
- B. Subsoil Fill: Type S2 as specified in Section 310513.

#### PART 3 - EXECUTION

#### 3.1 EXAMINATION

A. Verify survey bench mark and intended elevations for the Work are as indicated on Drawings.

#### 3.2 PREPARATION

- A. Call Local Utility Line Information service at 1-888-DIG-SAFE not less than three (3) working days before performing Work.
  - 1. Request underground utilities to be located and marked within and surrounding construction areas.



- B. Identify required lines, levels, contours, and datum.
- C. Protect utilities indicated to remain from damage.
- D. Protect plant life, lawns, structures, and other features remaining as portion of final landscaping.
- E. Protect bench marks, survey control point, existing structures, fences, sidewalks, paving, and curbs from excavating equipment and vehicular traffic.

## 3.3 TOPSOIL EXCAVATION

- A. Excavate topsoil from areas to be further excavated, relandscaped, or regraded, in marked areas, without mixing with foreign materials for use in finish grading.
- B. Do not excavate wet topsoil.
- C. Stockpile in area designated on site to depth not exceeding 8 feet and protect from erosion. Stockpile material on impervious material and cover over with same material, until disposal.
- D. Remove excess topsoil not intended for reuse, from site.

#### 3.4 SUBSOIL EXCAVATION

- A. Excavate subsoil from areas to be further excavated, relandscaped, or regraded. marked areas.
- B. Do not excavate wet subsoil .
- C. When excavating through roots, perform Work by hand and do not remove any roots over 2" in diameter.
- D. Stockpile excavated material in area designated on site in accordance with Section 310513.
- E. Benching Slopes: Horizontally bench existing slopes greater than 1: 4 to key placed fill material to slope to provide firm bearing.
- F. Stability: Replace damaged or displaced subsoil as specified for fill.

#### 3.5 FILLING

- A. Fill areas to contours and elevations with unfrozen materials.
- B. Place material in continuous layers as follows:
  - 1. Subsoil Fill: Maximum 8 inches compacted depth.
  - 2. Granular Fill: Maximum 6 inches compacted depth.
- C. Maintain optimum moisture content of fill materials to attain required compaction density.



- D. Make grade changes gradual. Blend slope into level areas.
- E. Repair or replace items indicated to remain damaged by excavation or filling.
- F. Install Work in accordance with RIDOT Standard Specifications for Road and Bridge Construction, latest edition.

#### 3.6 TOLERANCES

- A. Section 014000 Quality Requirements: Tolerances.
- B. Top Surface of Subgrade: Plus or minus 1/10 foot from required elevation.

#### 3.7 SCHEDULES

- A. Subsoil Fill:
  - 1. Fill Type S2 : To subgrade elevation. 6" thick.
  - 2. Compact uniformly to minimum 95% percent of maximum density.
- B. Topsoil Fill:
  - 1. Fill Type S4 : To subgrade elevation. 6" thick.
  - 2. Compact uniformly to minimum 90 % percent of maximum density.

#### END OF SECTION 312213



# SECTION 312500 - EROSION AND SEDIMENTATION CONTROLS

### PART 1 - GENERAL

#### 1.1 SUMMARY

- A. Furnish all labor, materials, equipment and incidentals required and perform all installation, maintenance, removal and area cleanup related to erosion and sedimentation control work required to meet Federal, State, and local permit requirements and as shown on the Drawings and as specified herein. The work shall include, but not necessarily be limited to; installation of temporary access ways and staging areas, compost filter socks, catch basin sediment filters (silt sack), sediment removal and disposal, device maintenance, removal of temporary devices, and final cleanup.
- B. Related Sections:
  - 1. Section 329119 Landscape Grading.

#### 1.2 REFERENCES

- A. EPA document titled: "Stormwater Management for Construction Activities Developing Pollution Prevention Plans and Best Management Practices" document number EPA 832-R-92¬005, dated 1992, or most recent edition. State, County Conservation Districts or local Conservation Commission standards can be substituted for the EPA standard if the State, County or Local Conservation Commission standards is equal to, or more detailed than, the EPA standard.
- B. State of Rhode Island Department of Transportation Standard Specifications for Road and Bridge Construction, Current Edition with latest addenda.

#### 1.3 SUBMITTALS

- A. Submit, in accordance with Division 01 10 00 General Requirements: Submittal Procedures ten (10) days after award of Contract, technical product literature for all commercial products to be used for erosion and sedimentation control.
- B. If a NPDES General Permit is required, Contractor shall, prior to the start of construction:
- C. Prepare and submit the EPA NPDES Notice of Intent to Discharge to the applicable EPA office in accordance with EPA regulations. Submit one copy of the permit to Owner's Representative for informational purposes only.
  - 1. Prepare and submit a Stormwater Pollution Prevention Plan (SWPPP) in accordance with the U.S. Environmental Protection Agency (EPA) National Pollution Discharge



Elimination System (NPDES) General Permit for this work. Submit one copy of the permit to Owner's Representative for informational purposes only.

# 1.4 QUALITY ASSURANCE

- A. Be responsible for the timely installation and maintenance of all erosion and sedimentation control devices necessary to prevent the movement of sediment from the construction site to off-site areas or into the stream system via surface runoff or underground drainage systems. Measures in addition to those shown on the Drawings necessary to prevent the movement of sediment off site shall be installed, maintained, removed, and cleaned up at the expense of the Contractor. No additional charges to the Owner will be considered.
- B. Where Contractor's efforts to control erosion and sediment have been demonstrated to be ineffective or potentially ineffective in the opinion of the Owner's Representative, the Owner's Representative may order that additional measures be implemented and constructed at no additional cost to the Owner.
- C. Perform Work in accordance with requirements of Section 310513, Section 312213.
- D. Perform Work according to Municipality of Public Works standards.

# PART 2 - PRODUCTS

# 2.1 MATERIALS

- A. Catch Basin sediment control devises shall be sediment capture devices specifically designed for this purpose such as "Silt Sack" by Geo-Synthetics, LLC or approved equal.
- B. When work is performed outside of normal seeding window straw mulch shall be utilized on all newly graded areas to protect areas against washouts and erosion. Straw mulch shall be comprised of threshed straw of oats, wheat, barley, or rye that is free from noxious weeds, mold or other objectionable material. The straw mulch shall contain at least 50 percent by weight of material to be 10-in or longer. Straw shall be in an air-dry condition and suitable for placement with blower equipment.
- C. Compost Filter Sock
  - 1. Machine produced.
  - 2. Straw filled tubes of compacted straw of rice, wheat or barley.
  - 3. Compost filter sock to be certified as weed free.
  - 4. Netting for tubes to be seamless, high density polyethylene with ultra violet inhibitors.
  - 5. Roll length to be 10.0 feet to 25.0 feet.
  - 6. Weight per linear foot, 12-inch: 2.5 lbs. minimum 9-inch: 1.5 lbs. minimum
  - 7. Stakes shall be wooden, 1 1/8-inch x 1 1/8-inch x 2.5 feet long, with lower ends tapered to facilitate driving into compacted soil. Rebar may be substituted for wooden stakes



PART 3 - EXECUTION

## 3.1 INSTALLATION

- A. Catch basin sediment control devices shall be installed according to manufacturer's recommendations and as directed by the Owner's Representative.
- B. Staging areas and stabilized construction entrance shall be surfaced with a minimum depth of 6 inches of crushed stone (if so directed by the Owner's Representative). Stabilized construction entrances shall be installed as shown on the Plans.

# 3.2 MAINTENANCE AND INSPECTION

- A. Inspections
- B. Make a visual inspection of all erosion and sedimentation control devices once per week and promptly after every rainstorm. If such inspection reveals that additional measures are needed to prevent movement of sediment to offsite areas, promptly install additional devices as needed. Sediment controls in need of maintenance shall be repaired promptly.
- C. Device Maintenance
- D. Sediment Filters
  - 1. Catch basin sediment control devices shall be cleaned of sediment in a manner as recommended by the manufacturer and as directed by the Owner's Representative. Remove sediment from filter bag when saturated with sediment as directed by the Owner's Representative.

#### 3.3 REMOVAL AND FINAL CLEANUP

- A. Once the site has been permanently stabilized against erosion, remove all sediment control devices and sediment. Dispose sediment and all waste materials in a proper manner.
- B. When sediment accumulation in sedimentation structures has reached a point one-third depth of sediment structure or device, remove and dispose of sediment.
- C. Do not damage structure or device during cleaning operations.
- D. Clean channels when depth of sediment reaches approximately one half channel depth.
- E. Clean channels when depth of sediment reaches approximately one half channel depth.

#### END OF SECTION 312500



## SECTION 321216 - ASPHALT PAVING

## PART 1 - GENERAL

### 1.1 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General Conditions apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:
  - 1. Hot-mix asphalt paving.
  - 2. Hot-mix asphalt overlay
- B. Related Requirements:
  - 1. Section 312000 "Earth Moving" for subgrade preparation, fill material, separation geotextiles, unbound-aggregate subbase and base courses, and aggregate pavement shoulders.
  - 2. Section 321373 "Concrete Paving Joint Sealants" for joint sealants and fillers at pavement terminations.

#### 1.3 UNIT PRICES

A. Work of this Section is affected by RFP Unit Price .

#### 1.4 PREINSTALLATION MEETINGS

#### 1.5 ACTION SUBMITTALS

- A. Product Data: For each type of product.
  - 1. Include technical data and tested physical and performance properties.
  - 2. Job-Mix Designs: Certification, by authorities having jurisdiction, of approval of each job mix proposed for the Work.
  - 3. Job-Mix Designs: For each job mix proposed for the Work.
- B. Samples for Verification: For the following product, in manufacturer's standard sizes unless otherwise indicated:
  - 1. 3/8" Crushed Stone .25 cubic feet minimum.



#### 1.6 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For manufacturer and testing agency.
- B. Material Certificates: For each paving material. Include statement that mixes containing recycled materials will perform equal to mixes produced from all new materials.

### 1.7 QUALITY ASSURANCE

- A. Manufacturer Qualifications: A paving-mix manufacturer registered with and approved by authorities having jurisdiction or the DOT of state in which Project is located .
- B. Testing Agency Qualifications: Qualified according to ASTM D 3666 for testing indicated.

## 1.8 FIELD CONDITIONS

- A. Environmental Limitations: Do not apply asphalt materials if subgrade is wet or excessively damp, if rain is imminent or expected before time required for adequate cure, or if the following conditions are not met:
  - 1. Tack Coat: Minimum surface temperature of 60 deg F.
  - 2. Asphalt Base Course: Minimum surface temperature of 40 deg F and rising at time of placement.
  - 3. Asphalt Surface Course: Minimum surface temperature of 60 deg F at time of placement.

#### PART 2 - PRODUCTS

#### 2.1 AGGREGATES

- A. General: Use materials and gradations that have performed satisfactorily in previous installations.
- B. Coarse Aggregate: ASTM D 692/D 692M, sound; angular crushed stone, crushed gravel, or cured, crushed blast-furnace slag.
- C. Fine Aggregate: ASTM D 1073 [or], sharp-edged natural sand or sand prepared from stone, gravel, cured blast-furnace slag, or combinations thereof.
  - 1. For hot-mix asphalt, limit natural sand to a maximum of 20 percent by weight of the total aggregate mass.
- D. Mineral Filler: ASTM D 242/D 242M [or], rock or slag dust, hydraulic cement, or other inert material.
- E. B. Cover Aggregate: Sieve Designation Percentage By Weight Passing 3/8" 100 #4 85-100 #8 0-25#200 0-2



# 2.2 ASPHALT MATERIALS

- A. Emulsified Asphalt Prime Coat: ASTM D 977 [or] emulsified asphalt, or ASTM D 2397/D 2397M [or] cationic emulsified asphalt, slow setting, diluted in water, of suitable grade and consistency for application.
- B. Water: Potable.

## PART 3 - EXECUTION

## 3.1 EXAMINATION

- A. Verify that subgrade is dry and in suitable condition to begin paving.
- B. Proceed with paving only after unsatisfactory conditions have been corrected.

## 3.2 PREPARATION

A. Protection: Provide protective materials, procedures, and worker training to prevent asphalt materials from spilling, coating, or building up on curbs, driveway aprons, manholes, and other surfaces adjacent to the Work.

#### 3.3 SURFACE PREPARATION

- A. Immediately before placing asphalt materials, remove loose and deleterious material from substrate surfaces. Ensure that prepared subgrade is ready to receive paving.
- B. Cutback Prime Coat: Apply uniformly over surface of compacted unbound-aggregate base course at a rate of 0.15 to 0.50 gal./sq. yd. Apply enough material to penetrate and seal, but not flood, surface. Allow prime coat to cure.
  - 1. If prime coat is not entirely absorbed within 24 hours after application, spread sand over surface to blot excess asphalt. Use enough sand to prevent pickup under traffic. Remove loose sand by sweeping before pavement is placed and after volatiles have evaporated.
  - 2. Protect primed substrate from damage until ready to receive paving.

# 3.4 PLACING HOT-MIX ASPHALT

- A. Machine place hot-mix asphalt on prepared surface, spread uniformly, and strike off. Place asphalt mix by hand in areas inaccessible to equipment in a manner that prevents segregation of mix. Place each course to required grade, cross section, and thickness when compacted.
  - 1. Place hot-mix asphalt base course in number of lifts and thicknesses indicated.
  - 2. Place hot-mix asphalt surface course in single lift.
  - 3. Spread mix at a minimum temperature of 250 deg F.



- 4. Begin applying mix along centerline of crown for crowned sections and on high side of one-way slopes unless otherwise indicated.
- 5. Regulate paver machine speed to obtain smooth, continuous surface free of pulls and tears in asphalt-paving mat.
- B. Place paving in consecutive strips not less than 12 feet wide unless infill edge strips of a lesser width are required.
  - 1. After first strip has been placed and rolled, place succeeding strips and extend rolling to overlap previous strips. Overlap mix placement about 1 to 1-1/2 inches from strip to strip to ensure proper compaction of mix along longitudinal joints.
  - 2. Complete a section of asphalt base course before placing asphalt surface course.
- C. Promptly correct surface irregularities in paving course behind paver. Use suitable hand tools to remove excess material forming high spots. Fill depressions with hot-mix asphalt to prevent segregation of mix; use suitable hand tools to smooth surface.

## 3.5 COMPACTION

- A. General: Begin compaction as soon as placed hot-mix paving will bear roller weight without excessive displacement. Compact hot-mix paving with hot, hand tampers or with vibratory-plate compactors in areas inaccessible to rollers.
  - 1. Complete compaction before mix temperature cools to 185 deg F.
- B. Breakdown Rolling: Complete breakdown or initial rolling immediately after rolling joints and outside edge. Examine surface immediately after breakdown rolling for indicated crown, grade, and smoothness. Correct laydown and rolling operations to comply with requirements.
- C. Intermediate Rolling: Begin intermediate rolling immediately after breakdown rolling while hot-mix asphalt is still hot enough to achieve specified density. Continue rolling until hot-mix asphalt course has been uniformly compacted to the following density:
  - 1. Average Density: 96 percent of reference laboratory density according to ASTM D 6927 or , but not less than 94 percent or greater than 100 percent.
  - 2. Average Density: 92 percent of reference maximum theoretical density according to ASTM D 2041/D 2041M, but not less than 90 percent or greater than 96 percent.
- D. Finish Rolling: Finish roll paved surfaces to remove roller marks while hot-mix asphalt is still warm.
- E. Edge Shaping: While surface is being compacted and finished, trim edges of pavement to proper alignment. Bevel edges while asphalt is still hot; compact thoroughly.
- F. Repairs: Remove paved areas that are defective or contaminated with foreign materials and replace with fresh, hot-mix asphalt. Compact by rolling to specified density and surface smoothness.



- G. Protection: After final rolling, do not permit vehicular traffic on pavement until it has cooled and hardened.
- H. Erect barricades to protect paving from traffic until mixture has cooled enough not to become marked.

#### 3.6 INSTALLATION TOLERANCES

- A. Pavement Thickness: Compact each course to produce the thickness indicated within the following tolerances:
  - 1. Base Course: Plus or minus 1/2 inch.
  - 2. Surface Course: Plus 1/4 inch, no minus.
- B. Pavement Surface Smoothness: Compact each course to produce a surface smoothness within the following tolerances as determined by using a 10-foot straightedge applied transversely or longitudinally to paved areas:
  - 1. Base Course: 1/2 inch
  - 2. Surface Course: Plus 1/4 inch, no minus.

#### 3.7 SURFACE TREATMENTS

- A. Preparation and Application of Cover Aggregate:
  - 1. Cover material shall be sufficiently dried when it comes in contact with bituminous material so that a satisfactory bond or coating is obtained.
  - 2. When the hot-mix asphalt has sufficiently cured, the asphalt for the surface coat shall be applied to the surface. Immediately following this application of bituminous material, the cover aggregate shall be uniformly spread over the surface with an approved mechanical spreader at a rate of twenty (20) to thirty (30) pounds per square yard. Cover material shall be applied continuously and without delay until the particular application is covered. Whenever possible successive strips shall be applied before the previous strip has cooled. Cover material shall not be spread on the six inches (6") adjacent to an unprotected edge until the next strip of bituminous material has been applied. Rolling shall immediately follow the application of each coat of cover aggregate and shall continue until the surface is accepted as determined by the Engineer.
  - 3. When all possible aggregate has been imbedded in the bituminous material on each course, the Contractor shall sweep each course surface of all excess material and remove it to a designated area, unless otherwise directed.

### 3.8 FIELD QUALITY CONTROL

A. Thickness: In-place compacted thickness of hot-mix asphalt courses will be determined according to ASTM D 3549/D 3549M.



B. Remove and replace or install additional hot-mix asphalt where test results or measurements indicate that it does not comply with specified requirements.

# 3.9 WASTE HANDLING

A. General: Handle asphalt-paving waste according to approved waste management plan required in Section 01000 General Requirements.

# END OF SECTION 321216



## SECTION 321313 - CONCRETE PAVING

### PART 1 - GENERAL

### 1.1 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes Concrete Paving Including the Following:
  - 1. Pads for Benches & Trash Receptacles.
- B. Related Requirements:
  - 1. Section 033000 "Cast-in-Place Concrete" for general building applications of concrete.

#### 1.3 DEFINITIONS

- A. Cementitious Materials: Portland cement alone or in combination with one or more of blended hydraulic cement, fly ash, slag cement, and other pozzolans.
- B. W/C Ratio: The ratio by weight of water to cementitious materials.

#### 1.4 PREINSTALLATION MEETINGS

#### 1.5 ACTION SUBMITTALS

- A. Product Data: For each type of product.
- B. Design Mixtures: For each concrete paving mixture. Include alternate design mixtures when characteristics of materials, Project conditions, weather, test results, or other circumstances warrant adjustments.

#### 1.6 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For qualified ready-mix concrete manufacturer .
- B. Material Certificates: For the following, from manufacturer:
  - 1. Cementitious materials.

#### 321313 - 1

Copyright © 2021 by the American Institute of Architects. Warning: This AIA MasterSpec-based document is protected by U.S. Copyright Law and International Treaties. It was created by "Providence Parks Dept" for "Blackstone Boulevard Path Improvements 2021". A valid, current MasterSpec license is required for editing and use of this document for any other project.(16521)



- 2. Steel reinforcement and reinforcement accessories.
- 3. Fiber reinforcement.
- 4. Admixtures.
- 5. Curing compounds.
- 6. Applied finish materials.
- 7. Bonding agent or epoxy adhesive.
- C. Material Test Reports: For each of the following:
  - 1. Aggregates: Include service-record data indicating absence of deleterious expansion of concrete due to alkali-aggregate reactivity.

## 1.7 QUALITY ASSURANCE

- A. Ready-Mix-Concrete Manufacturer Qualifications: A firm experienced in manufacturing readymixed concrete products and that complies with ASTM C 94/C 94M requirements for production facilities and equipment.
  - 1. Manufacturer certified according to NRMCA's "Certification of Ready Mixed Concrete Production Facilities" (Quality Control Manual - Section 3, "Plant Certification Checklist").

## 1.8 PRECONSTRUCTION TESTING

#### 1.9 FIELD CONDITIONS

- A. Traffic Control: Maintain access for vehicular and pedestrian traffic as required for other construction activities.
- B. Cold-Weather Concrete Placement: Protect concrete work from physical damage or reduced strength that could be caused by frost, freezing, or low temperatures. Comply with ACI 306.1 and the following:
  - 1. When air temperature has fallen to or is expected to fall below 40 deg F, uniformly heat water and aggregates before mixing to obtain a concrete mixture temperature of not less than 50 deg F and not more than 80 deg F at point of placement.
  - 2. Do not use frozen materials or materials containing ice or snow.
  - 3. Do not use calcium chloride, salt, or other materials containing antifreeze agents or chemical accelerators unless otherwise specified and approved in design mixtures.
- C. Hot-Weather Concrete Placement: Comply with ACI 301 and as follows when hot-weather conditions exist:
  - 1. Cool ingredients before mixing to maintain concrete temperature below 90 deg F at time of placement. Chilled mixing water or chopped ice may be used to control temperature, provided water equivalent of ice is calculated in total amount of mixing water. Using liquid nitrogen to cool concrete is Contractor's option.



PART 2 - PRODUCTS

# 2.1 CONCRETE, GENERAL

A. ACI Publications: Comply with ACI 301 unless otherwise indicated.

# 2.2 FORMS

- A. Form Materials: Plywood, metal, metal-framed plywood, or other approved panel-type materials to provide full-depth, continuous, straight, and smooth exposed surfaces.
- B. Form-Release Agent: Commercially formulated form-release agent that will not bond with, stain, or adversely affect concrete surfaces and that will not impair subsequent treatments of concrete surfaces.

# 2.3 CONCRETE MATERIALS

- A. Cementitious Materials: Use the following cementitious materials, of same type, brand, and source throughout Project:
  - 1. Portland Cement: ASTM C 150/C 150M, gray portland cement Type I.
- B. Normal-Weight Aggregates: ASTM C 33/C 33M, Class 4M uniformly graded. Provide aggregates from a single source with documented service-record data of at least 10 years' satisfactory service in similar paving applications and service conditions using similar aggregates and cementitious materials.
  - 1. Maximum Coarse-Aggregate Size: 3/4 inch nominal.
  - 2. Fine Aggregate: Free of materials with deleterious reactivity to alkali in cement.
- C. Chemical Admixtures: Admixtures certified by manufacturer to be compatible with other admixtures and to contain not more than 0.1 percent water-soluble chloride ions by mass of cementitious material.
  - 1. High-Range, Water-Reducing Admixture: ASTM C 494/C 494M, Type A.
- D. Water: Potable and complying with ASTM C 94/C 94M.

# 2.4 FIBER REINFORCEMENT

- A. Synthetic Fiber: Monofilament polypropylene fibers engineered and designed for use in decorative concrete paving, complying with ASTM C 1116/C 1116M, Type III, 1/2 to 1-1/2 inches long.
- B. GFRC Glass Fiber: 200-400 individual glass filaments which are lightly bonded to make up a stand



# 2.5 CURING MATERIALS

- A. Absorptive Cover: AASHTO M 182, Class 3, burlap cloth made from jute or kenaf, weighing approximately 9 oz./sq. yd. dry or cotton mats.
- B. Moisture-Retaining Cover: ASTM C 171, polyethylene film or white burlap-polyethylene sheet.
- C. Water: Potable.

# 2.6 CONCRETE MIXTURES

- A. Prepare design mixtures, proportioned according to ACI 301, for each type and strength of normal-weight concrete, and as determined by either laboratory trial mixtures or field experience.
  - 1. Use a qualified independent testing agency for preparing and reporting proposed concrete design mixtures for the trial batch method.
  - 2. When automatic machine placement is used, determine design mixtures and obtain laboratory test results that comply with or exceed requirements.
- B. Cementitious Materials: Use fly ash, pozzolan, slag cement, and silica fume as needed to reduce the total amount of portland cement, which would otherwise be used, by not less than 40 percent.
  - 1. Fly Ash or Pozzolan: 22 percent.
- C. Add air-entraining admixture at manufacturer's prescribed rate to result in normal-weight concrete at point of placement having an air content as follows:
  - 1. Air Content: 5 percent plus or minus 1-1/2 percent for 3/4-inch nominal maximum aggregate size.
- D. Limit water-soluble, chloride-ion content in hardened concrete to 0.15 percent by weight of cement.
- E. Chemical Admixtures: Use admixtures according to manufacturer's written instructions.
  - 1. Use in concrete as required for placement and workability.
- F. Synthetic Fiber: Uniformly disperse in concrete mixture at manufacturer's recommended rate, but not less than 1.5 lb/cu. yd.
- G. Concrete Mixtures: Normal-weight concrete.
  - 1. Compressive Strength (28 Days): 4000 psi
  - 2. Maximum W/C Ratio at Point of Placement: 0.45.
  - 3. Slump Limit: **4 inches** plus or minus **1 inch**.

Copyright © 2021 by the American Institute of Architects. Warning: This AIA MasterSpec-based document is protected by U.S. Copyright Law and International Treaties. It was created by "Providence Parks Dept" for "Blackstone Boulevard Path Improvements 2021". A valid, current MasterSpec license is required for editing and use of this document for any other project.(16521)

#### 321313 - 4



## 2.7 CONCRETE MIXING

- A. Project-Site Mixing: Measure, batch, and mix concrete materials and concrete according to ASTM C 94/C 94M. Mix concrete materials in appropriate drum-type batch machine mixer.
  - 1. For concrete batches of 1 cu. yd. or smaller, continue mixing at least 1-1/2 minutes, but not more than 5 minutes after ingredients are in mixer, before any part of batch is released.
  - 2. For concrete batches larger than 1 cu. yd., increase mixing time by 15 seconds for each additional 1 cu. yd..
  - 3. Provide batch ticket for each batch discharged and used in the Work, indicating Project identification name and number, date, mixture type, mixing time, quantity, and amount of water added.

# PART 3 - EXECUTION

## 3.1 EXAMINATION

- A. Examine exposed subgrades and subbase surfaces for compliance with requirements for dimensional, grading, and elevation tolerances.
- B. Proof-roll prepared subbase surface below **concrete paving** to identify soft pockets and areas of excess yielding.
  - 1. Completely proof-roll subbase in one direction and repeat in perpendicular direction. Limit vehicle speed to 3 mph.
  - 2. Proof-roll with a pneumatic-tired and loaded, 10-wheel, tandem-axle dump truck weighing not less than 15 tons.
  - 3. Correct subbase with soft spots and areas of pumping or rutting exceeding depth of 1/2 inch according to requirements in Section 312000 "Earth Moving."
- C. Proceed with installation only after unsatisfactory conditions have been corrected.

# 3.2 PREPARATION

A. Remove loose material from compacted subbase surface immediately before placing concrete.

# 3.3 EDGE FORMS AND SCREED CONSTRUCTION

- A. Set, brace, and secure edge forms, bulkheads, and intermediate screed guides to required lines, grades, and elevations. Install forms to allow continuous progress of work and so forms can remain in place at least 24 hours after concrete placement.
- B. Clean forms after each use and coat with form-release agent to ensure separation from concrete without damage.



## 3.4 JOINTS

- A. General: Form construction, isolation, and contraction joints and tool edges true to line, with faces perpendicular to surface plane of concrete. Construct transverse joints at right angles to centerline unless otherwise indicated.
- B. Construction Joints: Set construction joints at side and end terminations of paving and at locations where paving operations are stopped for more than one-half hour unless paving terminates at isolation joints.
- C. Edging: After initial floating, tool edges of paving, and joints in concrete with an edging tool to a **1/4-inch** radius. Repeat tooling of edges after applying surface finishes. Eliminate edging-tool marks on concrete surfaces.

## 3.5 CONCRETE PLACEMENT

- A. Before placing concrete, inspect and complete formwork installation and items to be embedded or cast-in.
- B. Remove snow, ice, or frost from subbase surface before placing concrete. Do not place concrete on frozen surfaces.
- C. Moisten subbase to provide a uniform dampened condition at time concrete is placed. Do not place concrete around manholes or other structures until they are at required finish elevation and alignment.
- D. Comply with ACI 301 requirements for measuring, mixing, transporting, and placing concrete.
- E. Do not add water to concrete during delivery or at Project site. Do not add water to fresh concrete after testing.
- F. Deposit and spread concrete in a continuous operation between transverse joints. Do not push or drag concrete into place or use vibrators to move concrete into place.
- G. Consolidate concrete according to ACI 301 by mechanical vibrating equipment supplemented by hand spading, rodding, or tamping.
- H. Screed paving surface with a straightedge and strike off.
- I. Commence initial floating using bull floats or darbies to impart an open-textured and uniform surface plane before excess moisture or bleedwater appears on the surface. Do not further disturb concrete surfaces before beginning finishing operations or spreading surface treatments.

#### 3.6 FLOAT FINISHING

A. General: Do not add water to concrete surfaces during finishing operations.



- B. Float Finish: Begin the second floating operation when bleedwater sheen has disappeared and concrete surface has stiffened sufficiently to permit operations. Float surface with power-driven floats or by hand floating if area is small or inaccessible to power units. Finish surfaces to true planes. Cut down high spots and fill low spots. Refloat surface immediately to uniform granular texture.
  - 1. Medium-to-Coarse-Textured Broom Finish: Provide a coarse finish by striating floatfinished concrete surface 1/16 to 1/8 inch deep with a stiff-bristled broom, perpendicular to line of traffic.

# 3.7 SPECIAL FINISHES

# 3.8 CONCRETE PROTECTION AND CURING

- A. General: Protect freshly placed concrete from premature drying and excessive cold or hot temperatures.
- B. Comply with ACI 306.1 for cold-weather protection.
- C. Evaporation Retarder: Apply evaporation retarder to concrete surfaces if hot, dry, or windy conditions cause moisture loss approaching 0.2 lb/sq. ft. x h before and during finishing operations. Apply according to manufacturer's written instructions after placing, screeding, and bull floating or darbying concrete but before float finishing.
- D. Begin curing after finishing concrete but not before free water has disappeared from concrete surface.
- E. Curing Methods: Cure concrete by moisture-retaining-cover curing curing compound [or] [a combination of these] as follows:
  - 1. Moisture-Retaining-Cover Curing: Cover concrete surfaces with moisture-retaining cover, placed in widest practicable width, with sides and ends lapped at least 12 inches, and sealed by waterproof tape or adhesive. Immediately repair any holes or tears occurring during installation or curing period, using cover material and waterproof tape.
  - 2. Curing Compound: Apply uniformly in continuous operation by power spray or roller according to manufacturer's written instructions. Recoat areas subjected to heavy rainfall within three hours after initial application. Maintain continuity of coating, and repair damage during curing period.

#### 3.9 PAVING TOLERANCES

- A. Comply with tolerances in ACI 117 and as follows:
  - 1. Elevation: 1/4 inch.
  - 2. Thickness: Plus 3/8 inch, minus 1/4 inch.
  - 3. Surface: Gap below 10-feet- long; unleveled straightedge not to exceed 1/2 inch.
  - 4. Joint Spacing: 3 inches.

#### 321313 - 7

Copyright © 2021 by the American Institute of Architects. Warning: This AIA MasterSpec-based document is protected by U.S. Copyright Law and International Treaties. It was created by "Providence Parks Dept" for "Blackstone Boulevard Path Improvements 2021". A valid, current MasterSpec license is required for editing and use of this document for any other project.(16521)



- 5. Contraction Joint Depth: Plus 1/4 inch, no minus.
- 6. Joint Width: Plus 1/8 inch, no minus.

# 3.10 REPAIR AND PROTECTION

- A. Remove and replace concrete paving that is broken, damaged, or defective or that does not comply with requirements in this Section. Remove work in complete sections from joint to joint unless otherwise approved by Architect.
- B. Drill test cores, where directed by Architect, when necessary to determine magnitude of cracks or defective areas. Fill drilled core holes in satisfactory paving areas with portland cement concrete bonded to paving with epoxy adhesive.
- C. Protect concrete paving from damage. Exclude traffic from paving for at least 14 days after placement. When construction traffic is permitted, maintain paving as clean as possible by removing surface stains and spillage of materials as they occur.
- D. Maintain concrete paving free of stains, discoloration, dirt, and other foreign material. Sweep paving not more than two days before date scheduled for Substantial Completion inspections.

END OF SECTION 321313



## SECTION 321320 - STONE DUST WALK

## PART 1 - PART I - GENERAL

#### 1.1 SUMMARY

- A. This work consists of providing the following items:
  - 1. Earthwork
  - 2. Stone dust walk.
  - 3. Gravel base
  - 4. Geotextile filter fabric

### 1.2 SYSTEM DESCRIPTION

A. A.Installation of stone dust walk as shown on the drawings.

# PART 2 - PART 2 - PRODUCT

#### 2.1 MATERIALS

A. Stone Dust: 1/4" Processed Bluestone Dust:

Sieve Size	Percent Passing By Weight
1/4"	100
#10	50-85
#40	20-45
#200	3-10

- B. Base Course: Washed 3/4" Gravel.
- C. Filter Fabric: Filter Fabric to be 6 oz. needle punch non-woven fabric meeting the following:
  - 1. Grab Tensile (lbs): 160, Test method ASTM D-4632
  - 2. Elongation (%): 50, Test Method ASTM D-4632
  - 3. Trapezoid Tear (lbs): 65, Test Method ASTM D-4533
  - 4. Puncture Resistance (lbs): 90, Test Method ASTM D-4833
  - 5. Permittivity (sec-1): 1.6, Test Method ASTM D-4491
  - 6. Flow  $(\text{gpm/ft}^2)$ : 110, Test Method ASTM D-4491
  - 7. A.O.S. (U.S. sieve no.): 70, Test Method ASTM D-4751
  - 8. Ultra Violet Stability: 70, Test Method ASTM D-4355
  - 9. Strength Retained %: 500 hours
  - 10. Weight (oz/yd<sup>2</sup>): 6, Test Method ASTM D-5261

Copyright © 2021 by the American Institute of Architects. Warning: This AIA MasterSpec-based document is protected by U.S. Copyright Law and International Treaties. It was created by "Providence Parks Dept" for "Blackstone Boulevard Path Improvements 2021". A valid, current MasterSpec license is required for editing and use of this document for any other project.(16521)

#### 321320 - 1



PART 3 - PART 3 - EXECUTION

## 3.1 PREPARATION

- A. Excavate the ground to NO DEEPER THAN 10" and grade out irregularities to form the walk at the lines and depths indicated on the drawings.
- B. Excavated area should be rectangular in section with vertical sides and level base.
- C. Stripped vegetation and excavated topsoil to be stockpiled or removed from site.
- D. If soft spots are present, excavate the area until the sub grade is stable.
- E. Fill excess w scalpings, crusher run or crushed demolition waste to formation level and compact to refusal.

## 3.2 INSTALLATION

- A. Filter Fabric:
  - 1. Lay and secure filter fabric over compacted subbase. Fabric sheet should line the base and both sides. Overlap joining sheets by 3 feet.
- B. Base:
  - 1. Using a drag box lay 6-inch depth of granular sub base upon the filter fabric sheet to falls and levels, to form 2" Crown in center of walk.. If no drag box is available, granular sub base should be laid, spread and raked to required falls and levels using asphalt rake.
  - 2. Compact sub base layer thoroughly to refusal using a heavy ride-on tandem vibrating roller until full compaction is achieved (minimum 120 type roller recommended).
  - 3. Once base layer is compacted, check levels of the surface at regular intervals along the compacted sub base layer for consistent even surface regularity, which should be accurate to maximum gap of 1/4"-inch under a 3-foot long straight edge, with no high or low points or hollows.
  - 4. Any part of the sub base layer deviating from the required level must be raked off or topped up with additional granular sub base and re-compacted to the correct levels.
  - 5. Check the finished compacted sub base layer is closed tightly with no exposed surface voids before laying the surface layer. If necessary, fill any voids with 6mm quarry granite dust.
- C. Stone Dust Surface
  - 1. Using drag box lay specified depth of quarry granite dust to falls and levels, to form width of walk surface.
  - 2. Provide 2" Crown along the center line of compacted sub base layer.
  - 3. If no drag box is available, 1/4" quarry granite dust should be laid, spread and raked to falls and levels using asphalt rake.



- 4. Compact surface layer thoroughly to refusal using a heavy ride-on tandem vibrating roller and continue rolling non-stop until there is no roller marks in the finished surface (minimum 120 type roller recommended).
- 5. Once rolling is finished, check levels of the surface at regular intervals along the compacted surface layer for consistent even surface regularity, which should be accurate to maximum gap of <sup>1</sup>/<sub>4</sub>-inch under a 3-foot long straight edge, with no high or low points or hollows.
- 6. Any part of the surface layer deviating from the required level must be raked off or topped up with additional 6mm quarry granite dust and re- compacted to the correct levels.

### D. FINISHING

- 1. Grade areas on both sides of walk to lines shown on drawings
- 2. Ensure that lawn areas are level with walk surface using available topsoil and turfs to cover walk base edges and to support walk surface edges.
- 3. Install lawn as per specification Section Turfs and Grasses.
- 4. Landscaped edges should be finished level with walk surface and taper down and away from the walk surface to allow surface water to run off unimpeded.

END OF SECTION 321320



SECTION 321540 - ORGANIC-LOCK FOR STABILIZED PATHWAY AGGREGATE: FOOT TRAFFIC

## PART 1 - GENERAL

#### 1.1 SUMMARY

A. This section includes materials and execution information for construction with aggregate with Organic-Lock binder for foot traffic applications

#### 1.2 REFERENCES

- A. ASTM C136 / C136M 14, Standard Test Method for Sieve Analysis of Fine and Coarse Aggregates, ASTM International, West Conshohocken, PA, 2014, www.astm.org
- B. ASTM D2419 14, Standard Test Method for Sand Equivalent Value of Soils and Fine Aggregates, ASTM International, West Conshohocken, PA, 2014, www.astm.org
- C. C.ASTM F1951 14, Standard Specification for Determination of Accessibility of Surface Systems Under and Around Playground Equipment, ASTM International, West Conshohocken, PA, 2014, www.astm.org

#### 1.3 SUBMITTALS

- A. Submit in accordance with Section 013300 Submittal Procedures:
  - 1. Manufacturer's product data sheet.
  - 2. 1 quart sample of base course.
  - 3. Base Course gradation indicating that the product meets specifications
  - 4. 1 quart sample of stabilized crushed aggregate paving.
  - 5. Stabilized crushed aggregate gradation indicating that the product meets specifications.
  - 6. Manufacturer's Material Safety Data Sheet.

#### 1.4 SITE CONDITIONS

- A. Ensure that the subgrade and base are properly graded and compacted to required specifications.
- B. Do not install the Organic-Lock pathway aggregate during rain. Rain within 3-5 days after installation will increase curing time.
- C. Protect all nearby surfaces, plants, and structures from possible contamination from materials or damage by equipment.



### 1.5 TEST PLOT

- A. Install 20 square feet minimum of stabilized crushed aggregate paving including base course, at location approved by Owner's Representative.
- B. Allow Owner's Representative to view test plot before proceeding with rest of stabilized crushed aggregate paving.
- C. Approved mock-up may remain as part of completed Work

## 1.6 DELIVERY, HANDLING, AND STORAGE

- A. Delivery:
  - 1. Delivery of Organic-Lock is available from the manufacturer or select Organic-Lock dealers. Please contact the manufacturer for more information.
  - 2. Delivery of Organic-Lock pre-blended with aggregate is available from select dealers. Contact your closest dealer or the manufacturer for more information.
- B. Handling:
  - 1. Wear appropriate respirator when ventilation is inadequate. Avoid contact with skin and eyes.
- C. Storage:
  - 1. Protect stabilized crushed aggregate mix from contamination. Store under cover.

# PART 2 - PRODUCTS

#### 2.1 MANUFACTURERS

- A. Organic-Lock for Organic-Lock stabilized pathway aggregate provided by:
  - 1. Envirobond Products Corporation, 6191-2100 Bloor Street West Toronto, Ontario, Canada, M6S 5A5. 1-866-636-8476, info@envirobond.com, www.envirobond.com, www.organic-lock.com.
- 2.2 Crushed Aggregate Materials:
  - A. Crushed Aggregate Material shall consist of sound, angular, durable particles.
  - B. Gradation, in accordance with ASTM C136.
  - C. Organic-Lock Binder

#### 321540 - 2

Copyright © 2021 by the American Institute of Architects. Warning: This AIA MasterSpec-based document is protected by U.S. Copyright Law and International Treaties. It was created by "Providence Parks Dept" for "Blackstone Boulevard Path Improvements 2021". A valid, current MasterSpec license is required for editing and use of this document for any other project.(16521)



- 1. Patented powdered organic binder designed to be blended with crushed aggregate
- 2. Made from 100% naturally occurring materials

### PART 3 - EXECUTION

### 3.1 PREPARATION

- A. Prepare the Subgrade
  - 1. Excavate the area to the depth required so that finish grade can be established as noted on plans.
  - 2. A Foot-Traffic Pathway will require a full depth of 7-9 inches: 4-6 inches of compacted base depth together with 3 inches of compacted Organic-Lock Pathway Aggregate.
  - 3. Compact the subgrade to 95% Modified Proctor Density.
- B. Prepare the Base
  - 1. Spread the base material to approved depth. Crushed, granular road base such as 3/4" minus is an optimal base material.
  - 2. Foot-Traffic Pathway will require 4-6 inches of compacted base material.
  - 3. Depending upon the method of compaction the installation of base material may require separate lifts.
  - 4. Note: Vibratory compaction is only acceptable for the base material, Organic- Lock Pathway Aggregate must be compacted with a single or double drum static roller.
  - 5. Compact the subgrade to 95% Modified Proctor Density.

#### 3.2 WATERSHED MANAGEMENT

- A. Crowns and/or cross-slopes must be incorporated into the compacted base material.
- B. If the slope is 2% or lower, a crown should be incorporated into the pathway. If the slope is greater than 2%, incorporate a cross-slope.
- C. Note: The addition of crowns and cross-slopes is heavily dependent upon surrounding watershed.

#### 3.3 SPREADING

- A. The use of a paving machine is highly recommended for large projects to evenly spread Organic-Lock Pathway Aggregate at the specified depth
- B. Spread the loose and uncompacted Organic-Lock Pathway Aggregate over the compacted base material.



C. Typically, a lift of 4 inches of loose, pre-wet Organic-Lock Pathway Aggregate will compact to the required 3 inch depth for Foot-Traffic Pathways.

### 3.4 COMPACTION

- A. Make 4-6 passes using a 1 ton double or single static drum roller, or equivalent. A Foot-Traffic Pathway will typically require one lift, compacted to 3 inches.
- B. Compaction will vary with different aggregates due to particle shape and size. Compact to 95% Modified Proctor Density.

## 3.5 COMPLETING INSTALLATION

- A. Apply a light spray to the surface of the material to give a clean appearance. Apply water until the water begins to run-off.
- B. Do not allow any traffic on the newly installed pathway until fully cured

## 3.6 3.7 REPAIRS AND PROTECTION

- A. Excavate the damaged area and scarify exposed Organic-Lock Pathway Aggregate.
- B. Pre-blend the replacement crushed stone aggregate material with Organic-Lock at 34 lbs/ imperial ton. Apply the material to the excavated area and compact.
- C. Thoroughly water the material to achieve a 8-10% moisture content, the use of a moisture probe is recommended.
- D. Allow the newly installed Organic-Lock Pathway Aggregate to cure, but not completely dry out.
- E. Re-compact the material, ensuring that the final grade and crown are maintained. Do not use a vibratory compactor.

#### END OF SECTION 321540



SECTION 329113 - SOIL PREPARATION

## PART 4 - GENERAL

### 4.1 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 4.2 SUMMARY

- A. Section includes planting soils specified by composition of the mixes.
- B. Related Requirements:
  - 1. Section 329200 "Turf and Grasses" for placing planting soil for turf and grasses.

#### 4.3 ALLOWANCES

A. Preconstruction and field quality-control testing are part of testing and inspecting allowance.

#### 4.4 UNIT PRICES

A. Work of this Section is affected by cubic yard

#### 4.5 DEFINITIONS

- A. Backfill: The earth used to replace or the act of replacing earth in an excavation. This can be amended or unamended soil as indicated.
- B. CEC: Cation exchange capacity.
- C. Compost: The product resulting from the controlled biological decomposition of organic material that has been sanitized through the generation of heat and stabilized to the point that it is beneficial to plant growth.
- D. Imported Soil: Soil that is transported to Project site for use.
- E. Manufactured Soil: Soil produced by blending soils, sand, stabilized organic soil amendments, and other materials to produce planting soil.
- F. Organic Matter: The total of organic materials in soil exclusive of undecayed plant and animal tissues, their partial decomposition products, and the soil biomass; also called "humus" or "soil organic matter."

329119 - 1



- G. Planting Soil: Existing, on-site soil; imported soil; or manufactured soil that has been modified as specified with soil amendments and perhaps fertilizers to produce a soil mixture best for plant growth.
- H. RCRA Metals: Hazardous metals identified by the EPA under the Resource Conservation and Recovery Act.
- I. Subgrade: Surface or elevation of subsoil remaining after excavation is complete, or the top surface of a fill or backfill before planting soil is placed.
- J. Subsoil: Soil beneath the level of subgrade; soil beneath the topsoil layers of a naturally occurring soil profile, typified by less than 1 percent organic matter and few soil organisms.
- K. Surface Soil: Soil that is present at the top layer of the existing soil profile. In undisturbed areas, surface soil is typically called "topsoil"; but in disturbed areas such as urban environments, the surface soil can be subsoil.
- L. USCC: U.S. Composting Council.
- 4.6 PREINSTALLATION MEETINGS

# 4.7 ACTION SUBMITTALS

- A. Product Data: For each type of product.
  - 1. Include recommendations for application and use.
  - 2. Include test data substantiating that products comply with requirements.
  - 3. Include sieve analyses for aggregate materials.
  - 4. Material Certificates: For each type of soil amendment and fertilizer before delivery to the site, according to the following:
    - a. Manufacturer's qualified testing agency's certified analysis of standard products.
    - b. Analysis of fertilizers, by a qualified testing agency, made according to AAPFCO methods for testing and labeling and according to AAPFCO's SUIP #25.
    - c. Analysis of nonstandard materials, by a qualified testing agency, made according to SSSA methods, where applicable.

# 4.8 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For each testing agency.
- B. Preconstruction Test Reports: For preconstruction soil analyses specified in "Preconstruction Testing" Article.



## 4.9 QUALITY ASSURANCE

- A. Testing Agency Qualifications: An independent, state-operated, or university-operated laboratory; experienced in soil science, soil testing, and plant nutrition; with the experience and capability to conduct the testing indicated; and that specializes in types of tests to be performed.
  - 1. Laboratories: Subject to compliance with requirements, provide testing by the following :
    - a. UMass Soil & Plant Nutrient Testing Laboratory Paige Laboratory, Room 203 161 Holdsworth Way Amherst, MA 01003 (413)545-2311.
  - 2. Multiple Laboratories: At Contractor's option, work may be divided among qualified testing laboratories specializing in physical testing, chemical testing, and fertility testing.

## 4.10 PRECONSTRUCTION TESTING

- A. Preconstruction Testing Service: Engage a qualified testing agency to perform preconstruction soil analyses on existing, on-site soil imported soil.
  - 1. Notify Architect seven days in advance of the dates and times when laboratory samples will be taken.
- B. Preconstruction Soil Analyses: For each unamended soil type, perform testing on soil samples and furnish soil analysis and a written report containing soil-amendment and fertilizer recommendations by a qualified testing agency performing the testing according to "Soil-Sampling Requirements" and "Testing Requirements" articles.
  - 1. Have testing agency identify and label samples and test reports according to sample collection and labeling requirements.

#### 4.11 SOIL-SAMPLING REQUIREMENTS

- A. General: Extract soil samples according to requirements in this article.
- B. Sample Collection and Labeling: Have samples taken and labeled by Contractor in presence of Architect under the direction of the testing agency.
  - 1. Number and Location of Samples: Minimum of three representative soil samples from varied locations where directed by Architect for each soil to be used or amended for landscaping purposes.
  - 2. Procedures and Depth of Samples: as directed by testing laboratory
  - 3. Division of Samples: Split each sample into two, equal parts. Send half to the testing agency and half to Owner for its records.
  - 4. Labeling: Label each sample with the date, location keyed to a site plan or other location system, visible soil condition, and sampling depth.

#### 4.12 TESTING REQUIREMENTS

A. General: Perform tests on soil samples according to requirements in this article.

#### 329119 - 3

Do not remove: Copyright © 2021 by Deltek. Warning: This SpecText-based document is protected by U.S. Copyright Law and International Treaties. It was created by "Providence Parks Dept" for "Blackstone Boulevard Path Improvements 2021". A valid, current SpecText license from Deltek.com is required for editing or use of this document for any other project. (16521)


- B. Physical Testing:
  - 1. Soil Texture: Soil-particle, size-distribution analysis by one of the following methods according to SSSA's "Methods of Soil Analysis Part 1-Physical and Mineralogical Methods":
    - a. Sieving Method: Report sand-gradation percentages for very coarse, coarse, medium, fine, and very fine sand; and fragment-gradation (gravel) percentages for fine, medium, and coarse fragments; according to USDA sand and fragment sizes.
    - b. Hydrometer Method: Report percentages of sand, silt, and clay.
  - 2. Total Porosity: Calculate using particle density and bulk density according to SSSA's "Methods of Soil Analysis Part 1-Physical and Mineralogical Methods."
  - 3. Water Retention: According to SSSA's "Methods of Soil Analysis Part 1-Physical and Mineralogical Methods."
  - 4. Saturated Hydraulic Conductivity: According to SSSA's "Methods of Soil Analysis -Part 1-Physical and Mineralogical Methods"; at 85% compaction according to ASTM D 698 (Standard Proctor).
- C. Chemical Testing:
  - 1. CEC: Analysis by sodium saturation at pH7 according to SSSA's "Methods of Soil Analysis Part 3- Chemical Methods."
  - 2. Clay Mineralogy: Analysis and estimated percentage of expandable clay minerals using CEC by ammonium saturation at pH 7 according to SSSA's "Methods of Soil Analysis Part 1- Physical and Mineralogical Methods."
  - 3. Metals Hazardous to Human Health: Test for presence and quantities of RCRA metals including aluminum, arsenic, barium, copper, cadmium, chromium, cobalt, lead, lithium, and vanadium. If RCRA metals are present, include recommendations for corrective action.
  - 4. Phytotoxicity: Test for plant-available concentrations of phytotoxic minerals including aluminum, arsenic, barium, cadmium, chlorides, chromium, cobalt, copper, lead, lithium, mercury, nickel, selenium, silver, sodium, strontium, tin, titanium, vanadium, and zinc.
- D. Fertility Testing: Soil-fertility analysis according to standard laboratory protocol of [SSSA NAPT NEC-67], including the following:
  - 1. Percentage of organic matter.
  - 2. CEC, calcium percent of CEC, and magnesium percent of CEC.
  - 3. Soil reaction (acidity/alkalinity pH value).
  - 4. Buffered acidity or alkalinity.
  - 5. Nitrogen ppm.
  - 6. Phosphorous ppm.
  - 7. Potassium ppm.
  - 8. Manganese ppm.
  - 9. Manganese-availability ppm.
  - 10. Zinc ppm.
  - 11. Zinc availability ppm.
  - 12. Copper ppm.
  - 13. Sodium ppm and sodium absorption ratio.
  - 14. Soluble-salts ppm.



- 15. Presence and quantities of problem materials including salts and metals cited in the Standard protocol. If such problem materials are present, provide additional recommendations for corrective action.
- 16. Other deleterious materials, including their characteristics and content of each.
- E. Organic-Matter Content: Analysis using loss-by-ignition method according to SSSA's "Methods of Soil Analysis Part 3- Chemical Methods."
- F. Recommendations: Based on the test results, state recommendations for soil treatments and soil amendments to be incorporated to produce satisfactory planting soil suitable for healthy, viable plants indicated. Include, at a minimum, recommendations for nitrogen, phosphorous, and potassium fertilization, and for micronutrients.
  - 1. Fertilizers and Soil Amendment Rates: State recommendations in weight per 1000 sq. ft. for 6-inch depth of soil .
  - 2. Soil Reaction: State the recommended liming rates for raising pH or sulfur for lowering pH according to the buffered acidity or buffered alkalinity in weight per 1000 sq. ft. for 6-inch depth of soil .

#### 4.13 DELIVERY, STORAGE, AND HANDLING

- A. Packaged Materials: Deliver packaged materials in original, unopened containers showing weight, certified analysis, name and address of manufacturer, and compliance with state and Federal laws if applicable.
- B. Bulk Materials:
  - 1. Do not dump or store bulk materials near structures, utilities, walkways and pavements, or on existing turf areas or plants.
  - 2. Provide erosion-control measures to prevent erosion or displacement of bulk materials, discharge of soil-bearing water runoff, and airborne dust reaching adjacent properties, water conveyance systems, or walkways.
  - 3. Do not move or handle materials when they are wet or frozen.
  - 4. Accompany each delivery of bulk fertilizers and soil amendments with appropriate certificates.

#### PART 5 - PRODUCTS

5.1 MATERIALS

#### 5.2 ORGANIC SOIL AMENDMENTS

- A. Compost: Well-composted, stable, and weed-free organic matter produced by composting feedstock, and bearing USCC's "Seal of Testing Assurance," and as follows:
  - 1. Reaction: pH of 5.5 to 8.

Do not remove: Copyright © 2021 by Deltek. Warning: This SpecText-based document is protected by U.S. Copyright Law and International Treaties. It was created by "Providence Parks Dept" for "Blackstone Boulevard Path Improvements 2021". A valid, current SpecText license from Deltek.com is required for editing or use of this document for any other project. (16521)



- 2. Soluble-Salt Concentration: Less than 4 dS/m.
- 3. Moisture Content: 35 to 55 percent by weight.
- 4. Organic-Matter Content: 50 to 60 percent of dry weight.
- 5. Particle Size: Minimum of 98 percent passing through a 1/2-inch sieve.

#### PART 6 - EXECUTION

#### 6.1 GENERAL

- A. Place planting soil and fertilizers according to requirements in other Specification Sections.
- B. Verify that no foreign or deleterious material or liquid such as paint, paint washout, concrete slurry, concrete layers or chunks, cement, plaster, oils, gasoline, diesel fuel, paint thinner, turpentine, tar, roofing compound, or acid has been deposited in planting soil.
- C. Proceed with placement only after unsatisfactory conditions have been corrected.

#### 6.2 PLACING AND MIXING PLANTING SOIL OVER EXPOSED SUBGRADE

- A. General: Apply and mix unamended soil with amendments on-site to produce required planting soil. Do not apply materials or till if existing soil or subgrade is frozen, muddy, or excessively wet.
- B. Subgrade Preparation: Till subgrade to a minimum depth of 4 inches. Remove stones larger than 1-1/2 inches in any dimension and sticks, roots, rubbish, and other extraneous matter and legally dispose of them off Owner's property.
  - 1. Apply, add soil amendments, and mix approximately half the thickness of unamended soil over prepared, loosened subgrade according to "Mixing" Paragraph below. Mix thoroughly into top 2 inches 4 inches of subgrade. Spread remainder of planting soil.
- C. Mixing: Spread unamended soil to total depth indicated on Drawings, but not less than required to meet finish grades after mixing with amendments and natural settlement. Do not spread if soil or subgrade is frozen, muddy, or excessively wet.
  - 1. Amendments: Apply soil amendments and fertilizer, if required, evenly on surface, and thoroughly blend them with unamended soil to produce planting soil.
  - 2. Lifts: Apply and mix unamended soil and amendments in lifts not exceeding 8 inches in loose depth for material compacted by compaction equipment, and not more than 6 inches in loose depth for material compacted by hand-operated tampers.
- D. Compaction: Compact each blended lift of planting soil to 75 to 82 percent of maximum Standard Proctor density according to ASTM D 698 and tested in-place except where a different compaction value is indicated on Drawings.
- E. Finish Grading: Grade planting soil to a smooth, uniform surface plane with loose, uniformly fine texture. Roll and rake, remove ridges, and fill depressions to meet finish grades.

Do not remove: Copyright © 2021 by Deltek. Warning: This SpecText-based document is protected by U.S. Copyright Law and International Treaties. It was created by "Providence Parks Dept" for "Blackstone Boulevard Path Improvements 2021". A valid, current SpecText license from Deltek.com is required for editing or use of this document for any other project. (16521)



#### 6.3 FIELD QUALITY CONTROL

- A. Testing Agency: Engage a qualified testing agency to perform tests and inspections.
- B. Soil will be considered defective if it does not pass tests and inspections.
- C. Prepare test reports.
- D. Label each sample and test report with the date, location keyed to a site plan or other location system, visible conditions when and where sample was taken, and sampling depth.

#### 6.4 **PROTECTION**

- A. Protection Zone: Identify protection zones according to Section 015639 "Temporary Tree and Plant Protection."
- B. Protect areas of in-place soil from additional compaction, disturbance, and contamination. Prohibit the following practices within these areas except as required to perform planting operations:
  - 1. Storage of construction materials, debris, or excavated material.
  - 2. Parking vehicles or equipment.
  - 3. Vehicle traffic.
  - 4. Foot traffic.
  - 5. Erection of sheds or structures.
  - 6. Impoundment of water.
  - 7. Excavation or other digging unless otherwise indicated.
- C. If planting soil or subgrade is overcompacted, disturbed, or contaminated by foreign or deleterious materials or liquids, remove the planting soil and contamination; restore the subgrade as directed by Architect and replace contaminated planting soil with new planting soil.

#### 6.5 CLEANING

- A. Protect areas adjacent to planting-soil preparation and placement areas from contamination. Keep adjacent paving and construction clean and work area in an orderly condition.
- B. Remove surplus soil and waste material including excess subsoil, unsuitable materials, trash, and debris and legally dispose of them off Owner's property unless otherwise indicated.
  - 1. Dispose of excess subsoil and unsuitable materials on-site where directed by Owner.

END OF SECTION 329113



### SECTION 329119 - LANDSCAPE GRADING

#### PART 1 - GENERAL

#### 1.1 SUMMARY

- A. Section Includes:
  - 1. Final grade topsoil for finish landscaping.
- B. Related Sections:
  - 1. Section 312213 Rough Grading: Site contouring.
  - 2. Section 329113 Soil Preparation
  - 3. Section 329200 Turf and Grasses

#### 1.2 UNIT PRICE - MEASUREMENT AND PAYMENT

- A. Topsoil:
  - 1. Basis of Measurement: By Cubic Yard (CY) cubic yard
  - 2. Basis of Payment: Includes excavating existing topsoil, supplying topsoil materials, stockpiling, preparing and scarifying substrate surface, placing where required, and rolling.

#### 1.3 SUBMITTALS

- A. Section 013300 Submittal Procedures: Submittal procedures
- B. Samples: Submit, in air-tight containers, 1 Cup sample of Loam to testing laboratory.
- C. Materials Source: Submit name of imported materials source.

#### 1.4 QUALITY ASSURANCE

- A. Furnish each topsoil material from single source throughout the Work.
- B. Perform Work in accordance with RIDOT Standard Specifications for Road & Bridge Construction, latest edition.



## PART 2 - PRODUCTS

#### 2.1 MATERIAL

A. Topsoil: Fill Type S2 as specified in Section 329300.

#### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Section 010000 Administrative Requirements: Verification of existing conditions before starting work.
- B. Verify substrate base has been contoured and compacted.

#### 3.2 PREPARATION

- A. Protect landscaping and other features remaining as final Work.
- B. Protect existing structures, sidewalks, utilities, paving, and curbs.

### 3.3 SUBSTRATE PREPARATION

- A. Eliminate uneven areas and low spots.
- B. Remove debris, loose roots, branches, stones, in excess of 1/2 inch in size. Remove contaminated subsoil.
- C. Scarify surface to depth of 3 inches where topsoil is scheduled. Scarify in areas where equipment used for hauling and spreading topsoil has compacted subsoil.

#### 3.4 PLACING TOPSOIL

- A. Place topsoil in areas where seeding is required. to thickness as scheduled. Place topsoil during dry weather.
- B. Fine grade topsoil to eliminate rough or low areas. Maintain profiles and contour of subgrade.
- C. Remove roots, weeds, rocks, and foreign material while spreading.
- D. Manually spread topsoil close to plant material and path to prevent damage.
- E. Roll placed topsoil.
- F. Remove surplus subsoil and topsoil from site.

#### 329119 - 9

Do not remove: Copyright © 2021 by Deltek. Warning: This SpecText-based document is protected by U.S. Copyright Law and International Treaties. It was created by "Providence Parks Dept" for "Blackstone Boulevard Path Improvements 2021". A valid, current SpecText license from Deltek.com is required for editing or use of this document for any other project. (16521)



G. Leave stockpile area and site clean and raked, ready to receive landscaping.

#### 3.5 TOLERANCES

- A. Section 014000 Quality Requirements: Tolerances.
- B. Top of Topsoil: Plus or minus  $\frac{1}{2}$  inch.

### 3.6 PROTECTION OF INSTALLED WORK

- A. Section 017000 Execution and Closeout Requirements: Requirements for protecting finished Work.
- B. Prohibit construction traffic over topsoil.

#### 3.7 SCHEDULES

- A. Compacted topsoil thicknesses:
  - 1. Seeded Grass: 6 inches.

#### END OF SECTION 329119



SECTION 329200 - TURF AND GRASSES

PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:
  - 1. Seeding.
  - 2. Hydroseeding.
  - 3. Turf renovation.
- B. Related Requirements:
  - 1. Section 329300 "Plants" for trees, shrubs, ground covers, and other plants as well as border edgings and mow strips.

#### 1.3 DEFINITIONS

- A. Finish Grade: Elevation of finished surface of planting soil.
- B. Pesticide: A substance or mixture intended for preventing, destroying, repelling, or mitigating a pest. Pesticides include insecticides, miticides, herbicides, fungicides, rodenticides, and molluscicides. They also include substances or mixtures intended for use as a plant regulator, defoliant, or desiccant.
- C. Pests: Living organisms that occur where they are not desired or that cause damage to plants, animals, or people. Pests include insects, mites, grubs, mollusks (snails and slugs), rodents (gophers, moles, and mice), unwanted plants (weeds), fungi, bacteria, and viruses.
- D. Planting Soil: Existing, on-site soil; imported soil; or manufactured soil that has been modified with soil amendments and perhaps fertilizers to produce a soil mixture best for plant growth. See Section 329113 "Soil Preparation" and drawing designations for planting soils.
- E. Subgrade: The surface or elevation of subsoil remaining after excavation is complete, or the top surface of a fill or backfill before planting soil is placed.

#### 1.4 PREINSTALLATION MEETINGS

A. Preinstallation Conference: Conduct conference at Project site .

Copyright © 2021 by the American Institute of Architects. Warning: This AIA MasterSpec-based document is protected by U.S. Copyright Law and International Treaties. It was created by "Providence Parks Dept" for "Blackstone Boulevard Path Improvements 2021". A valid, current MasterSpec license is required for editing and use of this document for any other project.(16521)



#### 1.5 INFORMATIONAL SUBMITTALS

- A. Certification of Grass Seed: From seed vendor for each grass-seed monostand or mixture, stating the botanical and common name, percentage by weight of each species and variety, and percentage of purity, germination, and weed seed. Include the year of production and date of packaging.
- B. Product Certificates: For fertilizers, from manufacturer.

### 1.6 CLOSEOUT SUBMITTALS

A. Maintenance Data: Recommended procedures to be established by Owner for maintenance of turf during a calendar year. Submit before expiration of required maintenance periods.

#### 1.7 QUALITY ASSURANCE

- A. Installer Qualifications: A qualified landscape installer whose work has resulted in successful turf establishment.
  - 1. Professional Membership: Installer shall be a member in good standing of either the National Association of Landscape Professionals or AmericanHort.
  - 2. Experience: Five years' experience in turf installation in addition to requirements in Section 014000 "Quality Requirements."
  - 3. Installer's Field Supervision: Require Installer to maintain an experienced full-time supervisor on Project site when work is in progress.
  - 4. Personnel Certifications: Installer's field supervisor shall have certification in one of the following categories from the National Association of Landscape Professionals:
    - a. Landscape Industry Certified Technician Exterior.
    - b. Landscape Industry Certified Lawn Care Manager.
    - c. Landscape Industry Certified Lawn Care Technician.
  - 5. Pesticide Applicator: State licensed, commercial.

#### 1.8 DELIVERY, STORAGE, AND HANDLING

- A. Seed and Other Packaged Materials: Deliver packaged materials in original, unopened containers showing weight, certified analysis, name and address of manufacturer, and indication of compliance with state and Federal laws, as applicable.
- B. Bulk Materials:
  - 1. Do not dump or store bulk materials near structures, utilities, walkways and pavements, or on existing turf areas or plants.
  - 2. Accompany each delivery of bulk materials with appropriate certificates.



#### 1.9 FIELD CONDITIONS

- A. Planting Restrictions: Plant during one of the following periods. Coordinate planting periods with initial maintenance periods to provide required maintenance from date of Substantial Completion .
  - 1. Spring Planting: April 15 May 15.
- B. Weather Limitations: Proceed with planting only when existing and forecasted weather conditions permit planting to be performed when beneficial and optimum results may be obtained. Apply products during favorable weather conditions according to manufacturer's written instructions.

#### PART 2 - PRODUCTS

- 2.1 SEED
  - A. Grass Seed: Fresh, clean, dry, new-crop seed complying with AOSA's "Rules for Testing Seeds" for purity and germination tolerances.
  - B. Seed Species:
    - 1. Quality: Seed of grass species as listed below for solar exposure, with not less than 85 percent germination, not less than 95 percent pure seed, and not more than 0.5 percent weed seed:
  - C. Grass-Seed Mix: Seed mix as follows:
    - 30% Improved Per. Rye
      30% Turf Type Tall Fescue
      30% Chewing Fescue
      5% Creeping Red Fescue
      5% Miniature or Dutch White Clover
    - 2. Products may be acquired from the following source (or approved equal) : Allen's Seed Store : 693 S County Trail Exeter, RI 02822 Phone: 401 294 2722

#### 2.2 FERTILIZERS

- A. Commercial Fertilizer: Commercial-grade complete fertilizer of neutral character, consisting of fast- and slow-release nitrogen, 50 percent derived from natural organic sources of urea formaldehyde, phosphorous, and potassium in the following composition:
  - 1. Composition: fertilizer to have a ratio of 18 Nitrogen (N) 24 Phosphorous (P) 12 Potassium (K)
- B. Slow-Release Fertilizer: Granular or pelleted fertilizer consisting of 50 percent water-insoluble nitrogen, phosphorus, and potassium in the following composition:



1. Composition: fertilizer to have a ratio of 18 Nitrogen (N) - 24 Phosphorous (P) - 12 Potassium (K)

## PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Examine areas to be planted for compliance with requirements and other conditions affecting installation and performance of the Work.
  - 1. Verify that no foreign or deleterious material or liquid such as paint, paint washout, concrete slurry, concrete layers or chunks, cement, plaster, oils, gasoline, diesel fuel, paint thinner, turpentine, tar, roofing compound, or acid has been deposited in soil within a planting area.
  - 2. Suspend planting operations during periods of excessive soil moisture until the moisture content reaches acceptable levels to attain the required results.
  - 3. Uniformly moisten excessively dry soil that is not workable or which is dusty.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.
- C. If contamination by foreign or deleterious material or liquid is present in soil within a planting area, remove the soil and contamination as directed by Landscape Architect and replace with new planting soil.

#### 3.2 PREPARATION

- A. Protect structures; utilities; sidewalks; pavements; and other facilities, trees, shrubs, and plantings from damage caused by planting operations.
  - 1. Protect adjacent and adjoining areas from hydroseeding and hydromulching overspray.
  - 2. Protect grade stakes set by others until directed to remove them.

#### 3.3 TURF AREA PREPARATION

and use of this document for any other project.(16521)

- A. General: Prepare planting area for soil placement and mix planting soil according to Section 329113 "Soil Preparation."
- B. Placing Planting Soil: Place and mix planting soil in place over exposed subgrade .
- C. Moisten prepared area before planting if soil is dry. Water thoroughly and allow surface to dry before planting. Do not create muddy soil.
- D. Before planting, obtain Landscape Architect's acceptance of finish grading; restore planting areas if eroded or otherwise disturbed after finish grading.



#### 3.4 SEEDING

- A. Sow seed with spreader or seeding machine. Do not broadcast or drop seed when wind velocity exceeds 5 mph.
  - 1. Evenly distribute seed by sowing equal quantities in two directions at right angles to each other.
  - 2. Do not use wet seed or seed that is moldy or otherwise damaged.
  - 3. Do not seed against existing trees. Limit extent of seed to outside edge of planting saucer.
- B. Sow seed at a total rate of 5 to 7 lb/1000 sq. ft.
- C. Rake seed lightly into top 1/8 inch of soil, roll lightly, and water with fine spray.

#### 3.5 HYDROSEEDING

- A. Hydroseeding: Mix specified seed, fertilizer, and fiber mulch in water, using equipment specifically designed for hydroseed application. Continue mixing until uniformly blended into homogeneous slurry suitable for hydraulic application.
  - 1. Mix slurry with fiber-mulch manufacturer's recommended tackifier.
  - 2. Spray-apply slurry uniformly to all areas to be seeded in a one-step process. Apply slurry at a rate so that mulch component is deposited at not less than 1500-lb/acre dry weight, and seed component is deposited at not less than the specified seed-sowing rate.

#### 3.6 TURF RENOVATION

- A. Renovate turf damaged by Contractor's operations, such as storage of materials or equipment and movement of vehicles.
  - 1. Reestablish turf where settlement or washouts occur or where minor regrading is required.
  - 2. Install new planting soil as required.
- B. Remove sod and vegetation from diseased or unsatisfactory turf areas; do not bury in soil.
- C. Remove topsoil containing foreign materials, such as oil drippings, fuel spills, stones, gravel, and other construction materials resulting from Contractor's operations, and replace with new planting soil.
- D. Mow, dethatch, core aerate, and rake existing turf.
- E. Remove weeds before seeding. Where weeds are extensive, apply selective herbicides as required. Do not use pre-emergence herbicides.
- F. Remove waste and foreign materials, including weeds, soil cores, grass, vegetation, and turf, and legally dispose of them off Owner's property.

Copyright © 2021 by the American Institute of Architects. Warning: This AIA MasterSpec-based document is protected by U.S. Copyright Law and International Treaties. It was created by "Providence Parks Dept" for "Blackstone Boulevard Path Improvements 2021". A valid, current MasterSpec license is required for editing and use of this document for any other project.(16521)



- G. Till stripped, bare, and compacted areas thoroughly to a soil depth of 6 inches .
- H. Apply soil amendments and initial fertilizer required for establishing new turf and mix thoroughly into top 4 inches of existing soil. Install new planting soil to fill low spots and meet finish grades.
  - 1. Initial Fertilizer: Commercial fertilizer applied according to manufacturer's recommendations.
- I. Water newly planted areas and keep moist until new turf is established.

#### 3.7 TURF MAINTENANCE

- A. General: Maintain and establish turf by watering, fertilizing, weeding, mowing, trimming, replanting, and performing other operations as required to establish healthy, viable turf. Roll, regrade, and replant bare or eroded areas and remulch to produce a uniformly smooth turf. Provide materials and installation the same as those used in the original installation.
  - 1. Fill in as necessary soil subsidence that may occur because of settling or other processes. Replace materials and turf damaged or lost in areas of subsidence.
  - 2. In areas where mulch has been disturbed by wind or maintenance operations, add new mulch and anchor as required to prevent displacement.
  - 3. Apply treatments as required to keep turf and soil free of pests and pathogens or disease. Use integrated pest management practices whenever possible to minimize the use of pesticides and reduce hazards.
- B. Watering: Install and maintain temporary piping, hoses, and turf-watering equipment to convey water from sources and to keep turf uniformly moist to a depth of 4 inches.
  - 1. Schedule watering to prevent wilting, puddling, erosion, and displacement of seed or mulch. Lay out temporary watering system to avoid walking over muddy or newly planted areas.
  - 2. Water turf with fine spray at a minimum rate of 1 inch per week unless rainfall precipitation is adequate.
- C. Mow turf as soon as top growth is tall enough to cut. Repeat mowing to maintain specified height without cutting more than one-third of grass height. Remove no more than one-third of grass-leaf growth in initial or subsequent mowings. Do not delay mowing until grass blades bend over and become matted. Do not mow when grass is wet. Schedule initial and subsequent mowings to maintain the following grass height:
  - 1. Mow to a height of 1-1/2 to 2 inches.

#### 3.8 SATISFACTORY TURF

A. Turf installations shall meet the following criteria as determined by Landscape Architect:



- 1. Satisfactory Seeded Turf: At end of maintenance period, a healthy, uniform, close stand of grass has been established, free of weeds and surface irregularities, with coverage exceeding 90 percent over any 10 sq. ft. and bare spots not exceeding 5 by 5 inches.
- B. Use specified materials to reestablish turf that does not comply with requirements, and continue maintenance until turf is satisfactory.

#### 3.9 CLEANUP AND PROTECTION

- A. Promptly remove soil and debris created by turf work from paved areas. Clean wheels of vehicles before leaving site to avoid tracking soil onto roads, walks, or other paved areas.
- B. Remove surplus soil and waste material, including excess subsoil, unsuitable soil, trash, and debris, and legally dispose of them off Owner's property.
- C. Erect temporary fencing or barricades and warning signs as required to protect newly planted areas from traffic. Maintain fencing and barricades throughout initial maintenance period and remove after plantings are established.

#### 3.10 MAINTENANCE SERVICE

- A. Turf Maintenance Service: Provide full maintenance by skilled employees of landscape Installer. Maintain as required in "Turf Maintenance" Article. Begin maintenance immediately after each area is planted and continue until acceptable turf is established, but for not less than the following periods:
  - 1. Seeded Turf: 60 days from date of Substantial Completion.
    - a. When initial maintenance period has not elapsed before end of planting season, or if turf is not fully established, continue maintenance during next planting season.

END OF SECTION 329200

## VICINITY MAP





- I. BASE INFORMATION OBTAINED FROM SURVEY INFORMATION BY NATIONAL SURVEYORS-DEVELOPERS INC DATED NOVEMBER 2020 AND RIDEM GIS IMAGERY. ALL EXISTING CONDITIONS ARE TO BE CONSIDERED APPROXIMATE.
- 2. ANY ERRORS OR DISCREPANCIES ON THE DRAWINGS, SHOP DRAWINGS, AND DETAILS ARE TO BE BROUGHT TO THE ATTENTION OF THE OWNER'S REPRESENTATIVE BEFORE THE WORK HAS COMMENCED
- 3. THE CONTRACTOR IS RESPONSIBLE FOR FIELD VERIFICATION OF ALL LOCATIONS AND DIMENSIONS. DISCREPANCIES BETWEEN LAYOUT DIMENSIONS ON PLANS AND ACTUAL MEASUREMENTS IN FIELD ARE TO BE REPORTED TO THE OWNER'S REPRESENTATIVE BEFORE CONSTRUCTION BEGINS.
- 4. THE CONTRACTOR SHALL NOTIFY THE OWNER'S REPRESENTATIVE PRIOR TO DEMOLITION OR INSTALLATION OF ANY PORTION OF THE SITE WORK .
- 5. THE CONTRACTOR SHALL STAKE OUT ALL LAYOUTS OF PROPOSED WORK FOR APPROVAL BY THE OWNER'S REPRESENTATIVE PRIOR TO COMMENCING WORK.
- 6. ANY AREAS DISTURBED BY EQUIPMENT AND/OR MATERIAL STORAGE ARE TO BE RESTORED TO ORIGINAL OR BETTER CONDITION BY THE CONTRACTOR AT THE CONTRACTOR'S EXPENSE BEFORE COMPLETION OF THE PROJECT. AND ARE SUBJECT TO APPROVAL BY OWNER'S REPRESENTATIVE.
- 7. THE CONTRACTOR IS RESPONSIBLE FOR KEEPING THE SITE CLEAN OF MISCELLANEOUS DEBRIS THROUGHOUT THE CONSTRUCTION PERIOD. ALL WASTE MATERIAL IS TO BE LEGALLY DISPOSED OF AT AN OFF-SITE LOCATION. UNLESS OTHERWISE INDICATED ON THE PLAN.
- 8. THE CONTRACTOR IS RESPONSIBLE FOR SECURING THE SITE FOR THE SAFETY OF THE GENERAL PUBLIC AND TO PROTECT PROPERTY AGAINST VANDALISM AND THEFT.
- 9. THE CONTRACTOR MUST OBTAIN ALL REQUIRED CITY, STATE AND FEDERAL PERMITS.
- IO. THE PROVIDENCE PARKS DEPARTMENT ASSUMES NO RESPONSIBILITY IF THE WORK IS NOT INSTALLED AS PER THE PLANS OR IF FIELD CHANGES ARE MADE WITHOUT THE KNOWLEDGE AND APPROVAL OF OWNER'S REPRESENTATIVE.



# EROSION AND SEDIMENT CONTROL (ESC)

# PROVIDENCE, RI BLACKSTONE BLVD PATH IMPROVEMENTS PROJECT



NIRVA LAFORTUNE **CITY COUNCILOR** 

WENDY NILSSON, SUPERINTENDENT OF PARKS **ISSUED FOR BID 9/27/21** 

I. THE SITE CONSTRUCTION FOREMAN SHALL BE DESIGNATED AS THE ON-SITE PERSONNEL RESPONSIBLE FOR THE DAILY INSPECTION AND MAINTENANCE OF ALL ESC MEASURES AND SHALL IMPLEMENT ALL NECESSARY MEASURES TO CONTROL EROSION AND PREVENT SEDIMENT FROM LEAVING THE SITE

THE CONTRACTOR SHALL INSTALL ALL ESC MEASURES AS SHOWN ON THE DESIGN PLANS AND AS DETERMINED NECESSARY IN THE FIELD BY OWNER'S REPRESENTATIVE BEFORE ANY CONSTRUCTION TO BEGIN. THESE MEASURES SHALL BE CHECKED, MAINTAINED/REPLACED AS NECESSARY DURING THE ENTIRE CONSTRUCTION PERIOD OF THE PROJECT. SUCH MEASURES SHALL REPRESENT THE LIMIT OF WORK. WORKERS SHALL BE INFORMED THAT NO CONSTRUCTION ACTIVITY IS TO OCCUR BEYOND THE LIMIT OF WORK AT ANY TIME THROUGH THE CONSTRUCTION PERIOD.

3. A MINIMUM SURPLUS OF 100 FEET OF EROSION CONTROL BARRIER (SILT FENCE #/OR SILT SOCK) SHALL BE STOCKPILED ONSITE AT ALL TIMES.

4. THE CONTRACTOR SHALL PROTECT THE ADJACENT AREA FROM SEDIMENTATION DURING PROJECT CONSTRUCTION OPERATIONS.

5. A CONSTRUCTION EXIT SHALL BE CONSTRUCTED TO SHED DIRT FROM CONSTRUCTION VEHICLE TIRES. THE CONSTRUCTION EXIT SHALL BE REPLACED/CLEANED AS NEEDED TO MAINTAIN ITS EFFECTIVENESS.

6. THE LIMIT OF ALL CLEARING. GRADING AND DISTURBANCES SHALL BE KEPT TO A MINIMUM WITHIN THE PROPOSED AREA OF CONSTRUCTION. THE CONTRACTOR SHALL PHASE THE SITE WORK IN A MANNER TO MINIMIZE AREAS OF EXPOSED SOIL.

7. IT IS THE CONTRACTOR'S RESPONSIBILITY TO MONITOR LOCAL WEATHER REPORTS DURING CONSTRUCTION AND PRIOR TO SCHEDULING EARTHMOVING OR OTHER CONSTRUCTION ACTIVITIES WHICH WILL LEAVE LARGE DISTURBED AREAS UNSTABILIZED. IF INCLEMENT WEATHER IS PREDICTED, THE CONTRACTOR SHALL USE THEIR BEST PROFESSIONAL JUDGEMENT AND SHALL BE RESPONSIBLE FOR ENSURING THAT NECESSARY EROSION CONTROL DEVICES ARE INSTALLED AND FUNCTIONING PROPERLY TO MINIMIZE EROSION FROM ANY IMPENDING WEATHER EVENTS.

8. SOIL ESC MEASURES SHALL BE INSPECTED AND MAINTAINED ON A WEEKLY BASIS AND AFTER EACH RAINFALL EVENT OF 0.25 INCH OR GREATER DURING CONSTRUCTION TO ENSURE THAT THE ESC MEASURES ARE INTACT AND FUNCTIONING PROPERLY. IDENTIFIED DEFICIENCIES SHALL BE CORRECTED IMMEDIATELY NO LATER THAN 24 HOURS AFTER IDENTIFICATION.

9. SOIL STOCKPILES LEFT OVERNIGHT SHALL BE SURROUNDED ON THEIR PERIMETERS WITH SILT SOCK.

IO. DISTURBED AREAS AND SLOPES SHALL NOT BE LEFT UNATTENDED OR EXPOSED FOR EXCESSIVE PERIODS OF TIME SUCH AS THE INACTIVE WINTER SEASON. THE CONTRACTOR SHOULD PROVIDE APPROPRIATE STABILIZATION PRACTICES ON ALL DISTURBED AREAS AS SOON AS POSSIBLE BUT NOT MORE THAN 14 DAYS AFTER THE CONSTRUCTION ACTIVITY IN THAT AREA HAS TEMPORARILY OR PERMANENTLY CEASED. TEMPORARY AREAS HAVING A SLOPE GREATER THAN 3:1 SHALL BE REINFORCED WITH EROSION BLANKETS OR APPROVED EQUAL UNTIL THE SITE IS PROPERLY STABILIZED. TEMPORARY SWALES MAY ALSO BE REQUIRED IF DETERMINED NECESSARY IN THE FIELD BY OWNER'S REPRESENTATIVE.

II. THE CONTRACTOR SHALL CONTAIN ALL SEDIMENT ONSITE. ALL EXITS FROM THE SITE WILL BE SWEPT AS NECESSARY INCLUDING ANY SEDIMENT TRACKING. PAVED AREAS SHALL BE SWEPT AS NEEDED TO REMOVE SEDIMENT AND POTENTIAL POLLUTANTS WHICH MAY ACCUMULATE DURING SITE WORK.

12. ACCUMULATED SEDIMENT SHALL BE REMOVED FROM ALL ESC MEASURES AND DISPOSED OF IN A PRE-APPROVED LOCATION BY THE CONTRACTOR.

13. DUST SHALL BE CONTROLLED BY WATERING OR OTHER APPROVED METHODS AS NECESSARY.

## SHEET SCHEDULE

SHEET #	Ν
L-	С
L-2-4	E
L-5-7	S

# CONSTRUCTION DETAILS

DETAIL #	SHEET #	TITLE	NOTES
I	L-3	DRIPLINE TREE PROTECTION	AS SHOWN ON PLANS
2	L-3	TREE TRUNK PROTECTION	AS NOTED ON PLANS
3	L-4	SILT SOCK	INSTALL AT PATH ENDS
4	L-4	CATCH BASIN SEDIMENT TRAP	ROCHAMBEAU AVE
5	L-6	I 2' W STONEDUST PATH	
6	L-6	I 2'W CHIP SEAL PAVEMENT	PATH ENDS
7	L-6	POURED CONCRETE PAD	BENCHES & TRASH RECEPTACLE
8	L-7	LOAM AND HYDROSEED	SIDES OF PATH ∉ DISTURBED AREAS
9	L-7	BOULDER IN PATH	+/- 15' FROM PATH ENDS
10	L-7	55 GAL. TRASH RECEPTACLE	ADD/ALTERNATE # I
	L-7	STABILIZED STONEDUST PATH	ADD/ALTERNATE #2

## LEGEND

×97.96	EXISTING GRADE	
+97.83	PROPOSED GRADE	
<u> </u>	EXISTING CONTOUR	, v v v v v v v
99	PROPOSED CONTOUR	
$\circ$	EXISTING TREES	
oo	TREE PROTECTION FENCE	
LOW	LIMIT OF WORK	
SS	SILT SOCK	

IAME

COVER SHEET

XISTING CONDITIONS/DEMOLTION PLANS ITE CONSTRUCTION/GRADING PLANS

EXISTING PATH TO BE REMOVED EXISTING LAWN TO BE REMOVED ASPHALT CHIP-SEAL STONEDUST PATH

PARKS DEPARTMENT DALRYMPLE BOATHOUSE ROGER WILLIAMS PARK PROVIDENCE, RI 02907 COPYRIGHT (C) CITY OF PROVIDENCE PARKS DEPARTMENT, ALL RIGHTS RESERVED 2021 FPRODUCED STORED IN A RETRIEV RKS DEPARTMENT SHALL RENDER NVALID AND UNUSAB NO. REVISION PROJEC Ζ ∑ Ш К О И M  $\square$ **A** <u>E</u> Ω 4  $\square$ > > BL' BDL S NO N ZP O S РÓ S **⊲** X M 20 C بې ک 0 **Bl** DATE: 9/16/21 SCALE: DRAWN BY: SHEET NO.

SG

CHECKED/ APPROVED: MG

OF **7** 

PROVIDENCE



BETWEEN THE PROPOSED UTILITIES AND FIELD-LOCATED UTILITIES AND SHALL REPORT ANY DISCREPANCIES TO THE LANDSCAPE ARCHITECT IMMEDIATELY. THE OWNER ASSUMES NO RESPONSIBILITY FOR DAMAGES INCURRED AS A RESULT OF UTILITIES OMITTED, INCOMPLETELY OR INACCURATELY SHOWN. THE CONTRACTOR SHALL BE RESPONSIBLE FOR MAINTAINING ACCURATE RECORDS OF THE LOCATION AND ELEVATION OF ALL WORK INSTALLED AND EXISTING UTILITIES FOUND DURING CONSTRUCTION FOR THE PREPARATION OF THE AS-BUILT PLAN.

PROVIDENCE

PARKS DEPARTMENT

DALRYMPLE BOATHOUSE

ROGER WILLIAMS PARK

PROVIDENCE, RI 02907

2 OF

6. THE CONTRACTOR IS RESPONSIBLE FOR MAINTAINING ALL EXISTING UTILITIES IN WORKING ORDER AND FREE FROM DAMAGE DURING THE ENTIRE DURATION OF THE PROJECT. ALL COST RELATED TO THE REPAIR OF UTILITIES SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR. EXCAVATION REQUIRED WITHIN THE PROXIMITY OF EXISTING UTILITY LINES SHALL BE DONE BY HAND. CONTRACTOR SHALL REPAIR ANY DAMAGE TO EXISTING UTILITY LINE OR STRUCTURES INCURRED DURING CONSTRUCTION OPERATIONS AT NO COST TO THE OWNER.

COPYRIGHT (C) CITY OF PROVIDENCE PARKS DEPARTMENT, ALL RIGHTS RESERVED 2021. 7. THE CONTRACTOR SHALL MAINTAIN CONTINUOUS ACCESS AND OPERATION FOR NO PART OF THIS DOCUMENT MAY BE SURROUNDING FACILITIES, AS DEEMED BY THE OWNER, AT ALL TIMES DURING REPRODUCED, STORED IN A RETRIEVAL BYSTEM OR TRANSMITTED IN ANY FORM OF DEMOLITION OF THE EXISTING FACILITIES. BY ANY MEANS, ELECTRONIC, MECHANICAL PHOTOCOPYING, RECORDING OR OTHERWIS WITHOUT THE PRIOR WRITTEN PERMISSION 8. PRIOR TO DEMOLITION OCCURRING, ALL EROSION CONTROL DEVISES AND TREE OF THE CITY OF PROVIDENCE PARKS DEPARTMENT. ANY MODIFICATIONS TO TH PROTECTIVE MEASURES ARE TO BE INSTALLED. DOCUMENT WITHOUT THE WRITTEN PERMISSION OF THE CITY OF PROVIDENCE PARKS DEPARTMENT SHALL RENDER IT INVALID AND UNUSABLE. NO. DATE REVISION  $\overline{}$ 274 BLACKSTONE BLVD Ш 3 ` Ŷ F#I SILT SOCK OR OTHER TEMPORARY SILT PROTECTION DURING ACTIVE Ω CONSTRUCTION (TYP)  $\geq$ KALMIA, CLE MULTI-STEM (REMOVE POSION IVY. WEED TREES) Ш 2 Ш QUERCUS -EX. GAZEBO ALUSTRIS S Z W/ BENCH Ľ 95.35 ,95.4) Ux 96.32 MP C PAT ×94.80 94.57 MOL CO BLVD E BOULEV  $\overline{\mathsf{O}}$  $\bigcirc$ KSTONE BLACKSTONE \_∎⊢ C 1 \ L-3 7 - 40" QUERCL RUBRA ₽₽ (TYP) 24" QUERCUS · RUBRA UH UH UH MAT S 350 BROOKWAY RD **BL** 240 Ш DATE: 9/16/21 SCALE: 1"=20'-0" DRAWN BY: SHEET NO. SG L-2 10 20 CHECKED/ APPROVED: MG









NO PART OF THIS DOCUMENT MAY BE REPRODUCED, STORED IN A RETRIEVAL YSTEM OR TRANSMITTED IN ANY FORM OF BY ANY MEANS, ELECTRONIC, MECHANICAL PHOTOCOPYING, RECORDING OR OTHERWIS WITHOUT THE PRIOR WRITTEN PERMISSION OF THE CITY OF PROVIDENCE PARKS DEPARTMENT. ANY MODIFICATIONS TO TH DOCUMENT WITHOUT THE WRITTEN PERMISSION OF THE CITY OF PROVIDENCE PARKS DEPARTMENT SHALL RENDER IT INVALID AND UNUSABLE.

NO.	REVISION	DATE

 $\mathcal{O}$ Ш  $\bigcirc$ Ľ Ω ഗ  $\geq$ Z Ш  $\overline{}$ 2  $\leq$ Ш S Z Ο Ľ ЧМ C PAT **BLVD** E BOULEV  $\bigcirc$ **KSTONE** BLACKSTONE C Ζ <u>S</u> AC 350  $\times$ **BL** 240 ш

AIE:	
	9/16/21

SCALE:

DRAWN BY:

CHECKED/ APPROVED: MG

SG

4 11.	

1"=20'-0"

SHEET NO.

4 OF 7

L-4









