



CITY OF PROVIDENCE, RHODE ISLAND

Department: Public Property

RFP Title: Gym Floor Replacement and Striping at Anthony Carnevale Elementary School, Gym Floor Striping at Narducci Learning Center

Opening Date: Monday 3/10/2025

Addendum #: #2

Issue Date: 3/6/2025

The purpose of this addendum is to add the answers to the previous Addendum and to add the sign in sheet.

Q1 Carnevale Moister barrier. Do you require a moister mitigation type barrier with warranty or a poly type moister barrier? There are no specs on it.

A-1 we would like a Moisture mitigation type with a warranty.

Q2 Narducci There are 2 Gym floors and only one is specified are we doing both?

A-2 There are 2 Gym Floors in Narducci and both are to be done.

Q3 Narducci The floor is VCT tile and it specifies rubber was this and error?

A-3 Yes, this is an error and the VCT that is in place is the product to put the stripping on.

Q4 Narducci In order to have good paint adhesion the floor should be stripped and re wax . Will this be part of the scope?

A4- Stripping and re-wax to e included in this contract.

Q5 Narducci Is there Pattern, layout, and color selection for the court markings?

A5 Yes, standard Basketball markings

Q6 What is the expected time frame for completion?

A6 June 30, 2025

Q7 Are there any limitations for hours of operation?

A7 April school break there will be access to both Narducci and Carnevale. Narducci should be able to be completed that week. We will send a follow up 3/7/2025 on Carnevale schedule.

Q8 What is the earliest start date?

A8 April 12, 2025 in Narducci, April 12, 2025 for Carnevale.

Q9 Are there certain patterns or logos being applied?

A-9 In Carnevale match the existing logo, no logo for Narducci.

Q10 Carnevale There seems to be a substantial gap between the base and finished floor height are there any allowances for unforeseen circumstances. Example door frames and thresh holds may need to be removed?

A10 there are currently no allowances or contingencies. If you know it has to be done, include it in your quote.

