



Procurement #: 54386

CITY OF PROVIDENCE, RHODE ISLAND

Department: Public Property

RFP Title: Providence City Hall Envelope Restoration - Phase 1

Opening Date: 2 Nov 2026

Addendum #: 6

Issuing Date: 8 Oct 2026

The purpose of this addendum is:

Bidders have submitted additional questions relating to the scope of work on this project. Responses from the City's design team are attached.

Providence City Hall
25 Dorrance Street
Providence, RI 02903

Providence City Hall Envelope Restoration – Phase 1

Addendum #6 – Response to Bidder Questions 2

10/8/26

The purpose of this addendum is to respond to questions sent in by prospective bidders. Design team responses are below in **RED**.

1. Is there an anticipated amount of New Parge Coat installed on the existing masonry?
 - a. **DBVW: Refer to detail 3/A504; assume parge coat is required over all areas at the base of the dome that are currently clad in sheet metal, approx. 900 square feet (vertical surface area).**
2. Detail 5/ A501, please confirm that the assumed max depth of the tooling repair is 1/2"
 - a. **DBVW: Confirmed.**
3. In the event that the depth is greater than 1/2" we are to perform a dutchman repair. Is there an anticipated number of units that require a dutchman?
 - a. **DBVW: We have not identified any required dutchman repairs at this time. If areas indicated for tooling repair are determined to require dutchman repairs, or any other dutchman repairs are identified during construction, this will be resolved as a change in scope.**



Dan Kittridge

Capital Improvement Project Manager

Pronoun: he/him/his
Department of Public Property
Providence City Hall
25 Dorrance Street
Providence, RI 02903
dkittridge@providenceri.gov
Cell: (401) 473-8418